A2	PROSOIL	BOREHOLE NO: BH-1	
		LOCATION: Paharia Kandi, Bancharampur 2, B.Baria.	
PROJECT : Telecommunication Tower.		DEPTH OF BORING: 21.0m	R. L.: On Road Level.
CLIENT : AXIATA (Bangladesh) Ltd.		DATE OF BORING: 22-06-2010.	G. W. T : 0.31m below from E. G. L.

THICKNESS	SOIL STRATA	BORELOG	UNDISTURBED SAMPLE	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Grain Size Distribution, % Clay %, Silt %, Sand %	Max^{m} Penetration
2.0m	Very pale Brown 10YR (8/3), loose to very loose, fine Sand, SM.			D-1 to D-2	3, 1		
1.0m	Very pale Brown 10YR (8/3), very loose to loose, Silt, ML.			D-2 to D-3	1, 5		
4.0m	Very pale Brown 10YR (8/3), loose to very dense, fine Sand, SM.			D-3 to D-6	5, 5, 7, 8		
14.45m	Light bluish Gray Gley2 (7/1), medium dense very dense, fine Sand, SM.			D-7 to D-17	30, 20, 9, 14, 36, 36, 30, 31, 34, 37, 37		

LEGEND FOR BORELOG AND GRAIN SIZE DISTRIBUTION (BASED ON 'ASTM CLASSIFICATION D-2487')

- PLASTIC CLAY
- SAND
- SILT
- SHALE
- PEAT/HIGHLY ORGANIC SOIL
- MICACEOUS FINE SAND/SILT
- UNDISTURBED SAMPLE
- DISTURBED SAMPLE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS

AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED