A2	PROSOIL	BOREHOLE NO: BH-1	
		LOCATION: Atia Mahmudpur, Mirzapur, Tangail.	
PROJECT : Telecommunication Tower.		DEPTH OF BORING: 21.0m	R. L.: 1.83m below from Road Level.
CLIENT : Grameenphone Ltd.		DATE OF BORING: 07-06-2012.	G. W. T : 3.05m below from E. G. L.

THICKNESS	SOIL STRATA	BORELOG	UNDISTURBED SAMPLE	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Grain Size Distribution, % Clay %, Silt %, Sand %	Max^{m} Penetration
2.0m	Gray 10YR (6/1), loose, Silt, ML.			D-1 D-2 D-3	3 4 6		
5.5m	Brown 7.5YR (5/4), loose to medium dense, fine Sand, SM.			D-4 D-5 D-6 D-7	7 9 10 8		
6.0m	Light Gray 10YR (7/1), medium dense to dense, Sand(with mica), SM.			D-8 D-9 D-10 D-11	10 16 29 31		
7.95m	Light Gray 10YR (7/1), dense to very dense, coarse Sand, SM.			D-12 D-13 D-14 D-15 D-16	36 40 50 50 50		Over Over Over

LEGEND FOR BORELOG AND GRAIN SIZE DISTRIBUTION (BASED ON 'ASTM CLASSIFICATION D-2487')

PLASTIC CLAY | SHALE | SILT | SAND

PEAT/HIGHLY ORGANIC SOIL | MICACEOUS FINE SAND/SILT | UNDISTURBED SAMPLE | DISTURBED SAMPLE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS

AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED