A2	PROSOIL	BOREHOLE NO: BH-1	
		LOCATION: Shalpara Bazar, Panchbibi, Joypurhat.	
PROJECT : Telecommunication Tower.		DEPTH OF BORING: 21.0m	R. L.: 1.10m below from Road Level.
CLIENT : Grameenphone Ltd.		DATE OF BORING: 02-08-2012.	G. W. T : 0.30m above from E. G. L.

THICKNESS	SOIL STRATA	BORELOG	UNDISTURBED SAMPLE	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Grain Size Distribution, % Clay %, Silt %, Sand %	Max^{m} Penetration
2.0m	Brown 10YR (5/3), medium dense to dense, Silt, ML.			D-1	7		
				D-2	17		
2.0m	Light Brown 7.5YR (6/3), dense, fine Sand, SM.			D-3	20		
				D-4	10		
3.5m	Brown 10YR (5/3), dense, fine Sand, SM.			D-5	17		
				D-6	21		
13.95m	Gray 10YR (5/1), dense to very dense, fine Sand, SM.			D-7	26		
				D-8	25		
				D-9	30		
				D-10	28		
				D-11	32		
				D-12	37		
				D-13	35		
				D-14	38		
				D-15	34		
				D-16	38		

LEGEND FOR BORELOG AND GRAIN SIZE DISTRIBUTION (BASED ON 'ASTM CLASSIFICATION D-2487')

PLASTIC CLAY | SHALE | SILT | SAND

PEAT/HIGHLY ORGANIC SOIL | MICACEOUS FINE SAND/SILT | UNDISTURBED SAMPLE | DISTURBED SAMPLE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS

AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED