A2	PROSOIL	BOREHOLE NO: 04	Latitude: N 23°35'52.56"	Longitude: E 90°31'16.64"
		Name of Project: Engineering Soil Mapping of Meghna as per Soil Classification of road master plan (Dhaka, Comilla, Narayangonj, Munshigonj).		
CLIENT : BRRL.		Type of Drill Rig: Manual Rotary	Borehole Depth: 51.0m	RL: -4.0 m
Location: Modonpur.		Commencement Date: 19-05-2015	Completed Date: 20-05-2015	G. W. T : -1.5 m

THICKNESS	SOIL STRATA	BORE LOG	SAMPLING From (m)	SAMPLING To (m)	SPT-N Value Blow/300mm N1=150 (mm)	N2=300 (mm)	N3=450 (mm)	N=N2+N3	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	% Sand	% Passing 200	% LL	% PI	SP Gravity	% W_n
18.0m	Gray 7.5YR (5/1), medium plastic, soft to very stiff, silty clay, CL.		1.5	1.95	1	2	3	5	D-1	5			49.4	33.6		
									UD-1		1.2	98.8	51.4	39.5		
			3	3.45	2	3	4	7	D-2	7			50	30.3		
									UD-2							
			4.5	4.95	3	4	5	9	D-3	9						
									UD-3		0.1	99.9	48.4	42.7		
			6	6.45	3	4	6	10	D-4	10						
									UD-4				46.7	33.1		
			7.5	7.95	3	5	7	12	D-5	12						
									UD-5		0.8	99.2	41.8	12.3		
			9	9.45	4	5	6	11	D-6	11						
									UD-6				46.7	17.8		
			10.5	10.95	5	7	10	17	D-7	17						
									UD-7		0.3	99.7	47.5	28.4	2.634	
			12	12.45	6	8	12	20	D-8	20						
									UD-8				50.9	33.2		
			13.5	13.95	5	7	11	19	D-9	19						
			15	15.45	6	9	14	23	D-10	23	0.4	99.6	53.8	34.3	2.658	
			16.5	16.95	7	10	13	23	D-11	23			57.2	36.4		
			18	18.45	16	18	24	42	D-12	42	1.7	98.3	39.7	14.2	2.63	
									UD-9				44.8	28.1	2.711	
			19.5	19.95	16	17	21	38	D-13	38						
									UD-10		3.5	96.5	39.9	22.7	22.7	
			21	21.45	13	16	18	34	D-14	34						
									UD-11				47.1	28.9	2.631	20.86
			22.5	22.95	15	18	22	40	D-15	40	1.3	98.7	36.5	14.4		19.56
16.5m	Grayish brown 10YR (5/2), medium plastic, hard, silty clay, CL.		24	24.45	15	18	20	38	D-16	38			53.8	37.3	2.681	20.01
			25.5	25.95	13	16	19	35	D-17	35	3.7	96.3	55.1	34.5		11.88
			27	27.45	16	19	23	42	D-18	42			48.7	18	2.67	17.97
			28.5	28.95	12	16	18	34	D-19	34						

RL WITH REPECT TO SUB.

LEGEND FOR BORELOG AND GRAIN SIZE DISTRIBUTION (BASED ON 'ASTM CLASSIFICATION D-2487')

PLASTIC CLAY | SILT | PEAT/HIGHLY ORGANIC SOIL | UNDISTURBED SAMPLE

MICACEOUS FINE SAND/SILT | SAND | SHALE | DISTURBED SAMPLE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX[m] PENETRATION= 50 BLOWS. AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED

50/X = BLOWS 50, "X" MM PENETRATION left of 300 mm