A2	PROSOIL	BOREHOLE NO: BH-1	
		LOCATION: Sreerampur, Horisonkorpur, Magura Sadar, Magura.	
PROJECT : Telecommunication Tower.		DEPTH OF BORING: 21.0m	R. L.: 0.49m below from Road Level.
CLIENT : Grameenphone Ltd.		DATE OF BORING: 19-03-2015.	B. W. T : 3.35m below from E. G. L.

THICKNESS	SOIL STRATA	BORELOG	UNDISTURBED SAMPLE	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Grain Size Distribution, % Clay %, Silt %, Sand %	Max^{m} Penetration
1.0m	Gray 7.5YR (5/1), medium plasticity, very soft, Clay, CL.			D-1	2		
4.0m	Brown 7.5YR (5/3), very loose to medium dense, Silt, ML.			D-2 D-3 D-4 D-5 D-6	5 4 7 11 7		
8.5m	Gray 7.5YR (5/1), loose to medium dense, silty Sand, SM.			D-7 D-8 D-9 D-10 D-11	6 9 10 13 12		
7.95m	Gray 7.5YR (5/1), medium dense to very dense, fine Sand, SM.			D-12 D-13 D-14 D-15 D-16	18 22 26 30 32		

YL

LEGEND FOR BORELOG AND GRAIN SIZE DISTRIBUTION (BASED ON 'ASTM CLASSIFICATION D-2487')

PLASTIC CLAY | SHALE | SILT | SAND

PEAT/HIGHLY ORGANIC SOIL | MICACEOUS FINE SAND/SILT | UNDISTURBED SAMPLE | DISTURBED SAMPLE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS

AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED