A2	PROSOIL	BOREHOLE NO: BH-1	
		LOCATION : Delpara, Ward no# 03, Saint Martin, Teknaf, Cox's Bazar.	
PROJECT : Telecommunication Tower.		DEPTH OF BORING : 2.0m	R. L.: On Road Level.
CLIENT : Warid Telecom International Ltd.		DATE OF BORING: 27-12-2010.	G. W. T : 0.91m below from E.G.L.

THICKNESS	SOIL STRATA	BORELOG	UNDISTURBED SAMPLE	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Grain Size Distribution, % Clay %, Silt %, Sand %	Max^{m} Penetration
2.0m	Weak Red 10R (5/3), dense, fine to coarse Sand(beach Sand with Gravel size Sandstone of very recent deposit), SM.			D-1	21		
	Boring was not possible due to hard, compacted and concentrated sand stone.						

LEGEND FOR BORELOG AND GRAIN SIZE DISTRIBUTION (BASED ON 'ASTM CLASSIFICATION D-2487')

- PLASTIC CLAY
- SAND
- SHALE
- UNDISTURBED SAMPLE
- MICACEOUS FINE SAND/SILT
- SILT
- PEAT/HIGHLY ORGANIC SOIL
- DISTURBED SAMPLE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS

AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED