A2 PROSOIL	BOREHOLE NO: BH-1	
	LOCATION : Borogopalpur, Gagira, Shariatpur.	
PROJECT : Telecommunication Tower.	DEPTH OF BORING : 21.0m	R. L.: 1.21m below from Road Level.
CLIENT : Grameenphone Ltd.	DATE OF BORING : 16-06-2007.	G. W. T : 1.82m below from E. G. L.

THICKNESS	SOIL STRATA	BORELOG	UNDISTURBED SAMPLE	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Grain Size Distribution, % Clay %, Silt %, Sand %	Max^{m} Penetration
3.0m	Light gray 10YR (7/2), medium dense, cohesionless silt, SM.			D-1 to D-3	8, 7, 7		
3.0m	Light gray 10YR (7/1), medium dense, cohesionless silt, SM.			D-4 to D-6	8, 9, 8		
7.5m	Gray 10YR (6/1), medium dense to dense, fine sand, SM.			D-7 to D-10	8, 9, 14, 18		
7.95m	Light gray 10YR (7/1), dense to very dense, fine sand, SM.			D-11 to D-16	22, 26, 30, 36, 40, 45		

LEGEND FOR BORELOG AND GRAIN SIZE DISTRIBUTION

PLASTIC SILTY CLAY

LOW PLASTIC CLAYEY SILT

NON PLASTIC SILT

SAND

ORGANIC

UNDISTURBED SAMPLE

DISTURBED SAMPLE

SHALE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS

AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED