A2 PROSOIL	BOREHOLE NO: BH-1	
	LOCATION : Pagla Pir, Rangpur.	
PROJECT : Telecommunication Tower.	DEPTH OF BORING : 20.0m	R. L.: 0.0m from Road Level.
CLIENT : Grameen Phone Ltd.	DATE OF BORING : 17-01-2005	G. W. T : 3.05m below from E. G. L.

THICKNESS	SOIL STRATA	BORELOG	UNDISTURBED SAMPLE	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Grain Size Distribution, % Clay %, Silt %, Sand %	Max^{m} Penetration
2.0m	Pale yellow colour 5Y (7/4), non plas loose, sandy Silt, SM.			D-1	5		
2.0m	Light brownish gray colour 10YR (6/2 medium dense, fine sand, SM.			D-2, D-3	9, 9		
1.0m	Gray colour 10YR (5/1), loose, fine sand, trace mica, SM.			D-4	5		
5.5m	Light gray colour 10YR (7/1), mediun dense to dense, fine sand, SM.			D-5, D-6, D-7, D-8, D-9	12, 16, 21, 19, 19		
6.0m	Light gray colour 10YR (7/2), dense, fine sand, SM.			D-10, D-11, D-12	19, 26, 24		
3.45m	Gray colour 10YR (5/1), dense to very dense, fine sand, SM.			D-13, D-14, D-15	22, 32, 39		



ID FOR BOREHOLE A RAIN SIZE DISTRIBU

PLASTIC SILTY CLAY

LOW PLASTIC CLAYEY SILT

NON PLASTIC SILT

SAND

UNDISTURBED SAMPLE

ORGANIC

DISTURBED SAMPLE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS

AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED