A2	PROSOIL	BOREHOLE NO: BH-1	
		LOCATION: Vill: Goali, P. O: Shikharpur, P. S: Naogaon, Dist: Naogaon.	
PROJECT : Telecommunication Tower.		DEPTH OF BORING: 21.0m	R. L.: On Road Level.
CLIENT : Grameenphone Ltd.		DATE OF BORING: 01-03-2015.	B. W. T : 2.44m below from E. G. L.

THICKNESS	SOIL STRATA	BORELOG	UNDISTURBED SAMPLE	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Grain Size Distribution, % Clay %, Silt %, Sand %	Max^{m} Penetration
3.0m	Gray 7.5YR (5/2), Medium plasticity, soft to stiff, Clay, CL.		UD-1, UD-2	D-1, D-2, D-3	3, 4, 12		
3.0m	Brown 7.5YR (5/3), medium dense to loose , silty Sand, SM.			D-4, D-5, D-6	14, 13, 5		
4.5m	Gray 7.5YR (5/2), Medium plasticity, soft to very stiff, Clay, CL.			D-7, D-8, D-9	8, 10, 22		
10.95m	Brown 7.5YR (5/3), dense to very dense, silty Sand, SM.			D-10, D-11, D-12, D-13, D-14, D-15, D-16	30, 33, 36, 38, 41, 45, 48		



LEGEND FOR BORELOG AND GRAIN SIZE DISTRIBUTION (BASED ON 'ASTM CLASSIFICATION D-2487')

PLASTIC CLAY | SHALE | SILT | SAND

PEAT/HIGHLY ORGANIC SOIL | MICACEOUS FINE SAND/SILT | UNDISTURBED SAMPLE | DISTURBED SAMPLE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS

AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED