A2 PROSOIL	BOREHOLE NO: BH-1	
	LOCATION : Choirkuri, Nasirnagar, B. Baria.	
PROJECT : Telecommunication Tower.	DEPTH OF BORING : 21.0m	R. L.: 3.65m below from Road Level.
CLIENT : Grameenphone Ltd.	DATE OF BORING : 03-05-2007.	G. W. T : 4.57m below from E. G. L.

THICKNESS	SOIL STRATA	BORELOG	UNDISTURBED SAMPLE	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Grain Size Distribution, % Clay %, Silt %, Sand %	Max^{m} Penetration
2.0m	Very pale brown 10YR (7/3), medium dense to loose, cohesionless Silt, SM.			D-1 D-2	7 4		
3.0m	Gray 10YR (6/1), medium dense to loose, cohesionless Silt, SM.			D-3 D-4	5 7		
1.0m	Gray 10YR (6/1), medium plstic, very stiff, silty Clay, CL.			D-5	16		
4.5m	Gray 10YR (6/1), medium dense to dense, cohesionless Silt, SM.			D-6 D-7 D-8 D-9 D-10	19 24 28 31 33		
10.95m	Gray 10YR (7/2), dense to very dense, fine sand, SM.			D-11 D-12 D-13 D-14 D-15 D-16	37 42 47 50 50 50		Over Over

LEGEND FOR BORELOG AND GRAIN SIZE DISTRIBUTION

PLASTIC SILTY CLAY

LOW PLASTIC CLAYEY SILT

NON PLASTIC SILT

SAND

ORGANIC

UNDISTURBED SAMPLE

DISTURBED SAMPLE

SHALE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS

AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED