A2 PROSOIL	BOREHOLE NO: BH-1	
	LOCATION : Hasanpur, Kesobpur, Jessore.	
PROJECT : Telecommunication Tower.	DEPTH OF BORING : 21.0m	R. L.: 0.91m below from Road Level.
CLIENT : Grameenphone Ltd.	DATE OF BORING : 20-07-2007.	G. W. T : 0.60m above from E. G. L.

THICKNESS	SOIL STRATA	BORELOG	UNDISTURBED SAMPLE	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Grain Size Distribution, % Clay %, Silt %, Sand %	Max^{m} Penetration
2.0m	Gray 10YR (7/1), medium plastic, medium stiff to soft, silty Clay, CL.		UD-1	D-1	7		
2.0m	Black 5YR (2.5/1), loose to dense, cohesionless Silt, SM.			D-2	4		
				D-3	3		
				D-4	17		
				D-5	19		
				D-6	25		
				D-7	28		
				D-8	30		
				D-9	33		
				D-10	36		
17.45m	Light gray 10YR (7/1), dense to very dense, fine sand, SM.			D-11	40		
				D-12	38		
				D-13	41		
				D-14	44		
				D-15	42		
				D-16	43		



LEGEND FOR BORELOG AND GRAIN SIZE DISTRIBUTION

PLASTIC SILTY CLAY

LOW PLASTIC CLAYEY SILT

NON PLASTIC SILT

SAND

ORGANIC

UNDISTURBED SAMPLE

DISTURBED SAMPLE

SHALE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS

AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED