A2	PROSOIL	BOREHOLE NO: BH-1	
		LOCATION: Raypur Bazar, Kalaroa, Satkhira.	
PROJECT : Telecommunication Tower.		DEPTH OF BORING: 21.0m	R. L.: 0.60m below from Road Level.
CLIENT : Grameenphone Ltd.		DATE OF BORING: 10-09-2012.	G. W. T : 0.60m above from E. G. L.

THICKNESS	SOIL STRATA	BORELOG	UNDISTURBED SAMPLE	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Grain Size Distribution, % Clay %, Silt %, Sand %	Max^{m} Penetration
2.0m	Gray 10YR (4/5), high plasticity, very soft, Clay, CH.		UD-1, UD-2	D-1, D-2	1, 1		
1.0m	Light Brown 10YR (4/5), high plasticity, very soft, Clay, CH.		UD-3	D-3	1		
4.5m	Gray 10YR (4/5), high plasticity, very soft, Clay, CH.		UD-4	D-4, D-5, D-6, D-7	2, 2, 2, 2		
1.5m	Grayish Brown 10YR (4/5), high plasticity, very soft to stiff, Clay, CH.			D-8	14		
12.45m	Gray 10YR (4/5), medium dense to very dense, fine Sand, SM.			D-9, D-10, D-11, D-12, D-13, D-14, D-15, D-16	16, 20, 24, 28, 31, 36, 32, 34		



LEGEND FOR BORELOG AND GRAIN SIZE DISTRIBUTION (BASED ON 'ASTM CLASSIFICATION D-2487')

PLASTIC CLAY | SHALE | SILT | SAND

PEAT/HIGHLY ORGANIC SOIL | MICACEOUS FINE SAND/SILT | UNDISTURBED SAMPLE | DISTURBED SAMPLE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS

AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED