| A2 PROSOIL | BOREHOLE NO: BH-1 | |
|---|---|---|
| | LOCATION : Belka Bazar, Gaibandha. | |
| PROJECT : Telecommunication Tower. | DEPTH OF BORING : 21.0m | R. L.: 0.91m below from Road Level. |
| CLIENT : Grameen phone Ltd. | DATE OF BORING : 04-05-2005 | G. W. T : 2.74m below from E. G. L. |

| THICKNESS | SOIL STRATA | BORELOG | UNDISTURBED SAMPLE | DISTURBED SAMPLE | DEPTH (m) SPT VALUES ( BLOWS / 300mm ) | Grain Size Distribution, % Clay %, Silt %, Sand % | Max$^{m}$ Penetration |
|---|---|---|---|---|---|---|---|
| 2.0m | Gray 7.5YR (6/1), low plastic, clayey Silt, ML. | | | D-1 | 3 | | |
| | | | | D-2 | 5 | | |
| 3.0m | Pale red 10R (6/1), loose to medium dense, fine sand, SM. | | | D-3 | 7 | | |
| | | | | D-4 | 12 | | |
| 2.5m | Gray colour 10R (6/1), medium dense, silty Sand, SM. | | | D-5 | 5 | | |
| | | | | D-6 | 10 | | |
| 3.0m | Bluish gray Gley2 (7/1), medium dense, fine sand, SM. | | | D-7 | 10 | | |
| | | | | D-8 | 12 | | |
| 10.95m | Greenish gray Gley2 (6/1), medium dense, fine sand, SM. | | | D-9 | 30 | | |
| | | | | D-10 | 36 | | |
| | | | | D-11 | 41 | | |
| | | | | D-12 | 47 | | |
| | | | | D-13 | 50 | | Over |
| | | | | D-14 | 50 | | Over |
| | | | | D-15 | 50 | | Over |
| | | | | D-16 | 50 | | Over |

0 10 20 30 40 50 60 70 80 0 20 40 60 80 100

ID FOR BORELOG A RAIN SIZE DISTRIBU

PLASTIC SILTY CLAY

LOW PLASTIC CLAYEY SILT

NON PLASTIC SILT

SAND

UNDISTURBED SAMPLE

ORGANIC

DISTURBED SAMPLE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX$^{m}$ PENETRATION= 50 BLOWS

AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED