A2 PROSOIL	BOREHOLE NO: BH-1	
	LOCATION : Gunoboti, Comilla.	
PROJECT : Telecommunication Tower.	DEPTH OF BORING : 21.0m	R. L.: 1.52m below from Road Level.
CLIENT : Grameen Phone Ltd.	DATE OF BORING : 23-07-2005	G. W. T : 0.46m above from E.G.L.

THICKNESS	SOIL STRATA	BORELOG	UNDISTURBED SAMPLE	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Grain Size Distribution, % Clay %, Silt %, Sand %	Remarks
3.0m	Very pale brown 10YR (7/3), low plastic, soft to medium stiff, clayey Silt, ML.			D-1 to D-3	5, 8, 7		
1.0m	Gray 10YR (6/2), medium dense, cohesionless silt, SM.			D-3 to D-4	10		
1.0m	Light brownish gray 10YR (6/2), medium dense, fine sand, SM.			D-4 to D-5	22		
2.5m	Gray 10YR (5/1), medium dense to dense, fine sand, SM.			D-5 to D-7	13, 22		
3.0m	Light brown gray 10YR (6/2), medium dense to dense, fine sand, SM.			D-7 to D-9	14, 50		
10.95m	Light gray 10YR (7/2), very dense, fine sand, SM.			D-9 to D-16	50, 50, 50, 50, 50, 50, 50		Over



ID FOR BOREHOLE A RAIN SIZE DISTRIBU

PLASTIC SILTY CLAY

LOW PLASTIC CLAYEY SILT

NON PLASTIC SILT

SAND

UNDISTURBED SAMPLE

ORGANIC

DISTURBED SAMPLE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS

AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED