A2	PROSOIL	BOREHOLE NO: BH-1	
		LOCATION : Kakara, Chakoria, Cox's bazar.	
PROJECT : Telecommunication Tower.		DEPTH OF BORING : 21.0m	R. L.: On Road Level.
CLIENT : Warid Telecom International Ltd.		DATE OF BORING: 11-09-2011.	G. W. T : 3.05m below from E.G.L.

THICKNESS	SOIL STRATA	BORELOG	UNDISTURBED SAMPLE	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Grain Size Distribution, % Clay %, Silt %, Sand %	Max^{m} Penetration
3.0m	Dark reddish Gray 10YR (4/1), low plasticity, very soft to soft, silty Clay, CL.		UD-1, UD-2	D-1, D-2	1, 5		
3.0m	Brown 10YR (5/3), medium plasticity, soft, silty Clay, CL.		UD-3	D-3	5		
1.5m	Light Gray 10YR (7/1), medium plasticity, soft, silty Clay, CL.		UD-4	D-4	3		
12.0m	Gray 10YR (6/1), medium plasticity, soft to medium stiff, silty Clay, CL.			D-5, D-6, D-7, D-8, D-9, D-10, D-11, D-12	4, 3, 3, 3, 4, 5, 4, 4		
1.95m	Gray 10YR (6/1), medium dense to very dense, silty Sand, SM.			D-13, D-14	8, 36		



LEGEND FOR BORELOG AND GRAIN SIZE DISTRIBUTION (BASED ON 'ASTM CLASSIFICATION D-2487')

PLASTIC CLAY	SAND	SHALE	UNDISTURBED SAMPLE
MICACEOUS FINE SAND/SILT	SILT	PEAT/HIGHLY ORGANIC SOIL	DISTURBED SAMPLE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS

AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED