A2 PROSOIL	BOREHOLE NO: BH-1	
	LOCATION : Daulipara,Mirzapur, Tangail.	
PROJECT : Telecommunication Tower.	DEPTH OF BORING : 21.0m	R. L.: 0.91m below from Road Level.
CLIENT : Grameenphone Ltd.	DATE OF BORING : 01-08-2007.	G. W. T : 0.30m above from E. G. L.

THICKNESS	SOIL STRATA	BORELOG	UNDISTURBED SAMPLE	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Grain Size Distribution, % Clay %, Silt %, Sand %	Max^{m} Penetration
4.0m	Very pale brown 10YR (7/3), medium dense, silty Sand, SM.			D-1 to D-4	8, 10, 11, 14		
2.0m	Light gray 10YR (7/2), medium dense to very dense, fine sand, SM.			D-5 to D-6	17, 31		
15.45m	Light gray 10YR (7/1), very dense, fine sand, SM.			D-7 to D-16	33, 37, 40, 42, 46, 47, 48, 50, 50, 50		Over, Over, Over



LEGEND FOR BORELOG AND GRAIN SIZE DISTRIBUTION

PLASTIC SILTY CLAY

LOW PLASTIC CLAYEY SILT

NON PLASTIC SILT

SAND

ORGANIC

UNDISTURBED SAMPLE

DISTURBED SAMPLE

SHALE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS

AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED