A2 PROSOIL	BOREHOLE NO: BH-1	
	LOCATION: Kotalipara (Kuthibari Bazar), Mohanpur, Rajshahi.	
PROJECT : Telecommunication Tower.	DEPTH OF BORING: 21.0m	R. L.: 0.46m above from Road Level.
CLIENT : Grameenphone Ltd.	DATE OF BORING: 15-10-2011.	G. W. T : 0.92m below from E. G. L.

THICKNESS	SOIL STRATA	BORELOG	UNDISTURBED SAMPLE	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Grain Size Distribution, % Clay %, Silt %, Sand %	Max^{m} Penetration
4.0m	Light bluish Gray Gley2 (7/1), very loose to medium dense, clayey Silt, ML.			D-1 to D-3	1, 2, 9		
3.5m	Gray 10YR (6/1), loose to medium dense, clayey Silt, ML.			D-4 to D-6	5, 4, 10		
6.0m	Gray 10YR (6/1), medium plasticity, soft to very stiff, silty Clay, CL.			D-7 to D-11	5, 5, 12, 12, 22		
3.0m	Brown 7.5YR (5/3), dense, clayey Silt, ML.			D-12 to D-14	23, 21, 20		
4.95m	Brown 7.5YR (5/3), dense, fine Sand, SM.			D-15 to D-16	22, 27		

LEGEND FOR BORELOG AND GRAIN SIZE DISTRIBUTION (BASED ON 'ASTM CLASSIFICATION D-2487')

PLASTIC CLAY | SHALE | SILT | SAND

PEAT/HIGHLY ORGANIC SOIL | MICACEOUS FINE SAND/SILT | UNDISTURBED SAMPLE | DISTURBED SAMPLE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS

AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED