A2	PROSOIL	BOREHOLE NO: BH-1	
		LOCATION: Baliadangi, Gabtoli, Bogra.	
PROJECT : Telecommunication Tower.		DEPTH OF BORING: 21.0m	R. L.: 0.31m below from Road Level.
CLIENT : Grameenphone Ltd.		DATE OF BORING: 04-05-2012.	G. W. T : 3.66m below from E. G. L.

THICKNESS	SOIL STRATA	BORELOG	UNDISTURBED SAMPLE	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Grain Size Distribution, % Clay %, Silt %, Sand %	Max^{m} Penetration
2.0m	Grayish Brown 10YR (5/2), loose to medium dense, Silt, ML.			D-1	7		
1.0m	Grayish Brown 10YR (5/2), medium plasticity, soft to stiff, silty Clay, CL.		UD-2	D-2, D-3	5, 10		
2.0m	Brown 7.5YR (5/3), loose to medium dense, silty Sand, SM.			D-4, D-5	5, 11		
7.0m	Brown 7.5YR (5/3), medium dense to dense, Silt, ML.			D-6, D-7, D-8, D-9	12, 12, 15, 15		
9.45m	Gray 10YR (5/1), dense, fine Sand, SM.			D-10, D-11, D-12, D-13, D-14, D-15, D-16	23, 19, 20, 21, 19, 22, 25		

LEGEND FOR BORELOG AND GRAIN SIZE DISTRIBUTION (BASED ON 'ASTM CLASSIFICATION D-2487')

PLASTIC CLAY | SHALE | SILT | SAND

PEAT/HIGHLY ORGANIC SOIL | MICACEOUS FINE SAND/SILT | UNDISTURBED SAMPLE | DISTURBED SAMPLE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS

AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED