A2	PROSOIL	BOREHOLE NO: BH-1	
		LOCATION : Golden Shower, Road # 28, Plot # 24, Block # K, Banani, Dhaka.	
PROJECT : Proposed Nine Storied Building.		DEPTH OF BORING : 21.0m	R. L.: 0.15m below from Road Level.
CLIENT : Concord Real Estate & Development Ltd.		DATE OF BORING : 07-12-2009.	G. W. T : 1.22m below from E. G. L.

THICKNESS	SOIL STRATA	BORELOG	UNDISTURBED SAMPLE	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Grain Size Distribution, % Clay %, Silt %, Sand %	Max^{m} Penetration
4.0m	Light gray 10YR (7/1), medium plastic, very soft to soft, silty Clay, CL.		UD-1, UD-2, UD-3, UD-4	D-1, D-2, D-3, D-4	1, 1, 1, 3		
2.0m	Gray 10YR (6/1), medium plastic, soft, silty Clay, CL.			D-5, D-6	3, 3		
1.5m	Dark gray 10YR (4/1), organic soil.			D-7	1		
1.5m	Gray 10YR (6/1), medium plastic, very soft to medium stiff, silty Clay, CL.			D-8	7		
1.5m	Gray 10YR (6/1), medium dense, silty Sand, SM.			D-9	9		
1.5m	Very pale brown 10YR (7/3), medium dense to dense, cohesionless silt, SM.			D-10	30		
3.0m	Very pale brown 10YR (7/3), dense to very dense, fine sand, SM.			D-11, D-12	37, 34		
3.0m	Very pale brown 10YR (7/4), very dense, fine sand, SM.			D-13, D-14	37, 41		
3.45m	Very pale brown 10YR (7/3), very dense, fine sand, SM.			D-15, D-16	50, 50		Over, Over

0 10 20 30 40 50 60 70 80 0 20 40 60 80 100

LEGEND FOR BORELOG AND GRAIN SIZE DISTRIBUTION

PLASTIC SILTY CLAY

LOW PLASTIC CLAYEY SILT

NON PLASTIC SILT

SAND

ORGANIC

UNDISTURBED SAMPLE

DISTURBED SAMPLE

SHALE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS

AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED