A2	PROSOIL	BOREHOLE NO: BH-1	
		LOCATION: Paschim Chambol, Bangla Bazar, Bashkhali, chittagonj	
PROJECT : Telecommunication Tower.		DEPTH OF BORING: 21.0m	R. L.: 0.91m below from Road Level.
CLIENT : AXIATA (Bangladesh) Ltd.		DATE OF BORING: 29-08-2010.	G. W. T : 0.0m below from E. G. L.

THICKNESS	SOIL STRATA	BORELOG	UNDISTURBED SAMPLE	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Grain Size Distribution, % Clay %, Silt %, Sand %	Max^{m} Penetration
4.0m	Black 2.5YR (2.5/1), very soft, Organic Soil, PT.			D-1 to D-4	1, 1, 1, 1		
9.5m	Dark reddish Gray 2.5YR (3/1), medium plasticity, very soft to soft, Clay, CL.			D-5 to D-10	2, 2, 2, 2, 2, 3		
3.0m	Dark reddish Gray 2.5YR (3/1), medium plasticity, soft to medium stiff, silty Clay, CL.			D-11 to D-13	5, 5, 9		
4.95m	Reddish black 10YR (2.5/1), medium plasticity, stiff, silty Clay, CL.			D-14 to D-17	9, 11, 11, 14		



LEGEND FOR BORELOG AND GRAIN SIZE DISTRIBUTION (BASED ON 'ASTM CLASSIFICATION D-2487')

PLASTIC CLAY	SAND	SILT	SHALE
PEAT/HIGHLY ORGANIC SOIL	MICACEOUS FINE SAND/SILT	UNDISTURBED SAMPLE	DISTURBED SAMPLE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS

AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED