A2	PROSOIL	BOREHOLE NO: BH-1	
		LOCATION: Vill: Gaymara (Pashkarhat), P. O: South Kishorgonj, P. S: Lalmohon, Dist: Bhola.	
PROJECT : Telecommunication Tower.		DEPTH OF BORING: 21.0m	R. L.: 0.61m below from Road Level.
CLIENT : Grameenphone Ltd.		DATE OF BORING: 19-03-2015.	B. W. T :1.52m below from E. G. L.

THICKNESS	SOIL STRATA	BORELOG	UNDISTURBED SAMPLE	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Grain Size Distribution, % Clay %, Silt %, Sand %	Max^{m} Penetration
2.0m	Gray 7.5YR (5/1), very loose, Silt, ML.			D-1	2		
2.0m	Gray 7.5YR (5/1), medium plasticity, very soft to soft, clay, CL.		UD-1	D-2, D-3	2, 1		
5.0m	Gray 7.5YR (5/1), very loose to loose, Silt, ML.			D-4, D-5, D-6, D-7, D-8	3, 2, 4, 5, 5		
12.45m	Gray 7.5YR (5/1), loose to very dense, silty Sand, SM.			D-9, D-10, D-11, D-12, D-13, D-14, D-15, D-16	13, 10, 13, 18, 14, 20, 25, 35		

LEGEND FOR BORELOG AND GRAIN SIZE DISTRIBUTION (BASED ON 'ASTM CLASSIFICATION D-2487')

PLASTIC CLAY | SHALE | SILT | SAND

PEAT/HIGHLY ORGANIC SOIL | MICACEOUS FINE SAND/SILT | UNDISTURBED SAMPLE | DISTURBED SAMPLE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS

AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED