
A2	PROSOIL	BOREHOLE NO: BH-01	
		LOCATION : Begumgonj, Noakhali, level-5.	
PROJECT : PROPOSED BUILDING.		DEPTH OF BORING : 22.5m	**R. L. : Road Level.**
CLIENT : MD. Fakhrul Islam.		DATE OF BORING : 23-10-2016	B. W. T : 1.52m below from E. G. L.



LEGEND FOR BORELOG AND GRAIN SIZE DISTRIBUTION (BASED ON 'ASTM CLASSIFICATION D-2487')

PLASTIC CLAY | SILT | PEAT/HIGHLY ORGANIC SOIL | UNDISTURBED SAMPLE

MICACEOUS FINE SAND/SILT | SAND | SHALE | DISTURBED SAMPLE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^m PENETRATION= 50 BLOWS. AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED

A2 PROSOIL	BOREHOLE NO: BH-02	
	LOCATION : Begumgonj, Noakhali, level-5.	
PROJECT : PROPOSED BUILDING.	DEPTH OF BORING : 22.5m	**R. L. : Road Level.**
CLIENT : MD. Fakhrul Islam.	DATE OF BORING : 23-10-2016	B. W. T : 1.52 below from E. G. L.

RL/ THICKNESS	SOIL STRATA	BORELOG	SAMPLING FROM (m)	SAMPLING TO (m)	SPT-N Value Blow/300mm N1=150 (mm)	N2=300 (mm)	N3=450 (mm)	N=N2 +N3	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Max^{m} Penetration
3.0m	Grayish Brown 10YR (5/2), soft, low plasticity Clay with Sand, CL.		1.5	1.95	2	2	2	4	D-1	4	
			3	3.45	1	1	2	3	D-2	3	
3.0m	Gray 7.5YR (5/1), soft to medium stiff, low plasticity Clay with Sand, CL.		4.5	4.95	2	2	3	5	D-3	5	
			6	6.45	3	3	7	10	D-4	10	
1.5m	Gray, 7.5YR (5/1), loose, silty Sand, SM.		7.5	7.95	4	7	10	17	D-5	17	
9.0m	Gray, 7.5YR (5/1), medium dense, silty Micaceous Sand, SM.		9	9.45	6	9	12	21	D-6	21	
			10.5	10.95	6	9	15	24	D-7	24	
			12	12.45	6	12	17	29	D-8	29	
			13.5	13.95	7	13	16	29	D-9	29	
			15	15.45	8	13	10	23	D-10	23	
			16.5	16.95	4	6	13	19	D-11	19	
6.45m	Gray, 7.5YR (5/1), medium dense to dense, Silty Sand, SM.		18	18.45	7	13	17	30	D-12	30	
			19.5	19.95	8	16	20	36	D-13	36	
			21	21.45	8	19	22	41	D-14	41	
			22.5	22.95	8	21	25	46	D-15	46	

RL WITH REPECT TO TOPOGRAPHY SURVEY.

0 10 20 30 40 50 60 70 80

LEGEND FOR BORELOG AND GRAIN SIZE DISTRIBUTION (BASED ON 'ASTM CLASSIFICATION D-2487')

PLASTIC CLAY | SILT | PEAT/HIGHLY ORGANIC SOIL | UNDISTURBED SAMPLE

MICACEOUS FINE SAND/SILT | SAND | SHALE | DISTURBED SAMPLE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS. AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED

A2 PROSOIL	BOREHOLE NO: BH-03	
	LOCATION : Begumgonj, Noakhali, level-5.	
PROJECT : PROPOSED BUILDING.	DEPTH OF BORING : 22.5m	**R. L. : Road Level.**
CLIENT : MD. Fakhrul Islam.	DATE OF BORING : 23-10-2016	B. W. T : 1.52m below from E. G. L.

RL/ THICKNESS	SOIL STRATA	BORELOG	SAMPLING FROM (m)	SAMPLING TO (m)	SPT-N Value Blow/300mm N1=150 (mm)	N2=300 (mm)	N3=450 (mm)	N=N2 +N3	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Max^{m} Penetration
6.0m	Gray 7.5YR (5/1), soft to medium stiff, low plasticity Clay with Sand, CL.		1.5	1.95	1	1	1	2	D-1	2	
			3	3.45	1	2	3	5	D-2	5	
			4.5	4.95	2	2	4	6	D-3	6	
1.5m	Gray, 7.5YR (5/1), medium dense, silty Sand, SM.		6	6.45	3	5	8	13	D-4	13	
			7.5	7.95	5	7	11	18	D-5	18	
9.0m	Gray, 7.5YR (5/1), medium dense to dense, silty Micaceous Sand, SM.		9	9.45	6	8	15	23	D-6	23	
			10.5	10.95	6	11	17	28	D-7	28	
			12	12.45	7	14	19	33	D-8	33	
			13.5	13.95	8	16	20	36	D-9	36	
			15	15.45	8	15	12	27	D-10	27	
1.5m	Gray, 7.5YR (5/1), medium dense, silty Sand, SM.		16.5	16.95	5	7	15	22	D-11	22	
			18	18.45	6	12	13	25	D-12	25	
4.95m	Gray, 7.5YR (5/1), medium dense to dense, silty Micaceous Sand, SM.		19.5	19.95	7	14	20	34	D-13	34	
			21	21.45	8	13	26	39	D-14	39	
			22.5	22.95	8	17	26	43	D-15	43	

RL WITH REPECT TO TOPOGRAPHY SURVEY.

LEGEND FOR BOREHOLE AND GRAIN SIZE DISTRIBUTION (BASED ON 'ASTM CLASSIFICATION D-2487')

PLASTIC CLAY | SILT | PEAT/HIGHLY ORGANIC SOIL | UNDISTURBED SAMPLE

MICACEOUS FINE SAND/SILT | SAND | SHALE | DISTURBED SAMPLE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS. AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED

A2	PROSOIL	BOREHOLE NO: BH-04	
		LOCATION : Begumgonj, Noakhali, level-5.	
PROJECT : PROPOSED BUILDING.		DEPTH OF BORING : 22.5m	R. L. : Road Level.
CLIENT : MD. Fakhrul Islam.		DATE OF BORING : 23-10-2016	B. W. T : 1.52m below from E. G. L.

RL/ THICKNESS	SOIL STRATA	BORELOG	SAMPLING FROM (m)	SAMPLING TO (m)	SPT-N Value Blow/300mm N1=150 (mm)	N2=300 (mm)	N3=450 (mm)	N=N2+N3	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Max^{m} Penetration
4.5m	Brown 7.5YR (5/3), soft to medium stiff, low plasticity Clay with Sand, CL.		1.5	1.95	1	1	2	3	D-1	3	
			3	3.45	2	2	3	5	D-2	5	
			4.5	4.95	2	3	4	7	D-3	7	
3.0m	Gray, 7.5YR (5/1), loose to medium dense, silty Sand, SM.		6	6.45	3	4	7	11	D-4	11	
			7.5	7.95	4	6	10	16	D-5	16	
			9	9.45	6	8	12	20	D-6	20	
			10.5	10.95	6	9	14	23	D-7	23	
			12	12.45	6	12	17	29	D-8	29	
			13.5	13.95	6	13	18	31	D-9	31	
15.45m	Gray, 7.5YR (5/1), medium dense to dense, silty Micaceous Sand, SM.		15	15.45	7	14	12	26	D-10	26	
			16.5	16.95	7	18	24	42	D-11	42	
			18	18.45	8	15	18	33	D-12	33	
			19.5	19.95	8	17	21	38	D-13	38	
			21	21.45	9	19	24	43	D-14	43	
			22.5	22.95	8	18	23	41	D-15	41	

RL WITH REPECT TO TOPOGRAPHY SURVEY.

LEGEND FOR BORELOG AND GRAIN SIZE DISTRIBUTION (BASED ON 'ASTM CLASSIFICATION D-2487')

PLASTIC CLAY | SILT | PEAT/HIGHLY ORGANIC SOIL | UNDISTURBED SAMPLE

MICACEOUS FINE SAND/SILT | SAND | SHALE | DISTURBED SAMPLE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS. AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED

A2 PROSOIL	BOREHOLE NO: BH-05	
	LOCATION : Begumgonj, Noakhali, level-5.	
PROJECT : PROPOSED BUILDING.	DEPTH OF BORING : 22.5m	**R. L. : Road Level.**
CLIENT : MD. Fakhrul Islam.	DATE OF BORING : 25-10-2016	B. W. T : 1.52m below from E. G. L.

RL/ THICKNESS	SOIL STRATA	BORELOG	SAMPLING FROM (m)	SAMPLING TO (m)	SPT-N Value Blow/300mm N1=150 (mm)	N2=300 (mm)	N3=450 (mm)	N=N2 +N3	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Max^{m} Penetration
4.5m	Brown 7.5YR (5/3), soft, low plasticity Clay with Sand, CL.		1.5	1.95	1	1	2	3	D-1	3	
			3	3.45	2	2	2	4	D-2	4	
			4.5	4.95	2	3	3	6	D-3	6	
13.5m	Gray 7.5YR (5/1), loose to dense, silty Micaceous Sand, SM.		6	6.45	3	4	6	10	D-4	10	
			7.5	7.95	4	8	11	19	D-5	19	
			9	9.45	5	8	16	24	D-6	24	
			10.5	10.95	7	11	14	25	D-7	25	
			12	12.45	7	13	14	27	D-8	27	
			13.5	13.95	6	9	11	20	D-9	20	
			15	15.45	3	18	14	32	D-10	32	
			16.5	16.95	9	15	15	30	D-11	30	
			18	18.45	7	13	19	32	D-12	32	
4.95m	Gray 7.5YR (5/1), dense, silty Sand, SM.		19.5	19.95	8	14	19	33	D-13	33	
			21	21.45	8	17	23	40	D-14	40	
			22.5	22.95	8	18	24	42	D-15	40	

RL WITH REPECT TO TOPOGRAPHY SURVEY.

LEGEND FOR BORELOG AND GRAIN SIZE DISTRIBUTION (BASED ON 'ASTM CLASSIFICATION D-2487')

PLASTIC CLAY | SILT | PEAT/HIGHLY ORGANIC SOIL | UNDISTURBED SAMPLE

MICACEOUS FINE SAND/SILT | SAND | SHALE | DISTURBED SAMPLE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS. AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED