A2	PROSOIL	BOREHOLE NO: BH-1	
		LOCATION: Heakow Bazar-2, Fatik chari, CTG.	
PROJECT : Telecommunication Tower.		DEPTH OF BORING: 21.0m	R. L.: On Road Level.
CLIENT : AXIATA (Bangladesh) Ltd.		DATE OF BORING: 21-02-2012.	G. W. T : 0.60m below from E. G. L.

THICKNESS	SOIL STRATA	BORELOG	UNDISTURBED SAMPLE	DISTURBED SAMPLE	DEPTH (m) SPT VALUES (BLOWS / 300mm)	Grain Size Distribution, % Clay %, Silt %, Sand %	Max^{m} Penetration
3.0m	Reddish Yellow 5YR (6/8), dense, Silt, ML.			D-1 to D-3	16, 27, 13		
1.5m	Light Brown 7.5YR (6/8), high plasticity stiff to very stiff, silty Clay, CL.		UD-3, UD-4	D-3, D-4	13, 22		
4.0m	Light Brown 7.5YR (6/8), dense, Silt, ML.			D-5 to D-9	23, 25, 27, 23		
1.5m	Yellow 10YR (7/8), dense, Silt, ML.			D-9, D-10	41		
10.95m	Yellow 10YR (7/8), very dense, fine Sand, SM.			D-10 to D-17	45, 48, 49, 50, 50, 50, 50		Over, Over, Over, Over

LEGEND FOR BORELOG AND GRAIN SIZE DISTRIBUTION (BASED ON 'ASTM CLASSIFICATION D-2487')

PLASTIC CLAY	SAND	SILT	SHALE
PEAT/HIGHLY ORGANIC SOIL	MICACEOUS FINE SAND/SILT	UNDISTURBED SAMPLE	DISTURBED SAMPLE

N- BLOWS DELIVERED PER FOOT BY A 140 LB HAMMER FALLING 30 INCHES

MAX^{m} PENETRATION= 50 BLOWS

AFTER 50 BLOWS PENETRATION DEPTH WERE MEASURED