

ELECTRICAL MOTOR CONTROL CENTER SPECIFICATION

Project: Industrial Plant MCC-01 | Standard: IEC 60364

1 Scope

This specification defines the electrical distribution and motor feeder ratings.

2 System Requirements

The three-phase induction motor operates at a rated voltage = 230 V.

System line operating frequency = 50 Hz with symmetrical sinusoidal supply.

Main busbar continuous incoming current = 750 A under peak operational loading.

Check that the the circuit breaker trip unit is correctly calibrated.