

QP No. ELEC-001	Issue Date 21-09-2026	Revision No. A	Date 21-09-2026	Name S. Joshi
---------------------------	---------------------------------	--------------------------	---------------------------	-------------------------

COSO

ELECTRICAL CONTROL PANEL INSPECTION SPECIFICATION

Document Code: ELEC-001 Discipline: Electrical Classification: Training / Test

1. Scope

Controlled test document for electrical parameter extraction and tolerance analysis.

2. Electrical Parameters

Parameter	Nominal	Tolerance	Measured	Unit
Supply Voltage	415.0	±5.0	418.2	V
Phase Current	24.0	±1.0	24.7	A
Frequency	50.0	±0.5	49.8	Hz
Insulation Resistance	10.0	±1.0	9.4	MΩ
Power Factor	0.95	±0.02	0.936	PF

3. Inspection

Verify instrument calibration before measurement. Any value outside the permitted range shall be recorded for engineering review.

4. Reporting

The final report shall include nominal value, actual value, tolerance, deviation, tolerance utilization, Tolerance Index and status.

QP No. QP-ELEC-001	Issue Date 21-09-2026	Revision No. A	Date 21-09-2026	Name S. Joshi
------------------------------	---------------------------------	--------------------------	---------------------------	-------------------------

COSO

SIGNATURE & APPROVAL RECORD

Role	Name	Signature	Date
Prepared By	S. Joshi		
Checked By	Quality Engineer		
Approved By	Engineering Manager		

Document control statement: This page records preparation, checking and approval of the controlled training/test document.