

UAUC Capture Report

Audit ID: MABP-2 | Project: MABP | 8/7/2026, 4:32:10 pm

3

Safety Issues Found

4

Recommendations

Detected Safety Issues

Safety Issue	Potential Risk
Workers are seated on an unstable platform without proper seating arrangements.	Fall from height due to unstable seating or lack of fall protection.
Potential fall hazard due to lack of proper barricades or fall protection around the work area.	Trip and fall incidents caused by loose materials and cables.
Loose materials and cables are scattered on the ground, creating trip hazards.	Head or body injury from falling objects or unstable structures.

AI Recommendations

- Provide stable and secure seating arrangements for workers at height.
- Install proper barricades or fall protection systems around the work area.
- Improve housekeeping by removing loose materials and organizing cables to eliminate trip hazards.
- Ensure workers are using appropriate PPE, including helmets and safety harnesses.

Analyzed Image

