

UAUC Capture Report

Audit ID: MPSB-10 | Project: MPSB | 6/18/2026, 6:47:35 AM

2

Safety Issues Found

2

Recommendations

Detected Safety Issues

Safety Issue	Potential Risk
Worker on elevated platform without visible fall protection.	Worker could fall from the elevated platform.
Loose cable on the ground creating a trip hazard.	Worker could trip over the loose cable and sustain injuries.

AI Recommendations

- Ensure all workers on elevated platforms use proper fall protection equipment such as harnesses.
- Secure or remove loose cables from the ground to eliminate trip hazards.

Analyzed Image

