

UAUC Capture Report

Audit ID: MPSB-24 | Project: MPSB | 7/2/2026, 6:49:07 AM

3

Safety Issues Found

3

Recommendations

Detected Safety Issues

Safety Issue	Potential Risk
Water accumulation on the floor creating a slip hazard.	Slip and fall due to water accumulation.
Poor housekeeping with scattered materials and debris on the floor.	Trip and fall due to scattered materials and debris.
Open edges without proper barricades in some areas.	Fall from height due to open edges without proper barricades.

AI Recommendations

- Remove water accumulation and ensure the floor is dry.
- Improve housekeeping by clearing scattered materials and debris.
- Install proper barricades or guardrails at open edges to prevent falls.

Analyzed Image

