

UAUC Capture Report

Audit ID: MPSB-45 | Project: MPSB | 7/23/2026, 7:00:40 AM

3

Safety Issues Found

3

Recommendations

Detected Safety Issues

Safety Issue	Potential Risk
• Worker on elevated structure without visible fall protection	Fall from height
• Loose materials on the ground creating trip hazards	Trip and fall injuries
• Worker using mobile phone in a construction area	Distraction leading to accidents

AI Recommendations

- Ensure workers on elevated structures use fall protection equipment such as harnesses.
- Remove loose materials from the ground to prevent trip hazards.
- Prohibit mobile phone usage in active construction zones unless necessary for work-related communication.

Analyzed Image

