

UAUC Capture Report

Audit ID: MSBP_Sarai Ghat-1 | Project: MSBP_Sarai Ghat | 6/12/2026, 3:41:43 AM

2

Safety Issues Found

2

Recommendations

Detected Safety Issues

Safety Issue	Potential Risk
Worker on elevated platform without visible fall protection.	Worker may fall from the elevated platform.
Loose cable on the ground creating a trip hazard.	Worker may trip over the loose cable and sustain injuries.

AI Recommendations

- Ensure all workers on elevated platforms use proper fall protection equipment such as harnesses.
- Secure or remove loose cables from the ground to eliminate trip hazards.

Analyzed Image

