

UAUC Capture Report

Audit ID: MSBP_Sarai Ghat-18 | Project: MSBP_Sarai Ghat | 6/11/2026, 1:58:00 PM

2

Safety Issues Found

3

Recommendations

Detected Safety Issues

Safety Issue	Potential Risk
No visible safety barriers or nets for workers on upper floors.	Risk of falling from height for workers on upper floors.
Potentially unsafe access to upper levels without visible fall protection.	Risk of injury to pedestrians or workers below from falling objects.

AI Recommendations

- Install safety barriers or nets on all open edges of upper floors.
- Ensure workers on upper levels use proper fall protection equipment such as harnesses.
- Set up a restricted zone below the work area to prevent pedestrian access and reduce risk of injury from falling objects.

Analyzed Image

