

UAUC Capture Report

Audit ID: MSBP_Sarai Ghat-28 | Project: MSBP_Sarai Ghat | 6/15/2026, 8:09:54 AM

3

Safety Issues Found

3

Recommendations

Detected Safety Issues

Safety Issue	Potential Risk
• Worker on elevated platform without visible fall protection.	Fall from height due to lack of fall protection.
• Loose cable on the ground creating a trip hazard.	Tripping over loose cable leading to injury.
• Worker using a mobile phone in an active construction zone.	Distraction from mobile phone use causing accidents.

AI Recommendations

• Ensure all workers on elevated platforms use proper fall protection equipment such as harnesses.
• Remove or secure loose cables on the ground to eliminate trip hazards.
• Prohibit mobile phone use in active construction zones unless necessary for work-related communication.

Analyzed Image

