

UAUC Capture Report

Audit ID: MSBP_Sarai Ghat-31 | Project: MSBP_Sarai Ghat | 6/15/2026, 8:58:15 AM

3

Safety Issues Found

3

Recommendations

Detected Safety Issues

Safety Issue	Potential Risk
• Worker on elevated platform without visible fall protection	Fall from height due to lack of fall protection
• Loose cable on the ground creating a trip hazard	Tripping over loose cable leading to injury
• Worker using a phone in a construction zone	Distraction from phone use causing accidents

AI Recommendations

- Ensure all workers on elevated platforms use proper fall protection equipment such as harnesses and guardrails.
- Organize and secure loose cables to eliminate trip hazards.
- Prohibit phone use in active construction zones unless necessary for work communication.

Analyzed Image

