

Compliance Audit Report

Audit ID: MSBP_Sarai Ghat-23 | Project: MSBP_Sarai Ghat | 6/3/2026, 6:25:37 AM

3

Safety Issues Found

3

Recommendations

Detected Safety Issues

Safety Issue	Potential Risk
• Worker on elevated platform without visible fall protection.	Fall from height due to lack of fall protection.
• Loose cable on the ground creating a trip hazard.	Tripping over loose cable leading to injury.
• Worker using a mobile phone in a construction zone.	Distraction from mobile phone use causing accidents.

AI Recommendations

- Ensure all workers on elevated platforms use proper fall protection equipment such as harnesses.
- Secure or remove loose cables from the ground to eliminate trip hazards.
- Prohibit mobile phone use in active construction zones unless necessary for work-related communication.

Analyzed Image

