```
****************************************************
*                                                  *
*           STAAD.Pro V8i SELECTseries3            *
*           Version  20.07.08.22                   *
*           Proprietary Program of                 *
*           Bentley Systems, Inc.                  *
*           Date=    DEC 11, 2012                  *
*           Time=     7:42:34                      *
*                                                  *
*      USER ID: JCUBE ENGINEERING SERVICES PTE L   *
****************************************************
```

```
     1. STAAD SPACE
INPUT FILE: 172-PF-02.STD
     2. START JOB INFORMATION
     3. ENGINEER DATE 12-NOV-12
     4. END JOB INFORMATION
     5. INPUT WIDTH 79
     6. UNIT METER KN
     7. JOINT COORDINATES
     8. 1 0 0 0; 2 0 1.2 0; 3 0 0 0.7; 4 0 1.2 0.7; 5 3.34 0 0; 6 3.34 1.2 0
     9. 7 3.34 0 0.7; 8 3.34 1.2 0.7; 9 6.7 0 0; 10 6.7 1.2 0; 11 6.7 0 0.7
    10. 12 6.7 1.2 0.7; 13 8.12 0 0; 14 8.12 0 0.7; 15 0 1.2 -0.25; 16 3.34 1.2 -0.25
    11. 17 6.7 1.2 -0.25; 18 0 1.2 0.95; 19 3.34 1.2 0.95; 20 6.7 1.2 0.95
    12. 21 0 1.2 0.35; 22 3.34 1.2 0.35; 23 6.7 1.2 0.35
    13. MEMBER INCIDENCES
    14. 1 1 2; 2 3 4; 3 5 6; 4 7 8; 5 9 10; 6 11 12; 11 2 21; 12 6 22; 13 10 23
    15. 14 13 10; 15 14 12; 16 15 2; 17 4 18; 18 16 6; 19 8 19; 20 17 10; 21 12 20
    16. 22 15 16; 23 16 17; 24 18 19; 25 19 20; 26 21 4; 27 22 8; 28 23 12; 29 21 22
    17. 30 22 23
    18. DEFINE MATERIAL START
    19. ISOTROPIC STEEL
    20. E 2.05E+008
    21. POISSON 0.3
    22. DENSITY 76.8195
    23. ALPHA 1.2E-005
    24. DAMP 0.03
    25. TYPE STEEL
    26. STRENGTH FY 253200 FU 407800 RY 1.5 RT 1.2
    27. END DEFINE MATERIAL
    28. MEMBER PROPERTY BRITISH
    29. 1 TO 6 11 TO 13 16 TO 30 TABLE ST UC152X152X23
    30. 14 15 TABLE ST CH200X75X23
    31. CONSTANTS
    32. BETA 90 MEMB 1 TO 6
    33. MATERIAL STEEL ALL
    34. SUPPORTS
    35. 1 3 5 7 9 11 13 14 PINNED
    36. MEMBER RELEASE
    37. 14 15 END MPY 0.99 MPZ 0.99
    38. LOAD 1 LOADTYPE DEAD  TITLE LOAD CASE 1 SELF WEIGHT
    39. SELFWEIGHT Y -1
    40. LOAD 2 LOADTYPE DEAD  TITLE LOAD CASE 2 SDL
```

```
   41. ONEWAY LOAD
   42. YRANGE 0 2 ONE -0.75 GY
**WARNING** about Floor/OneWay Loads/Weights.
  Please note that depending on the shape of the floor you may
  have to break up the FLOOR/ONEWAY LOAD into multiple commands.
  For details please refer to Technical Reference Manual
  Section 5.32.4 Note 6.

   43. MEMBER LOAD
   44. 14 15 UNI GY -0.375
   45. LOAD 3 LOADTYPE LIVE  TITLE LOAD CASE 3 LL
   46. ONEWAY LOAD
   47. YRANGE 0 2 ONE -5 GY
   48. MEMBER LOAD
   49. 14 15 UNI GY -2.5
   50. LOAD 4 LOADTYPE LIVE  TITLE LOAD CASE 4 WL(X)
   51. JOINT LOAD
   52. 2 4 FX 1.36
   53. LOAD 5 LOADTYPE LIVE  TITLE LOAD CASE 5 WL(Z)
   54. JOINT LOAD
   55. 15 TO 17 FZ 0.162
   56. LOAD COMB 6 COMBINATION LOAD CASE 6  1.0DL+1.0LL
   57. 1 1.0 2 1.0 3 1.0
   58. LOAD COMB 7 COMBINATION LOAD CASE 7 1.4DL+1.6LL+WL(X)
   59. 1 14.0 2 1.4 3 1.6 4 1.0
   60. LOAD COMB 8 COMBINATION LOAD CASE 8 1.0DL+1.4WL(X)
   61. 1 1.0 2 1.0 4 1.4
   62. LOAD COMB 9 COMBINATION LOAD CASE 9 1.2DL+1.2LL+1.2WL(X)
   63. 1 1.2 2 1.2 3 1.2 4 1.2
   64. LOAD COMB 10 COMBINATION LOAD CASE 10 1.4DL+1.6LL+WL(Z)
   65. 1 1.4 2 1.4 3 1.6 5 1.0
   66. LOAD COMB 11 COMBINATION LOAD CASE 11 1.0DL+1.4WL(Z)
   67. 1 1.0 2 1.0 5 1.4
   68. LOAD COMB 12 COMBINATION LOAD CASE 12 1.2DL+1.2LL+1.2WL(Z)
   69. 1 1.2 2 1.2 3 1.2 5 1.2
   70. PERFORM ANALYSIS
```

P R O B L E M   S T A T I S T I C S

NUMBER OF JOINTS/MEMBER+ELEMENTS/SUPPORTS =   23/   26/   8

```
       SOLVER USED IS THE OUT-OF-CORE BASIC SOLVER

 ORIGINAL/FINAL BAND-WIDTH=    19/     6/     39 DOF
 TOTAL PRIMARY LOAD CASES =    5, TOTAL DEGREES OF FREEDOM =    114
 SIZE OF STIFFNESS MATRIX =        5 DOUBLE  KILO-WORDS
 REQRD/AVAIL. DISK SPACE  =     12.1/ 268298.0 MB




71. PARAMETER 1
72. CODE BS5950
73. UNL 1.2 MEMB 11 TO 13 16 TO 21 26 TO 28
74. KY 1.5 MEMB 1 TO 6
75. KZ 1.5 MEMB 1 TO 6
76. CHECK CODE ALL


                     STAAD.Pro CODE CHECKING - (BSI )
                     ***********************

 PROGRAM CODE REVISION V2.13_5950-1_2000
```