```
****************************************************
*                                                  *
*           STAAD.Pro V8i SELECTseries5            *
*           Version  20.07.10.65                   *
*           Proprietary Program of                 *
*           Bentley Systems, Inc.                  *
*           Date=    SEP  6, 2018                  *
*           Time=     8:52:13                      *
*                                                  *
*      USER ID:                                    *
****************************************************
```

```
     1. STAAD PLANE
INPUT FILE: 3f3k floor beam.STD
     2. START JOB INFORMATION
     3. ENGINEER DATE 16-NOV-17
     4. END JOB INFORMATION
     5. INPUT WIDTH 79
     6. UNIT METER KN
     7. JOINT COORDINATES
     8. 32 0 6.195 0; 33 0.606667 6.195 0; 34 1.21333 6.195 0; 35 1.82 6.195 0
     9. 36 2.42667 6.195 0; 37 3.03333 6.195 0; 38 3.64 6.195 0; 39 4.24667 6.195 0
    10. 40 4.85333 6.195 0; 41 5.46 6.195 0; 42 0 6.795 0; 43 0.303333 6.795 0
    11. 45 0.91 6.795 0; 47 1.51667 6.795 0; 49 2.12333 6.795 0; 51 2.73 6.795 0
    12. 53 3.33667 6.795 0; 55 3.94333 6.795 0; 57 4.55 6.795 0; 59 5.15667 6.795 0
    13. 60 5.46 6.795 0; 76 6.66 6.795 0; 78 6.375 6.795 0
    14. MEMBER INCIDENCES
    15. 3 32 42; 4 41 60; 12 60 78; 14 78 76; 28 41 78; 72 32 33; 73 33 34; 74 34 35
    16. 75 35 36; 76 36 37; 77 37 38; 78 38 39; 79 39 40; 80 40 41; 81 42 43; 90 43 45
    17. 91 45 47; 92 47 49; 93 49 51; 94 51 53; 95 53 55; 96 55 57; 97 57 59; 98 59 60
    18. 117 32 43; 118 43 33; 119 45 33; 120 45 34; 121 47 34; 122 47 35; 123 49 35
    19. 124 49 36; 125 51 36; 126 51 37; 127 53 37; 128 53 38; 129 55 38; 130 55 39
    20. 131 57 39; 132 57 40; 133 59 40; 134 59 41
    21. START USER TABLE
    22. TABLE 1
    23. UNIT MMS KN
    24. GENERAL
    25. 2C75X45
    26. 1098 75 6 90 3 938192 638334 100000 26218 14185 450 270 26218 14185 100000 75
    27. TABLE 2
    28. UNIT MMS KN
    29. GENERAL
    30. C75X45
    31. 518 45 3 75 3 138000 449000 100000 4940 12000 270 315 4940 12000 100000 40
    32. TABLE 3
    33. UNIT MMS KN
    34. TUBE
    35. SHS38X3-CF
    36. 397 38 38 3 78500 78500 133000 228 152
    37. SHS50X3
    38. 564 50 50 3 208492 208492 311469 300 200
```



```
    39. SHS75X75X3
    40. 864 75 75 3 747792 747792 1.11974E+006 450 450
    41. TABLE 4
    42. UNIT MMS KN
    43. GENERAL
    44. C100X50
    45. 653 50 3 100 3 229000 990000 1E+006 7270 19800 300 343 11600 23600 1E+006 48
    46. TABLE 5
    47. UNIT MMS KN
    48. ANGLE
    49. UA38X38X3
    50. 38 38 3 7.51315 76 76
    51. TABLE 6
    52. UNIT MMS KN
    53. GENERAL
    54. C75NSHS75X3
    55. 1673 150 6 80 3 3.82575E+006 3.79732E+006 100000 51941 94933 690 848 -
    56. 51941 94933 100000 150
    57. END
    58. UNIT METER KN
    59. DEFINE MATERIAL START
    60. ISOTROPIC STEEL
    61. E 2.05E+008
    62. POISSON 0.3
    63. DENSITY 76.8195
    64. ALPHA 1.2E-005
    65. DAMP 0.03
    66. END DEFINE MATERIAL
    67. MEMBER PROPERTY BRITISH
    68. 28 UPTABLE 2 C75X45
    69. MEMBER PROPERTY BRITISH
    70. 72 TO 81 90 TO 98 UPTABLE 4 C100X50
    71. MEMBER PROPERTY BRITISH
    72. 117 TO 134 UPTABLE 5 UA38X38X3
    73. MEMBER PROPERTY BRITISH
    74. 12 14 UPTABLE 3 SHS75X75X3
    75. MEMBER PROPERTY BRITISH
    76. 3 4 UPTABLE 6 C75NSHS75X3
    77. CONSTANTS
    78. MATERIAL STEEL ALL
    79. SUPPORTS
    80. 41 PINNED
    81. 32 FIXED BUT FX FZ MX MY MZ
    82. MEMBER RELEASE
    83. 72 81 START MX MY MZ
    84. 80 98 END MX MY MZ
    85. MEMBER TRUSS
    86. 117 TO 134
    87. LOAD 1 LOADTYPE DEAD  TITLE DL
    88. SELFWEIGHT Y -1
    89. MEMBER LOAD
    90. 12 14 81 90 TO 98 UNI GY -0.55
    91. LOAD 2 LOADTYPE LIVE REDUCIBLE TITLE LL
    92. MEMBER LOAD
    93. 12 14 81 90 TO 98 UNI GY -5.46
    94. LOAD 3 LOADTYPE WIND  TITLE WL
```

17

```
 95. LOAD 4 LOADTYPE NONE  TITLE WLII
 96. MEMBER LOAD
 97. 3 UNI GX 0.6
 98. LOAD COMB 5 1.35DL+1.5LL
 99. 1 1.35 2 1.5
100. LOAD COMB 6 1.35DL+1.5LL+0.75WL
101. 1 1.35 2 1.5 3 0.75
102. LOAD COMB 7 1.35DL+1.05LL+1.35WL
103. 1 1.35 2 1.05 3 1.35
104. LOAD COMB 8 1.35DL+1.5LL+0.75WLII
105. 1 1.35 2 1.5 3 0.75
106. LOAD COMB 9 1.35DL+1.05LL+1.35WLII
107. 1 1.35 2 1.05 4 1.35
108. LOAD COMB 10 1.0DL+1.0LL
109. 1 1.0 2 1.0
110. PERFORM ANALYSIS


        P R O B L E M   S T A T I S T I C S
        -----------------------------------

  NUMBER OF JOINTS          23  NUMBER OF MEMBERS      42
  NUMBER OF PLATES           0  NUMBER OF SOLIDS        0
  NUMBER OF SURFACES         0  NUMBER OF SUPPORTS      2

        SOLVER USED IS THE OUT-OF-CORE BASIC SOLVER

  ORIGINAL/FINAL BAND-WIDTH=    13/     2/      9 DOF
TOTAL      PRIMARY LOAD CASES =      4, TOTAL DEGREES OF FREEDOM =       66
TOTAL LOAD COMBINATION  CASES =      6  SO FAR.
  SIZE OF STIFFNESS MATRIX =         1 DOUBLE  KILO-WORDS
  REQRD/AVAIL. DISK SPACE  =      12.1/-743999.3 MB


111. PARAMETER 1
112. CODE EN 1993-1-1:2005
113. SGR 1 ALL
114. CHECK CODE ALL

                    STAAD.PRO CODE CHECKING - EN 1993-1-1:2005
                    ********************************************
                    NATIONAL ANNEX - NOT USED

PROGRAM CODE REVISION V1.11 BS_EC3_2005/1
```



```
ALL UNITS ARE - KN   METE (UNLESS OTHERWISE Noted)

MEMBER     TABLE       RESULT/   CRITICAL COND/     RATIO/     LOADING/
                         FX            MY             MZ       LOCATION
=======================================================================

     3 ST  C75NSHS75X3   (UPT: DESIGNED AS I-SECTION)
                          PASS     EC-6.3.3-662       0.004         9

                         0.66 C         0.00         -0.04       0.25
     4 ST  C75NSHS75X3   (UPT: DESIGNED AS I-SECTION)
                          PASS     EC-6.3.3-662       0.068         5

                         5.32 C         0.00         -0.78       0.60
    12 ST  SHS75X75X3    (UPT)
                          PASS     EC-6.2.9.1         0.122         5

                         9.49 T         0.00          0.78       0.00
    14 ST  SHS75X75X3    (UPT)
                          PASS     EC-6.2.9.1         0.057         5

                         0.00           0.00          0.37       0.00
    28 ST  C75X45        (UPT: DESIGNED AS I-SECTION)
                          PASS     EC-6.3.3-662       0.126         5

                        11.41 C         0.00          0.05       0.00
    72 ST  C100X50       (UPT: DESIGNED AS I-SECTION)
                          PASS     EC-6.2.9.2/3       0.086         5

                        11.50 T         0.00          0.05       0.61
    73 ST  C100X50       (UPT: DESIGNED AS I-SECTION)
                          PASS     EC-6.2.9.2/3       0.202         5

                        29.93 T         0.00         -0.07       0.56
    74 ST  C100X50       (UPT: DESIGNED AS I-SECTION)
                          PASS     EC-6.2.9.2/3       0.282         5

                        42.62 T         0.00         -0.08       0.51
    75 ST  C100X50       (UPT: DESIGNED AS I-SECTION)
                          PASS     EC-6.2.9.2/3       0.328         5

                        49.79 T         0.00         -0.09       0.35
    76 ST  C100X50       (UPT: DESIGNED AS I-SECTION)
                          PASS     EC-6.2.9.2/3       0.338         5

                        51.37 T         0.00         -0.09       0.25
```

18