

```

*****
*
*          STAAD.Pro V8i SELECTseries3          *
*          Version  20.07.08.22                  *
*          Proprietary Program of                 *
*          Bentley Systems, Inc.                  *
*          Date=    NOV 26, 2012                  *
*          Time=    15:59:48                      *
*
*          USER ID: JCUBE ENGINEERING SERVICES PTE L
*****

```

```

1. STAAD SPACE
INPUT FILE: 172-PF-03_EL+0.0_Rev_26112012.STD
2. START JOB INFORMATION
3. ENGINEER DATE 12-NOV-12
4. END JOB INFORMATION
5. INPUT WIDTH 79
6. UNIT METER KN
7. JOINT COORDINATES
8. 1 0 1 0; 2 2.082 1 0; 5 0 1 1.6; 6 2.082 1 1.6; 9 0 1 3.2; 10 2.082 1 3.2
9. 13 0 1 4.8; 14 2.082 1 4.8; 15 1.041 1 0; 16 1.041 1 1.6; 17 1.041 1 3.2
10. 18 1.041 1 4.8; 23 0 2.5 0; 24 0 2.5 1.6; 25 0 2.5 3.2; 26 0 2.5 4.8
11. MEMBER INCIDENCES
12. 1 1 15; 5 5 16; 8 9 17; 11 13 18; 14 1 5; 15 2 6; 16 5 9; 17 6 10; 18 10 14
13. 19 9 13; 20 15 2; 21 16 6; 22 17 10; 23 18 14; 28 15 16; 29 16 17; 30 17 18
14. 31 1 23; 32 5 24; 33 9 25; 34 13 26
15. START USER TABLE
16. TABLE 1
17. UNIT METER KN
18. WIDE FLANGE
19. UC10210219.4
20. 0.00244007 0.1057 0.0071 0.1031 0.0088 4.67579E-006 1.60997E-006 5.73505E-008 -
21. 0.00075047 0.00181456
22. TABLE 2
23. UNIT METER KN
24. ANGLE
25. EA1001006
26. 0.1 0.1 0.006 0.0198945 0.0004 0.0004
27. END
28. DEFINE MATERIAL START
29. ISOTROPIC STEEL
30. E 2.05E+008
31. POISSON 0.3
32. DENSITY 76.8195
33. ALPHA 1.2E-005
34. DAMP 0.03
35. TYPE STEEL
36. STRENGTH FY 253200 FU 407800 RY 1.5 RT 1.2
37. END DEFINE MATERIAL
38. MEMBER PROPERTY AMERICAN
39. 1 5 8 11 14 TO 23 28 TO 34 UPTABLE 1 UC10210219.4
40. CONSTANTS

```

STAAD SPACE

-- PAGE NO. 2

41. MATERIAL STEEL ALL
 42. SUPPORTS
 43. 2 6 10 14 23 TO 26 PINNED
 44. MEMBER RELEASE
 45. 14 TO 19 28 TO 30 START MPY 0.99 MPZ 0.99
 46. 14 TO 19 28 TO 30 END MPY 0.99 MPZ 0.99
 47. LOAD 1 LOADTYPE DEAD TITLE LOAD CASE 1 SELF WEIGHT
 48. SELFWEIGHT Y -1
 49. LOAD 2 LOADTYPE DEAD TITLE LOAD CASE 2 SDL
 50. ONEWAY LOAD
 51. YRANGE 0 2.5 ONE -0.75 GY

****WARNING**** about Floor/Oneway Loads/Weights.

Please note that depending on the shape of the floor you may
 have to break up the FLOOR/ONEWAY LOAD into multiple commands.
 For details please refer to Technical Reference Manual
 Section 5.32.4 Note 6.

52. LOAD 3 LOADTYPE LIVE TITLE LOAD CASE 3 LL
 53. ONEWAY LOAD
 54. YRANGE 0 2.5 ONE -5 GY
 55. LOAD COMB 4 COMBINATION LOAD CASE 4 1.0DL+1.0LL
 56. 1 1.0 2 1.0 3 1.0
 57. LOAD COMB 5 COMBINATION LOAD CASE 5 1.4DL+1.6LL
 58. 1 1.4 2 1.4 3 1.6
 59. PERFORM ANALYSIS

P R O B L E M S T A T I S T I C S

NUMBER OF JOINTS/MEMBER+ELEMENTS/SUPPORTS = 16/ 21/ 8

SOLVER USED IS THE OUT-OF-CORE BASIC SOLVER

ORIGINAL/FINAL BAND-WIDTH= 12/ 4/ 27 DOF
 TOTAL PRIMARY LOAD CASES = 3, TOTAL DEGREES OF FREEDOM = 72
 SIZE OF STIFFNESS MATRIX = 2 DOUBLE KILO-WORDS
 REQD/AVAIL. DISK SPACE = 12.1/ 269753.3 MB

60. PARAMETER 2
 61. CODE BS5950
 62. KY 1.5 MEMB 31 TO 34
 63. KZ 1.5 MEMB 31 TO 34
 64. CHECK CODE ALL