

```

*****
*
*          STAAD.Pro V8i SELECTseries3          *
*          Version  20.07.08.22                  *
*          Proprietary Program of                 *
*          Bentley Systems, Inc.                  *
*          Date=    NOV 12, 2012                  *
*          Time=    18:11:54                      *
*
*          USER ID: JCUBE ENGINEERING SERVICES PTE L  *
*****

```

```

1. STAAD SPACE
INPUT FILE: 172-PF-04.STD
2. START JOB INFORMATION
3. ENGINEER DATE 12-NOV-12
4. END JOB INFORMATION
5. INPUT WIDTH 79
6. UNIT METER KN
7. JOINT COORDINATES
8. 1 0 0 0; 2 0 0 0.5; 3 1.75 0 0; 4 1.75 0 0.5; 5 3.5 0 0; 6 3.5 0 0.5
9. 7 0 0 0.05; 8 1.75 0 0.05; 9 3.5 0 0.05
10. MEMBER INCIDENCES
11. 1 1 7; 2 3 8; 3 5 9; 4 2 4; 5 4 6; 8 7 2; 9 8 4; 10 9 6; 11 7 8; 12 8 9
12. START USER TABLE
13. TABLE 1
14. UNIT METER KN
15. WIDE FLANGE
16. UC102102
17. 0.00244007 0.1057 0.0071 0.1031 0.0088 4.67579E-006 1.60997E-006 -
18. 5.73505E-008 0.00075047 0.00181456
19. END
20. MEMBER RELEASE
21. 4 5 11 12 START MPY 0.99 MPZ 0.99
22. 4 5 11 12 END MPY 0.99 MPZ 0.99
23. DEFINE MATERIAL START
24. ISOTROPIC STEEL
25. E 2.05E+008
26. POISSON 0.3
27. DENSITY 76.8195
28. ALPHA 1.2E-005
29. DAMP 0.03
30. TYPE STEEL
31. STRENGTH FY 253200 FU 407800 RY 1.5 RT 1.2
32. END DEFINE MATERIAL
33. MEMBER PROPERTY
34. 1 TO 5 8 TO 12 UPTABLE 1 UC102102
35. CONSTANTS
36. MATERIAL STEEL ALL
37. SUPPORTS
38. 1 3 5 FIXED
39. LOAD 1 LOADTYPE DEAD TITLE LOAD CASE 1 SELF WEIGHT
40. SELFWEIGHT Y -1 LIST ALL

```

STAAD SPACE

-- PAGE NO. 2

41. LOAD 2 LOADTYPE DEAD TITLE LOAD CASE 2 SDL
 42. ONEWAY LOAD
 43. YRANGE 0 1 ONE -0.75 GY

****WARNING**** about Floor/OneWay Loads/Weights.

Please note that depending on the shape of the floor you may have to break up the FLOOR/ONEWAY LOAD into multiple commands. For details please refer to Technical Reference Manual Section 5.32.4 Note 6.

44. LOAD 3 LOADTYPE LIVE TITLE LOAD CASE 3 LL
 45. ONEWAY LOAD
 46. YRANGE 0 1 ONE -5 GY
 47. LOAD COMB 4 COMBINATION LOAD CASE 4 1.0DL+1.0LL
 48. 1 1.0 2 1.0 3 1.0
 49. LOAD COMB 5 COMBINATION LOAD CASE 5 1.4DL+1.6LL
 50. 1 1.4 2 1.4 3 1.4 4 1.6
 51. PERFORM ANALYSIS

P R O B L E M S T A T I S T I C S

NUMBER OF JOINTS/MEMBER+ELEMENTS/SUPPORTS = 9/ 10/ 3

SOLVER USED IS THE OUT-OF-CORE BASIC SOLVER

ORIGINAL/FINAL BAND-WIDTH= 6/ 3/ 18 DOF
 TOTAL PRIMARY LOAD CASES = 3, TOTAL DEGREES OF FREEDOM = 36
 SIZE OF STIFFNESS MATRIX = 1 DOUBLE KILO-WORDS
 REQ'D/AVAIL. DISK SPACE = 12.0/ 270767.1 MB

52. PARAMETER 1
 53. CODE BS5950
 54. CHECK CODE ALL

STAAD.Pro CODE CHECKING - (BSI)

PROGRAM CODE REVISION V2.13_5950-1_2000