

```

*****
*
*          STAAD.Pro V8i SELECTseries3          *
*          Version  20.07.08.22                  *
*          Proprietary Program of                 *
*          Bentley Systems, Inc.                  *
*          Date=    JAN 30, 2013                  *
*          Time=    16:32:28                      *
*
*          USER ID: JCUBE ENGINEERING SERVICES PTE L
*****

```

```

1. STAAD SPACE
INPUT FILE: 199-PF-01.STD
2. START JOB INFORMATION
3. ENGINEER DATE 24-NOV-12
4. END JOB INFORMATION
5. INPUT WIDTH 79
6. UNIT METER KN
7. JOINT COORDINATES
8. 3 1.85 1.55 0; 4 5.25 1.55 0; 7 1.85 1.55 0.8; 8 5.25 1.55 0.8; 10 1.85 0 0
9. 11 5.25 0 0; 12 1.85 0 0.8; 13 5.25 0 0.8; 14 5.25 0 -1.85; 15 4.45 1.55 0
10. 16 4.45 0 -1.85; 17 1.85 0 2.65; 18 2.65 1.55 0.8; 19 2.65 0 2.65
11. MEMBER INCIDENCES
12. 3 3 15; 6 7 18; 8 10 3; 9 12 7; 10 11 4; 11 13 8; 12 3 7; 13 4 8; 14 14 4
13. 15 15 4; 16 16 15; 17 17 7; 18 18 8; 19 19 18
14. DEFINE MATERIAL START
15. ISOTROPIC STEEL
16. E 2.05E+008
17. POISSON 0.3
18. DENSITY 76.8195
19. ALPHA 1.2E-005
20. DAMP 0.03
21. TYPE STEEL
22. STRENGTH FY 253200 FU 407800 RY 1.5 RT 1.2
23. END DEFINE MATERIAL
24. MEMBER PROPERTY BRITISH
25. 3 6 8 TO 13 15 18 TABLE ST UC152X152X23
26. 14 16 17 19 TABLE ST CH200X75X23
27. CONSTANTS
28. BETA 90 MEMB 8 TO 11
29. MATERIAL STEEL ALL
30. MEMBER RELEASE
31. 14 16 17 19 END MPY 0.99 MPZ 0.99
32. SUPPORTS
33. 10 TO 14 16 17 19 PINNED
34. DEFINE WIND LOAD
35. TYPE 1 WIND 1
36. INT 0.337 HEIG 1.55
37. LOAD 1 LOADTYPE DEAD TITLE LOAD CASE 1 SELF WEIGHT
38. SELFWEIGHT Y -1
39. LOAD 2 LOADTYPE DEAD TITLE LOAD CASE 2 SDL
40. ONEWAY LOAD

```

STAAD SPACE

-- PAGE NO. 2

41. YRANGE 0 1.6 ONE -0.75 GY

****WARNING**** about Floor/Oneway Loads/Weights.

Please note that depending on the shape of the floor you may have to break up the FLOOR/ONEWAY LOAD into multiple commands. For details please refer to Technical Reference Manual Section 5.32.4 Note 6.

42. MEMBER LOAD

43. 14 16 17 19 UNI GY -0.3

44. LOAD 3 LOADTYPE LIVE REDUCIBLE TITLE LOAD CASE 3 LIVE LOAD

45. ONEWAY LOAD

46. YRANGE 0 1.6 ONE -5 GY

47. MEMBER LOAD

48. 14 16 17 19 UNI GY -1.6

49. LOAD 4 LOADTYPE WIND TITLE LOAD CASE 4 WIND LOAD X

50. WIND LOAD X 1 TYPE 1 XR 1.85 1.86 YR 0 1.55 OPEN

51. LOAD 5 LOADTYPE WIND TITLE LOAD CASE 5 WIND LOAD Z

52. WIND LOAD Z 1 TYPE 1 XR 0 7.8 YR 0 1.55 ZR 0 0.1 OPEN

53. LOAD 6 LOADTYPE NONE TITLE LOAD CASE 6 NOTIONAL LOAD X

54. NOTIONAL LOAD

55. 1 X 0.007 2 X 0.007 3 X 0.008

56. LOAD 7 LOADTYPE NONE TITLE LOAD CASE 7 NOTIONAL Z

57. NOTIONAL LOAD

58. 1 Z 0.007 2 Z 0.007 3 Z 0.008

59. LOAD COMB 8 COMBINATION LOAD CASE 8 1.0DL+1.0LL

60. 1 1.0 2 1.0 3 1.0

61. LOAD COMB 9 COMBINATION LOAD CASE 9 1.4DL+1.6LL

62. 1 1.4 2 1.4 3 1.6

63. LOAD COMB 10 COMBINATION LOAD CASE 10 1.4DL+1.6LL+1.0WLX

64. 1 1.4 2 1.4 3 1.6 4 1.0

65. LOAD COMB 11 COMBINATION LOAD CASE 11 1.4DL+1.6LL+1.0WLZ

66. 1 1.4 2 1.4 3 1.6 5 1.0

67. LOAD COMB 12 COMBINATION LOAD CASE 12 1.4DL+1.6LL+1.0NLX

68. 1 1.4 2 1.4 3 1.6 6 1.0

69. LOAD COMB 13 COMBINATION LOAD CASE 13 1.4DL+1.6LL+1.0NLZ

70. 1 1.4 2 1.4 3 1.6 7 1.0

71. LOAD COMB 14 COMBINATION LOAD CASE 14 1.0DL+1.4WLX

72. 1 1.0 2 1.0 4 1.4

73. LOAD COMB 15 COMBINATION LOAD CASE 15 1.0DL+1.4WLZ

74. 1 1.0 2 1.0 5 1.4

75. LOAD COMB 16 COMBINATION LOAD CASE 16 1.0DL+1.4NLX

76. 1 1.0 2 1.0 6 1.4

77. LOAD COMB 17 COMBINATION LOAD CASE 17 1.0DL+1.4NLZ

78. 1 1.0 2 1.0 7 1.4

STAAD SPACE

-- PAGE NO. 3

79. LOAD COMB 18 COMBINATION LOAD CASE 18 1.2DL+1.2LL+1.2WLX
 80. 1 1.2 2 1.2 3 1.2 4 1.2
 81. LOAD COMB 19 COMBINATION LOAD CASE 19 1.2DL+1.2LL+1.2WLZ
 82. 1 1.2 2 1.2 5 1.2
 83. LOAD COMB 20 COMBINATION LOAD CASE 20 1.2DL+1.2LL+1.2NLX
 84. 1 1.2 2 1.2 3 1.2 6 1.2
 85. LOAD COMB 21 COMBINATION LOAD CASE 21 1.2DL+1.2LL+1.2NLZ
 86. 1 1.2 2 1.2 3 1.2 7 1.2
 87. LOAD COMB 100 COMBINATION LOAD CASE 100
 88. 1 1.0 2 1.0
 89. PERFORM ANALYSIS

P R O B L E M S T A T I S T I C S

NUMBER OF JOINTS/MEMBER+ELEMENTS/SUPPORTS = 14/ 14/ 8

SOLVER USED IS THE OUT-OF-CORE BASIC SOLVER

ORIGINAL/FINAL BAND-WIDTH= 10/ 4/ 24 DOF
 TOTAL PRIMARY LOAD CASES = 7, TOTAL DEGREES OF FREEDOM = 60
 SIZE OF STIFFNESS MATRIX = 2 DOUBLE KILO-WORDS
 REQ'D/AVAIL. DISK SPACE = 12.0/ 202321.3 MB

90. PARAMETER 2
 91. CODE BS5950
 92. KY 1.5 MEMB 8 TO 11
 93. KZ 1.5 MEMB 8 TO 11
 94. CHECK CODE ALL

STAAD.Pro CODE CHECKING - (BSI)

PROGRAM CODE REVISION V2.13_5950-1_2000