

```

*****
*
*          STAAD.Pro V8i SELECTseries3          *
*          Version  20.07.08.22                  *
*          Proprietary Program of                 *
*          Bentley Systems, Inc.                  *
*          Date=    MAY 14, 2013                  *
*          Time=    19:27:13                      *
*
*          USER ID: JCUBE ENGINEERING SERVICES PTE L  *
*****

```

```

1. STAAD SPACE
INPUT FILE: 562-PF-01B_Rev_14022013.STD
2. START JOB INFORMATION
3. ENGINEER DATE 11-DEC-12
4. END JOB INFORMATION
5. INPUT WIDTH 79
6. UNIT METER KN
7. JOINT COORDINATES
8. 1 0 0 0; 2 1.102 0 0; 3 2.602 0 0; 4 0 0 2.305; 5 1.102 0 2.305
9. 6 2.602 0 2.305; 7 1.102 -2.5 0; 8 2.602 -2.5 0; 9 1.102 -2.5 2.305
10. 10 2.602 -2.5 2.305; 11 2.602 0 1.175; 12 1.102 0 1.1525; 13 0 0 1.1525
11. MEMBER INCIDENCES
12. 1 1 2; 2 2 3; 3 4 5; 4 5 6; 5 1 13; 6 3 11; 7 7 2; 8 9 5; 9 8 3; 10 10 6
13. 11 11 6; 12 2 12; 13 12 5; 14 13 4; 15 13 12; 16 12 11
14. DEFINE MATERIAL START
15. ISOTROPIC STEEL
16. E 2.05E+008
17. POISSON 0.3
18. DENSITY 76.8195
19. ALPHA 1.2E-005
20. DAMP 0.03
21. TYPE STEEL
22. STRENGTH FY 253200 FU 407800 RY 1.5 RT 1.2
23. END DEFINE MATERIAL
24. MEMBER PROPERTY BRITISH
25. 1 TO 16 TABLE ST UC152X152X23
26. CONSTANTS
27. BETA 90 MEMB 7 TO 10
28. MATERIAL STEEL ALL
29. SUPPORTS
30. 7 TO 10 PINNED
31. MEMBER RELEASE
32. 5 15 16 START MPY 0.99 MPZ 0.99
33. 14 TO 16 END MPY 0.99 MPZ 0.99
34. DEFINE WIND LOAD
35. TYPE 1 WIND 1
36. INT 0.4 HEIG 2.5
37. LOAD 1 LOADTYPE DEAD TITLE LOAD CASE 1 SELF WEIGHT
38. SELFWEIGHT Y -1
39. LOAD 2 LOADTYPE DEAD TITLE LOAD CASE 2 SDL
40. ONEWAY LOAD

```

41. YRANGE 0 2.5 ONE -0.75 GY TOWARDS 4

****WARNING**** about Floor/OneWay Loads/Weights.

Please note that depending on the shape of the floor you may have to break up the FLOOR/ONEWAY LOAD into multiple commands. For details please refer to Technical Reference Manual Section 5.32.4 Note 6.

42. LOAD 3 LOADTYPE LIVE TITLE LOAD CASE 3 LIVE LOAD

43. ONEWAY LOAD

44. YRANGE 0 2.5 ONE -5 GY TOWARDS 4

45. LOAD 4 LOADTYPE NONE TITLE LOAD CASE 4 HNLX

46. NOTIONAL LOAD

47. 1 X 0.07 2 X 0.07 3 X 0.08

48. LOAD 5 LOADTYPE NONE TITLE LOAD CASE 5 HNLZ

49. NOTIONAL LOAD

50. 1 Z 0.07 2 Z 0.07 3 Z 0.08

51. LOAD 6 LOADTYPE WIND TITLE LOAD CASE 6 WLX

52. WIND LOAD -X 1 TYPE 1 XR 2.6 2.605 OPEN

53. LOAD 7 LOADTYPE WIND TITLE LOAD CASE 7 WLZ

54. WIND LOAD Z 1 TYPE 1 ZR 0 0.1 OPEN

55. LOAD COMB 8 COMBINATION LOAD CASE 8 1.4DL+1.6LL+1.0HNLX

56. 1 1.4 2 1.4 3 1.6 4 1.0

57. LOAD COMB 9 COMBINATION LOAD CASE 9 1.4DL+1.6LL+1.0HNLZ

58. 1 1.4 2 1.4 3 1.6 5 1.0

59. LOAD COMB 10 COMBINATION LOAD CASE 10 1.0DL+1.4WLX

60. 1 1.0 2 1.0 6 1.4

61. LOAD COMB 11 COMBINATION LOAD CASE 11 1.0DL+1.4WLZ

62. 1 1.0 2 1.0 7 1.4

63. LOAD COMB 12 COMBINATION LOAD CASE 12 1.2DL+1.2LL+1.2WLX

64. 1 1.2 2 1.2 3 1.2 6 1.2

65. LOAD COMB 13 COMBINATION LOAD CASE 13 1.2DL+1.2LL+1.2WLZ

66. 1 1.2 2 1.2 3 1.2 7 1.2

67. PERFORM ANALYSIS

P R O B L E M S T A T I S T I C S

NUMBER OF JOINTS/MEMBER+ELEMENTS/SUPPORTS = 13/ 16/ 4

SOLVER USED IS THE OUT-OF-CORE BASIC SOLVER

ORIGINAL/FINAL BAND-WIDTH= 12/ 4/ 27 DOF
 TOTAL PRIMARY LOAD CASES = 7, TOTAL DEGREES OF FREEDOM = 66
 SIZE OF STIFFNESS MATRIX = 2 DOUBLE KILO-WORDS
 REQD/AVAIL. DISK SPACE = 12.1/ 168330.8 MB

68. PARAMETER 1
 69. CODE BS5950
 70. LY 2.31 MEMB 6 11 TO 13
 71. UNL 2.31 MEMB 6 11 TO 13
 72. KY 1.5 MEMB 7 TO 10
 73. KZ 1.5 MEMB 7 TO 10
 74. CHECK CODE MEMB 1 TO 4 6 TO 13 15 16

STAAD.Pro CODE CHECKING - (BSI)

PROGRAM CODE REVISION V2.13_5950-1_2000