

```
*****
* STAAD.Pro V8i SELECTseries1
* Version 20.07.06.35
* Proprietary Program of
* Bentley Systems, Inc.
* Date= MAY 14, 2013
* Time= 9:54:59
*
* USER ID: LONGROVE ASSOCIATES PTE LTD
*****

1. STAAD PLANE DXF IMPORT OF FRAME01.DXF
INPUT FILE: Frame01.STD
2. START JOB INFORMATION
3. JOB NAME BICYCLE SHED FOR JRC AT JI
4. JOB CLIENT LISTONE PTE LTD
5. JOB NO 13110-40
6. ENGINEER NAME CH
7. ENGINEER DATE 14-MAY-13
8. END JOB INFORMATION
9. INPUT WIDTH 79
10. UNIT METER KN
11. JOINT COORDINATES
12. 1 0 0 0; 2 1E-016 2.2 0; 3 2.7 0 0; 4 2.7 2.49378 0; 5 -0.5 2.14745 0
13. 6 3.2 2.55633 0
14. MEMBER INCIDENCES
15. 1 1 2; 2 3 4; 3 5 2; 4 2 4; 5 4 6
16. START USER TABLE
17. TABLE 1
18. UNIT METER KN
19. TUBE
20. SHS100X3
21. 0.0014 0.1 0.1 0.003 1.77E-006 1.77E-006 2.73802E-006 0.0006 0.0006
22. TABLE 2
23. UNIT METER KN
24. TUBE
25. RHS150X100X4.5
26. 0.00212 0.15 0.1 0.0045 6.58E-006 3.52E-006 7.21038E-006 0.00135 0.0009
27. END
28. DEFINE MATERIAL START
29. ISOTROPIC STEEL
30. E 2.05E+008
31. POISSON 0.3
32. DENSITY 76.6195
33. ALPHA 1.2E-005
34. DAMP 0.03
35. END DEFINE MATERIAL
36. MEMBER PROPERTY
37. 3 TO 5 UPTABLE 1 SHS100X3
38. 1 2 UPTABLE 2 RHS150X100X4.5
39. CONSTANTS
40. MATERIAL STEEL ALL
```

DXF IMPORT OF FRAME01.DXF

```
41. SUPPORTS
42. 1 3 FINNED
43. LOAD 1 LOADTYPE DEAD TITLE DL
44. SELFWEIGHT Y -1 LIST 1 TO 5
45. MEMBER LOAD
46. 3 TO 5 UNI GY -0.85
47. LOAD 2 LOADTYPE LIVE TITLE LL
48. MEMBER LOAD
49. 3 TO 5 UNI GY -1.7
50. LOAD COMB 3 1.4DL+1.6LL
51. 1 1.4 2 1.6
52. LOAD COMB 4 SERVICE
53. 1 1.0 2 1.0
54. PERFORM ANALYSIS
```

PROBLEM STATISTICS

NUMBER OF JOINTS/MEMBER/ELEMENTS/SUPPORTS = 6/ 5/ 2

SOLVER USED IS THE OUT-OF-CORE BASIC SOLVER

ORIGINAL/FINAL BAND-WIDTH= 3/ 3/ 10 DOF
TOTAL PRIMARY LOAD CASES = 2, TOTAL DEGREES OF FREEDOM = 14
SIZE OF STIFFNESS MATRIX = 1 DOUBLE KILO-WORDS
REORD/AVAIL. DISK SPACE = 12.0/ 208667.1 MB

55. PARAMETER 1
56. CODE BS5950
57. CHECK CODE ALL

STAAD.Pro CODE CHECKING - (BSI)

PROGRAM CODE REVISION V2.12_5950-1_2000