

```
*****
*
*      STAAD.Pro
*      Version 2007   Build 04
*      Proprietary Program of
*      Research Engineers, Intl.
*      Date=   JAN 18, 2013
*      Time=   17: 9: 4
*
*      USER ID:
*****
```

```
1. STAAD SPACE
INPUT FILE: 20121120 T-Goal Post 021-022 FR.STD
2. START JOB INFORMATION
3. ENGINEER DATE 12-MAY-12
4. END JOB INFORMATION
5. INPUT WIDTH 79
6. UNIT METER KN
7. JOINT COORDINATES
8. 2 5 1 -6.085; 4 5 2.197 -6.085; 6 5 2.197 -10.085; 11 5 1 -10.085
9. MEMBER INCIDENCES
10. 3 2 4; 5 6 4; 10 11 6
11. DEFINE MATERIAL START
12. ISOTROPIC STEEL
13. E 2.05E+008
14. POISSON 0.3
15. DENSITY 76.8195
16. ALPHA 1.2E-005
17. DAMP 0.03
18. END DEFINE MATERIAL
19. MEMBER PROPERTY JAPANESE
20. 3 10 TABLE ST H394X398X11
21. 5 TABLE ST H394X398X11
22. CONSTANTS
23. BETA 90 MEMB 3 10
24. MATERIAL STEEL ALL
25. SUPPORTS
26. 2 11 FIXED
27. ***** DEAD LOAD *****
28. LOAD 1 LOADTYPE NONE TITLE DL
29. SELFWEIGHT Y -1
30. MEMBER LOAD
31. 5 CON GY -16.34 0.3
32. 5 CON GY -16.34 2
33. 5 CON GY -16.34 3.7
34. ***** FRICTIONAL LOAD *****
35. LOAD 2 LOADTYPE NONE TITLE FL
36. MEMBER LOAD
37. 5 CON GX -3.4 0.3
38. 5 CON GX -3.4 2
39. 5 CON GX -3.4 3.7
40. ***** WIND LOAD X-DIRECTION*****
41. LOAD 3 LOADTYPE NONE TITLE WLX
42. MEMBER LOAD
43. 5 UNI GX -0.34
44. 3 10 UNI GX -0.34
45. ***** WIND LOAD Z-DIRECTION*****
46. LOAD 4 LOADTYPE NONE TITLE WLZ
47. MEMBER LOAD
48. 3 10 UNI GZ -0.34
49. ***** NOTIONAL LOAD X-DIRECTION*****
50. LOAD 5 LOADTYPE NONE TITLE NLX
51. SELFWEIGHT X -0.015
52. MEMBER LOAD
53. 5 CON GX -0.2451 0.3
```

```
54. 5 CON GX -0.2451 2
55. 5 CON GX -0.2451 3.7
56. *****NOTIONAL LOAD Z-DIRECTION*****
57. LOAD 6 LOADTYPE NONE TITLE NLZ
58. SELFWEIGHT Z -0.015
59. MEMBER LOAD
60. 5 CON GZ -0.2451 0.3
61. 5 CON GZ -0.2451 2
62. 5 CON GZ -0.2451 3.7
63. ***** LOAD COMBINATION - SERVICE *****
64. LOAD COMB 7 1.0DL+1.0FL
65. 1 1.0 2 1.0
66. LOAD COMB 8 1.0DL+1.0FL+1.0WLX
67. 1 1.0 2 1.0 3 1.0
68. LOAD COMB 9 1.0DL+1.0FL+1.0WLX
69. 1 1.0 2 1.0 4 1.0
70. LOAD COMB 10 1.0DL+1.0FL+1.0NLX
71. 1 1.0 2 1.0 5 1.0
72. LOAD COMB 11 1.0DL+1.0FL+1.0NLZ
73. 1 1.0 2 1.0 6 1.0
74. ***** LOAD COMBINATION - ULTIMATE *****
75. LOAD COMB 12 1.0DL+1.4FL
76. 1 1.0 2 1.4
77. LOAD COMB 13 1.4DL+1.4FL
78. 1 1.4 2 1.4
79. LOAD COMB 14 1.0DL+1.4FL+1.4WLX
80. 1 1.0 2 1.4 3 1.4
81. LOAD COMB 15 1.0DL+1.4FL+1.4WLZ
82. 1 1.0 2 1.4 4 1.4
83. LOAD COMB 16 1.0DL+1.4FL+1.4NLX
84. 1 1.0 2 1.4 5 1.4
85. LOAD COMB 17 1.0DL+1.4FL+1.4NLZ
86. 1 1.0 2 1.4 6 1.4
87. PERFORM ANALYSIS
```

PROBLEM STATISTICS

NUMBER OF JOINTS/MEMBER+ELEMENTS/SUPPORTS = 4/ 3/ 2

SOLVER USED IS THE IN-CORE ADVANCED SOLVER

TOTAL PRIMARY LOAD CASES = 6, TOTAL DEGREES OF FREEDOM = 12

88. LOAD LIST 7 TO 11
89. PRINT JOINT DISPLACEMENTS ALL

JOINT DISPLACEMENT (CM RADIANS) STRUCTURE TYPE = SPACE

JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
2	7	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	8	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	9	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	10	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	11	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
4	7	-0.0083	-0.0009	-0.0004	-0.0001	0.0001	0.0001
	8	-0.0097	-0.0009	-0.0004	-0.0001	0.0002	0.0001
	9	-0.0083	-0.0009	-0.0005	-0.0001	0.0001	0.0001
	10	-0.0090	-0.0009	-0.0004	-0.0001	0.0001	0.0001
	11	-0.0083	-0.0009	-0.0007	-0.0001	0.0001	0.0001

Friday, January 18, 2013, 05:09 PM

Friday, January 18, 2013, 05:09 PM

	8	-0.0097	-0.0009	0.0004	0.0001	-0.0002	0.0001
	9	-0.0083	-0.0009	0.0003	0.0001	-0.0001	0.0001
	10	-0.0090	-0.0009	0.0004	0.0001	-0.0001	0.0001
	11	-0.0083	-0.0009	0.0001	0.0001	-0.0001	0.0001
11	7	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	8	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	9	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	10	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	11	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000

***** END OF LATEST ANALYSIS RESULT *****

90. PRINT SUPPORT REACTION ALL

SUPPORT REACTIONS -UNIT KN METE STRUCTURE TYPE = SPACE

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM Z
	2	7	5.10	29.10	-7.50	1.85	-0.02
		8	6.19	29.10	-7.50	1.85	-0.02
		9	5.10	29.07	-7.09	2.05	-0.02
		10	5.54	29.10	-7.50	1.85	-0.02
		11	5.10	29.02	-7.06	2.21	-0.02
11	7	5.10	29.10	7.50	-1.85	0.02	-6.10
	8	6.19	29.10	7.50	-1.85	0.02	-7.16
	9	5.10	29.12	7.90	-1.66	0.02	-6.10
	10	5.54	29.10	7.50	-1.85	0.02	-6.61
	11	5.10	29.17	7.93	-1.49	0.02	-6.10

***** END OF LATEST ANALYSIS RESULT *****

91. LOAD LIST 12 TO 17

92. PRINT MEMBER FORCES ALL

MEMBER END FORCES STRUCTURE TYPE = SPACE

ALL UNITS ARE -- KN METE (LOCAL)

MEMBER	LOAD	JT	AXIAL	SHEAR-Y	SHEAR-Z	TORSION	MOM-Y	MOM-Z
	3	12	2	29.10	-7.50	7.14	-0.02	-8.55
		4	-27.38	7.50	-7.14	0.02	0.00	-10.82
	13	2	40.74	-10.49	7.14	-0.02	-8.55	2.59
		4	-38.33	10.49	-7.14	0.02	0.00	-15.15
	14	2	29.10	-7.50	8.66	-0.03	-10.03	1.85
		4	-27.38	7.50	-8.09	0.03	0.00	-10.82
	15	2	29.06	-6.93	7.14	-0.02	-8.55	2.13
		4	-27.35	7.50	-7.14	0.02	0.00	-10.76
	16	2	29.10	-7.50	7.75	-0.02	-9.26	1.85
		4	-27.38	7.50	-7.71	0.02	0.00	-10.82
	17	2	28.99	-6.88	7.14	-0.02	-8.55	2.36
		4	-27.28	6.92	-7.14	0.02	0.00	-10.62
	5	12	6	7.50	27.38	-7.14	0.00	0.02
		4	-7.50	27.38	-7.14	0.00	-0.02	-10.82
	13	6	10.49	38.33	-7.14	0.00	0.02	15.15
		4	-10.49	38.33	-7.14	0.00	-0.02	-15.15

	4	-7.50	27.38	-8.09	0.00	-0.03	-10.82
15	6	7.50	27.41	-7.14	0.00	0.02	10.89
	4	-7.50	27.35	-7.14	0.00	-0.02	-10.76
16	6	7.50	27.38	-7.71	0.00	0.02	10.82
	4	-7.50	27.38	-7.71	0.00	-0.02	-10.82
17	6	8.07	27.48	-7.14	0.00	0.02	11.03
	4	-6.92	27.28	-7.14	0.00	-0.02	-10.62
10	12	11	29.10	7.50	7.14	0.02	-8.55
	6	-27.38	-7.50	-7.14	-0.02	0.00	10.82
13	11	40.74	10.49	7.14	0.02	-8.55	-2.59
	6	-38.33	-10.49	-7.14	-0.02	0.00	15.15
14	11	29.10	7.50	8.66	0.03	-10.03	-1.85
	6	-27.38	-7.50	-8.09	-0.03	0.00	10.82
15	11	29.13	8.06	7.14	0.02	-8.55	-1.58
	6	-27.41	-7.50	-7.14	-0.02	0.00	10.89
16	11	29.10	7.50	7.75	0.02	-9.26	-1.85
	6	-27.38	-7.50	-7.71	-0.02	0.00	10.82
17	11	29.20	8.11	7.14	0.02	-8.55	-1.35
	6	-27.48	-8.07	-7.14	-0.02	0.00	11.03

***** END OF LATEST ANALYSIS RESULT *****

93. LOAD LIST ALL

94. PARAMETER 1

95. CODE BS5950

96. BEAM 2 ALL

97. CHECK CODE ALL

STAAD.Pro CODE CHECKING - (BSI)

PROGRAM CODE REVISION V2.12_5950-1_2000

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
3	ST	H394X398X11	PASS	BS-4.8.3.3.2	0.051
		40.74 C	8.55	15.15	-
5	ST	H394X398X11	PASS	BS-4.2.3-(Y)	0.056
		10.49 C	0.02	15.15	0.00
10	ST	H394X398X11	PASS	BS-4.8.3.3.2	0.051
		40.74 C	8.55	15.15	-

***** END OF TABULATED RESULT OF DESIGN *****

98. FINISH

***** END OF THE STAAD.Pro RUN *****

**** DATE= JAN 18,2013 TIME= 17: 9: 6 ****

*	For questions on STAAD.Pro, please contact	*	
*	Research Engineers Offices at the following locations	*	
*		*	
*	Telephone	Email	*
*	USA: +1 (714)974-2500	support@bentley.com	*