

```

*****
*
*      STAAD.Pro
*      Version 2007   Build 04
*      Proprietary Program of
*      Research Engineers, Intl.
*      Date=   JAN 18, 2013
*      Time=   16:44:18
*
*      USER ID:
*****

```

```

1. STAAD SPACE
INPUT FILE: 20121120 T-Goal Post 041 FR.STD
2. START JOB INFORMATION
3. ENGINEER DATE 12-MAY-12
4. END JOB INFORMATION
5. INPUT WIDTH 79
6. UNIT METER KN
7. JOINT COORDINATES
8. 2 5 1 -5.73; 4 5 4.495 -5.73; 5 5 4.495 -5.03
9. MEMBER INCIDENCES
10. 3 2 4; 4 4 5
11. DEFINE MATERIAL START
12. ISOTROPIC STEEL
13. E 2.05E+008
14. POISSON 0.3
15. DENSITY 76.8195
16. ALPHA 1.2E-005
17. DAMP 0.03
18. END DEFINE MATERIAL
19. MEMBER PROPERTY JAPANESE
20. 4 TABLE ST H428X407X20
21. 3 TABLE ST H428X407X20
22. CONSTANTS
23. BETA 90 MEMB 3
24. MATERIAL STEEL ALL
25. SUPPORTS
26. 2 FIXED
27. ***** DEAD LOAD *****
28. LOAD 1 LOADTYPE NONE TITLE DL
29. SELFWEIGHT Y -1
30. MEMBER LOAD
31. 4 CON GY -19.6 0.35
32. ***** FRICTIONAL LOAD *****
33. LOAD 2 LOADTYPE NONE TITLE FL
34. MEMBER LOAD
35. 4 CON GX -5.88 0.35
36. ***** WIND LOAD X-DIRECTION*****
37. LOAD 3 LOADTYPE NONE TITLE WLX
38. MEMBER LOAD
39. 4 UNI GX -0.364
40. 3 UNI GX -0.364
41. ***** WIND LOAD Z-DIRECTION*****
42. LOAD 4 LOADTYPE NONE TITLE WLZ
43. MEMBER LOAD
44. 3 UNI GZ -0.346
45. ***** NOTIONAL LOAD X-DIRECTION*****
46. LOAD 5 LOADTYPE NONE TITLE NLX
47. SELFWEIGHT X -0.015
48. MEMBER LOAD
49. 4 CON GX -0.294 0.35
50. *****NOTIONAL LOAD Z-DIRECTION*****
51. LOAD 6 LOADTYPE NONE TITLE NLZ
52. SELFWEIGHT Z -0.015
53. MEMBER LOAD

```

```

54. 4 CON GZ -0.294 0.35
55. ***** LOAD COMBINATION - SERVICE *****
56. LOAD COMB 7 1.0DL+1.0FL
57. 1 1.0 2 1.0
58. LOAD COMB 8 1.0DL+1.0FL+1.0WLX
59. 1 1.0 2 1.0 3 1.0
60. LOAD COMB 9 1.0DL+1.0FL+1.0WLX
61. 1 1.0 2 1.0 4 1.0
62. LOAD COMB 10 1.0DL+1.0FL+1.0NLX
63. 1 1.0 2 1.0 5 1.0
64. LOAD COMB 11 1.0DL+1.0FL+1.0NLZ
65. 1 1.0 2 1.0 6 1.0
66. ***** LOAD COMBINATION - ULTIMATE *****
67. LOAD COMB 12 1.0DL+1.4FL
68. 1 1.0 2 1.4
69. LOAD COMB 13 1.4DL+1.4FL
70. 1 1.4 2 1.4
71. LOAD COMB 14 1.0DL+1.4FL+1.4WLX
72. 1 1.0 2 1.4 3 1.4
73. LOAD COMB 15 1.0DL+1.4FL+1.4WLZ
74. 1 1.0 2 1.4 4 1.4
75. LOAD COMB 16 1.0DL+1.4FL+1.4NLX
76. 1 1.0 2 1.4 5 1.4
77. LOAD COMB 17 1.0DL+1.4FL+1.4NLZ
78. 1 1.0 2 1.4 6 1.4
79. PERFORM ANALYSIS

```

PROBLEM STATISTICS

NUMBER OF JOINTS/MEMBER+ELEMENTS/SUPPORTS = 3/ 2/ 1

SOLVER USED IS THE IN-CORE ADVANCED SOLVER

TOTAL PRIMARY LOAD CASES = 6, TOTAL DEGREES OF FREEDOM = 12

80. LOAD LIST 7 TO 11
81. PRINT JOINT DISPLACEMENTS ALL

JOINT DISPLACEMENT (CM RADIANS) STRUCTURE TYPE = SPACE

JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
2	7	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	8	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	9	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	10	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	11	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
4	7	-0.1050	-0.0012	0.0189	0.0001	-0.0072	0.0004
	8	-0.1181	-0.0012	0.0189	0.0001	-0.0076	0.0005
	9	-0.1050	-0.0012	0.0159	0.0001	-0.0072	0.0004
	10	-0.1117	-0.0012	0.0189	0.0001	-0.0076	0.0005
	11	-0.1050	-0.0012	0.0165	0.0001	-0.0072	0.0004
5	7	-0.6127	-0.0102	0.0189	0.0001	-0.0073	0.0004
	8	-0.6478	-0.0102	0.0189	0.0001	-0.0076	0.0005
	9	-0.6127	-0.0095	0.0159	0.0001	-0.0073	0.0004
	10	-0.6473	-0.0102	0.0189	0.0001	-0.0076	0.0005
	11	-0.6127	-0.0096	0.0165	0.0001	-0.0073	0.0004

***** END OF LATEST ANALYSIS RESULT *****

Friday, January 18, 2013, 04:44 PM

82. PRINT SUPPORT REACTION ALL

SUPPORT REACTIONS -UNIT KN METE STRUCTURE TYPE = SPACE

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM Z
2	7	5.88	31.22	0.00	-7.54	2.06	-20.55
	8	7.41	31.22	0.00	-7.54	2.15	-23.66
	9	5.88	31.22	1.21	-5.43	2.06	-20.55
	10	6.35	31.22	0.00	-7.54	2.17	-21.93
	11	5.88	31.22	0.47	-6.16	2.06	-20.55

***** END OF LATEST ANALYSIS RESULT *****

83. LOAD LIST 12 TO 17

84. PRINT MEMBER FORCES ALL

MEMBER END FORCES STRUCTURE TYPE = SPACE

ALL UNITS ARE -- KN METE (LOCAL)

MEMBER	LOAD	JT	AXIAL	SHEAR-Y	SHEAR-Z	TORSION	MOM-Y	MOM-Z
3	12	2	31.22	0.00	8.23	2.88	-28.77	-7.54
	4		-21.54	0.00	-8.23	-2.88	0.00	7.54
13	2		43.71	0.00	8.23	2.88	-28.77	-10.55
	4		-30.16	0.00	-8.23	-2.88	0.00	10.55
14	2		31.22	0.00	10.37	3.01	-33.13	-7.54
	4		-21.54	0.00	-8.59	-3.01	0.00	7.54
15	2		31.22	1.69	8.23	2.88	-28.77	-4.58
	4		-21.54	0.00	-8.23	-2.88	0.00	7.54
16	2		31.22	0.00	8.89	3.04	-30.71	-7.54
	4		-21.54	0.00	-8.68	-3.04	0.00	7.54
17	2		31.22	0.66	8.23	2.88	-28.77	-5.60
	4		-21.54	-0.45	-8.23	-2.88	0.00	7.54
4	12	4	0.00	21.54	-8.23	0.00	2.88	7.54
	5		0.00	0.00	0.00	0.00	0.00	0.00
13	4		0.00	30.16	-8.23	0.00	2.88	10.55
	5		0.00	0.00	0.00	0.00	0.00	0.00
14	4		0.00	21.54	-8.59	0.00	3.01	7.54
	5		0.00	0.00	0.00	0.00	0.00	0.00
15	4		0.00	21.54	-8.23	0.00	2.88	7.54
	5		0.00	0.00	0.00	0.00	0.00	0.00
16	4		0.00	21.54	-8.68	0.00	3.04	7.54
	5		0.00	0.00	0.00	0.00	0.00	0.00
17	4		0.45	21.54	-8.23	0.00	2.88	7.54
	5		0.00	0.00	0.00	0.00	0.00	0.00

***** END OF LATEST ANALYSIS RESULT *****

85. LOAD LIST ALL

86. PARAMETER 1

87. CODE BS5950

88. BEAM 2 ALL

89. CHECK CODE ALL

STAAD.Pro CODE CHECKING - (BSI)

PROGRAM CODE REVISION V2.12_5950-1_2000

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
3 ST	H428X407X20	PASS	ANNEX I.1	0.048	14
		31.22 C	33.13	7.54	-
4 ST	H428X407X20	PASS	BS-4.2.3-(Y)	0.022	13
		0.00	2.88	10.55	0.00

***** END OF TABULATED RESULT OF DESIGN *****

90. FINISH

***** END OF THE STAAD.Pro RUN *****

**** DATE= JAN 18,2013 TIME= 16:44:19 ****

* For questions on STAAD.Pro, please contact *

* Research Engineers Offices at the following locations *

* *

	Telephone	Email
* USA:	+1 (714)974-2500	support@bentley.com
* CANADA	+1 (905)632-4771	detch@odandetech.com
* UK	+44(1454)207-000	support@bentley.com
* NORWAY	+47 67 57 21 30	staad@edr.no
* SINGAPORE	+65 6225-6158	support@bentley.com
* INDIA	+91(033)4006-2021	support@bentley.com
* JAPAN	+81(03)5952-6500	eng-eye@crc.co.jp
* CHINA	+86(411)8479-1166	support@bentley.com
* THAILAND	+66(0)2645-1018/19	support@bentley.com
* *		
* North America		support@bentley.com
* Europe		support@bentley.com
* Asia		support@bentley.com

Friday, January 18, 2013, 04:44 PM