

```

*****
*
*      STAND.Pro      Build 02
*      Version 2007
*      Proprietary Program of
*      Research Engineers, Intl.
*      Date= JUL 17, 2009
*      Time= 19:45:34
*
*      USER ID: Longrove Associates
*****

```

1. STAND PLANE DXF IMPORT OF ROOF TRANSFER_2F7.5K.DXF

INPUT FILE: 2F6K_ROOF_TRANSFER.STD

2. START JOB INFORMATION

3. JOB NAME 2F6K - ROOF TRANSFER

4. JOB CLIENT AGL

5. ENGINEER NAME RC2

6. APPROVED NAME LCK

7. ENGINEER DATE 15-JUN-09

8. END JOB INFORMATION

9. INPUT WIDTH 79

10. UNIT MMS KN

11. JOINT COORDINATES

12. 1 356.999 265.965 0; 2 7637 265.965 0; 4 3997 265.965 0

13. MEMBER INCIDENCES

14. 1 1 4; 3 4 2

15. DEFINE MATERIAL START

16. ISOTROPIC STEEL

17. E 205

18. POISSON 0.3

19. DENSITY 7.8195E-008

20. ALPHA 6.5E-006

21. DAMP 0.03

22. END DEFINE MATERIAL

23. CONSTANTS

24. MATERIAL STEEL ALL

25. START USER TABLE

26. TABLE 1

27. UNIT MMS KN

28. GENERAL

29. C28X38

30. 252 38 2.3 38 2.3 38072 62913 100000 1557 3311 87 175 1557 3311 100000 38

31. TABLE 2

32. UNIT MMS KN

33. GENERAL

34. 2C75X45

35. 1098 75 6 90 3 938192 638334 100000 26218 14185 450 270 26218 14185 100000 75

36. TABLE 3

37. UNIT MMS KN

38. GENERAL

39. C100X50

40. 653 50 3 100 3 229000 990000 1E+006 7270 19800 300 343 11600 23600 1E+006 48

DXF IMPORT OF ROOF TRANSFER_2F7.5K.DXF

```

41. TABLE 4
42. UNIT MMS KN
43. GENERAL
44. C75X45
45. 518 45 3 75 3 138000 449000 100000 4940 12000 270 315 4940 12000 100000 40
46. TABLE 5
47. UNIT MMS KN
48. TUBE
49. SHS100X3-CF
50. 1140 100 100 3 1.77E+006 1.77E+006 2.79E+006 600 400
51. TABLE 6
52. UNIT MMS KN
53. TUBE
54. SHS100X4-CF
55. 1490 100 100 4 2.26E+006 2.26E+006 3.62E+006 800 533
56. TABLE 7
57. UNIT MMS KN
58. TUBE
59. SHS100X6-CF
60. 2160 100 100 6 3.11E+006 3.11E+006 5.14E+006 1200 800
61. TABLE 8
62. UNIT MMS KN
63. TUBE
64. SHS150X4-SCF
65. 2570 150 150 4 5 8.96E+006 8.96E+006 1.41E+007 1350 900
66. TABLE 9
67. UNIT MMS KN
68. TUBE
69. SHS75X3-CF
70. 841 75 75 3 716000 716000 1.15E+006 450 300
71. TABLE 10
72. UNIT MMS KN
73. TUBE
74. SHS50X3-CF
75. 541 50 50 3 195000 195000 321000 300 200
76. TABLE 11
77. UNIT MMS KN
78. TUBE
79. SHS38X3-CF
80. 397 38 38 3 78500 78500 133000 228 152
81. TABLE 12
82. UNIT MMS KN
83. GENERAL
84. 2C300X98X3.0
85. 3258 300 6 196 3 4.416E+007 6.5986E+006 100000 294408 68736 2136 1800 -
86. 9.29441E+006 58736 100000 300
87. TABLE 13
88. UNIT MMS KN
89. TUBE
90. SHS125X4.5-CF
91. 2120 125 125 4.5 5.06E+006 5.06E+006 8.04E+006 1125 750
92. TABLE 14
93. UNIT MMS KN
94. TUBE
95. RSH150X100X4.5-CF
96. 2120 150 110 4.5 6.58E+006 3.52E+006 7.36E+006 900 900

```

97. TABLE 15
 98. UNIT MMS KN
 99. TUBE
 100. RSH200X100X4.5
 101. 2570 200 100 4.5 1.331E+007 4.55E+006 1.097E+007 1800 900
 102. TABLE 16
 103. UNIT MMS KN
 104. TUBE
 105. RSH200X100X6.3
 106. 3480 200 100 6.3 1.739E+007 5.91E+006 1.483E+007 3520 1360
 107. TABLE 17
 108. UNIT MMS KN
 109. TUBE
 110. RSH250X150X5
 111. 4560 250 150 5 3.886E+007 1.768E+007 3.81816E+007 3000 1800
 112. END
 113. MEMBER PROPERTY AMERICAN
 114. 1 3 UPTABLE 17 RSH250X150X6
 115. SUPPORTS
 116. 1 PINNED
 117. 2 FIXED BUT FX MX MY MZ
 118. UNIT METER KN
 119. LOAD 1 LOADTYPE DEAD TITLE S/W
 120. SELFWEIGHT Y -1
 121. LOAD 2 LOADTYPE DEAD REDUCIBLE TITLE DL
 122. JOINT LOAD
 123. 4 FY -11.3
 124. LOAD 3 LOADTYPE LIVE REDUCIBLE TITLE LL
 125. JOINT LOAD
 126. 4 FY -14.4
 127. LOAD 4 LOADTYPE WIND TITLE WL
 128. JOINT LOAD
 129. 4 FY 5.1
 130. LOAD COMB 5 1.4DL + 1.6LL
 131. 1 1.4
 132. LOAD COMB 6 1.0DL + 1.4WL
 133. 1 1.0
 134. LOAD COMB 7 SERVICE
 135. 1 1.0
 136. PERFORM ANALYSIS

PROBLEM STATISTICS

NUMBER OF JOINTS/MEMBERS/ELEMENTS/SUPPORTS = 3/ 2/ 2

SOLVER USED IS THE OUT-OF-CORE BASIC SOLVER

ORIGINAL/FINAL BAND-WIDTH= 2/ 2/ 6 DOF
 TOTAL PRIMARY LOAD CASES = 4, TOTAL DEGREES OF FREEDOM = 6
 SIZE OF STIFFNESS MATRIX = 1 DOUBLE Kilo-WORDS
 REQD/AVAIL. DISK SPACE = 12.0/ 32684.6 MB

137. PARAMETER 1
 138. CODE BSS950
 139. CHECK CODE ALL

STAAD.PRO CODE CHECKING = (BSI)

PROGRAM CODE REVISION V2.10_5950-1_2000

DXF IMPORT OF ROOF TRANSFER_2F7.5K.DXF

ALL UNITS ARE - KN METER (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ RZ	LOADING/ LOCATION
1 ST	RHS250X150X6 PASS	0.00	BS-4.2.3-(Y)	0.015	3
			0.00	0.00	0.00
3 ST	RHS250X150X6 PASS	0.00	BS-4.2.3-(Y)	0.015	3
			0.00	-26.21	0.00

***** END OF TABULATED RESULT OF DESIGN *****

140. PRINT SUPPORT REACTION ALL

DXF IMPORT OF ROOF TRANSFER_2F7.5K.DXF

SUPPORT REACTIONS -UNIT KN METER STRUCTURE TYPE = PLANE

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOY-X	MOY-Y	MOY-Z
1	1	0.00	1.28	0.00	0.00	0.00	0.00
	2	0.00	5.65	0.00	0.00	0.00	0.00
	3	0.00	7.20	0.00	0.00	0.00	0.00
	4	0.00	-2.55	0.00	0.00	0.00	0.00
	5	0.00	1.79	0.00	0.00	0.00	0.00
	6	0.00	1.28	0.00	0.00	0.00	0.00
	7	0.00	1.28	0.00	0.00	0.00	0.00
2	1	0.00	1.28	0.00	0.00	0.00	0.00
	2	0.00	5.65	0.00	0.00	0.00	0.00
	3	0.00	7.20	0.00	0.00	0.00	0.00
	4	0.00	-2.55	0.00	0.00	0.00	0.00
	5	0.00	1.79	0.00	0.00	0.00	0.00
	6	0.00	1.28	0.00	0.00	0.00	0.00
	7	0.00	1.28	0.00	0.00	0.00	0.00

***** END OF LATEST ANALYSIS RESULT *****

141. LOAD LIST 7

142. PRINT JOINT DISPLACEMENTS ALL