

```

*****
*
*          STAAD.Pro
*          Version 2005      Bld 1002.US
*          Proprietary Program of
*          Research Engineers, Intl.
*          Date=      JUL 19, 2006
*          Time=      16:56: 3
*
*          USER ID: Meinhardt Singapore Pte Ltd
*****

```

```

1. STAAD PLANE      FRAME 1
INPUT FILE: RA BLD 10 FR1.STD
2. START JOB INFORMATION
3. JOB NAME - DUBAI METRO PROJECT
4. JOB CLIENT - GOVERNMENT OF DUBAI _ ROADS & TRANSPORT AUTHORITY
5. END JOB INFORMATION
6. INPUT WIDTH 79
7. UNIT METER KN
9. JOINT COORDINATES
10. 1 0 5.250
11. 2 1.5 5.250
12. 3 3 5.250
13. 4 5 5.250
14. 5 7 5.250
15. 6 8.5 5.250
16. 7 10 5.250
18. 101 0 0
19. 201 10 0
21. MEMBER INCIDENCES
22. 1 1 2
23. 2 2 3
24. 3 3 4
25. 4 4 5
26. 5 5 6
27. 6 6 7
29. 101 101 1
30. 201 201 7
32. MEMBER PROPERTY BRITISH
33. 1 6      TABLE ST UB406X178X60
34. 2 3 4 5      TABLE ST UB406X178X60
35. 101 201      TABLE ST UC305X305X97
37. DEFINE MATERIAL START
38. ISOTROPIC STEEL
39. E 2.05E+08
40. POISSON 0.3
41. DENSITY 76.8195
42. ALPHA 1.20E-05
43. DAMP 0.03
44. END DEFINE MATERIAL
45. CONSTANTS
46. MATERIAL      STEEL      ALL
    FRAME 1
    2

```

-- PAGE NO.

```

48. SUPPORTS
49. 101 201 PIN
51. LOAD 1 SELFWEIGHT
52. SELFWEIGHT Y -1
53. LOAD 2 SDL
54. JOINT LOAD
55. 2 3 5 6 FY -9.6
56. 1 7 FY -27.5
57. MEMBER LOAD
58. 1 CON GY -9.6 0.1

```

```

59. 3  CON GY -9.6 1.5
60. 4  CON GY -9.6 0.5
61. 6  CON GY -9.6 1.4
62. LOAD 3 LL
63. JOINT LOAD
64. 2 3 5 6  FY -7.2
65. 1 7  FY -3.4
66. MEMBER LOAD
67. 1  CON GY -7.2 0.1
68. 3  CON GY -7.2 1.5
69. 4  CON GY -7.2 0.5
70. 6  CON GY -7.2 1.4
71. LOAD 4 PH (NOTIONAL HORIZONTAL LOAD)
72. JOINT LOAD
73. 1  FX 1.6
74. LOAD 11 WL1 (INTERNAL SUCTION, WIND ANGLE 0)
75. MEMBER LOAD
76. 101  UNI Y -10.8
77. 201  UNI Y -2
78. 1 2 3  UNI Y 5.9
79. 4 5 6  UNI Y -3.4
80. LOAD 12 WL2 (INTERNAL PRESSURE, WIND ANGLE 0)
81. MEMBER LOAD
82. 101  UNI Y -5.9
83. 201  UNI Y -7
84. 1 2 3  UNI Y 10.9
85. 4 5 6  UNI Y 4.8
86. LOAD 13 WL3 (INTERNAL SUCTION, WIND ANGLE 90)
87. MEMBER LOAD
88. 101  UNI Y 5
89. 201  UNI Y -5
90. 1 2 3  UNI Y -5
91. 4 5 6  UNI Y -5
92. LOAD 14 WL4 (INTERNAL PRESSURE, WIND ANGLE 90)
93. MEMBER LOAD
94. 101  UNI Y 9.9
95. 201  UNI Y -9.9
96. 1 2 3  UNI Y 8.9
97. 4 5 6  UNI Y 8.9
98. LOAD 21 EQ (EARTHQUAKE LOAD)
99. MEMBER LOAD
100. 101  UNI Y 5.9
101. 201  UNI Y 5.9
103. LOAD COMB 1001  1.4DL + 1.6LL
104. 1 1.4  2 1.4  3 1.6
105. LOAD COMB 1002  1.4DL + 1.6LL + 1.0PH
    FRAME 1
    3

```

-- PAGE NO.

```

106. 1 1.4  2 1.4  3 1.6 4 1.0
107. LOAD COMB 1011  1.2DL + 1.2LL + 1.2WL1
108. 1 1.2  2 1.2  3 1.2 11 1.2
109. LOAD COMB 1111  1.4DL + 1.4WL1
110. 1 1.4  2 1.4  11 1.4
111. LOAD COMB 1211  1.0DL + 1.4WL1
112. 1 1.0  2 1.0  11 1.4
113. LOAD COMB 1012  1.2DL + 1.2LL + 1.2WL2
114. 1 1.2  2 1.2  3 1.2 12 1.2
115. LOAD COMB 1112  1.4DL + 1.4WL2
116. 1 1.4  2 1.4  12 1.4
117. LOAD COMB 1212  1.0DL + 1.4WL2
118. 1 1.0  2 1.0  12 1.4
119. LOAD COMB 1013  1.2DL + 1.2LL + 1.2WL3
120. 1 1.2  2 1.2  3 1.2 13 1.2
121. LOAD COMB 1113  1.4DL + 1.4WL3
122. 1 1.4  2 1.4  13 1.4
123. LOAD COMB 1213  1.0DL + 1.4WL3
124. 1 1.0  2 1.0  13 1.4
125. LOAD COMB 1014  1.2DL + 1.2LL + 1.2WL4
126. 1 1.2  2 1.2  3 1.2 14 1.2
127. LOAD COMB 1114  1.4DL + 1.4WL4
128. 1 1.4  2 1.4  14 1.4
129. LOAD COMB 1214  1.0DL + 1.4WL4

```

```

130. 1 1.0 2 1.0 14 1.4
131. LOAD COMB 1021 1.2DL + 0.5LL + 1.0EQ
132. 1 1.2 2 1.2 3 0.5 21 1.0
133. LOAD COMB 1121 1.2DL + 0.5LL - 1.0EQ
134. 1 1.2 2 1.2 3 0.5 21 -1.0
135. LOAD COMB 1221 0.9DL + 1.0EQ
136. 1 0.9 2 0.9 21 1.0
137. LOAD COMB 1321 0.9DL - 1.0EQ
138. 1 0.9 2 0.9 21 -1.0
140. LOAD COMB 2001 1.0DL + 1.0LL
141. 1 1.0 2 1.0 3 1.0
142. LOAD COMB 2002 1.0DL + 0.5LL
143. 1 1.0 2 1.0 3 0.5
144. LOAD COMB 2011 DL + LL + WL1
145. 1 1.0 2 1.0 3 1.0 11 1.0
146. LOAD COMB 2012 DL + LL + WL2
147. 1 1.0 2 1.0 3 1.0 12 1.0
148. LOAD COMB 2013 DL + LL + WL3
149. 1 1.0 2 1.0 3 1.0 13 1.0
150. LOAD COMB 2014 DL + LL + WL4
151. 1 1.0 2 1.0 3 1.0 14 1.0
153. PERFORM ANALYSIS
    FRAME 1
    4

```

-- PAGE NO.

P R O B L E M S T A T I S T I C S

```

-----
NUMBER OF JOINTS/MEMBER+ELEMENTS/SUPPORTS =      9/      8/      2
ORIGINAL/FINAL BAND-WIDTH=      7/      1/      6 DOF
TOTAL PRIMARY LOAD CASES =      9, TOTAL DEGREES OF FREEDOM =      23
SIZE OF STIFFNESS MATRIX =      1 DOUBLE KILO-WORDS
REQRD/AVAIL. DISK SPACE =      12.0/ 10563.1 MB

```

```

154. LOAD LIST 1001 1002 -
155. 1011 1111 1211 -
156. 1012 1112 1212 -
157. 1013 1113 1213 -
158. 1014 1114 1214 -
159. 1021 1121 1221 1321
160. *PRINT MEMBER FORCES
161. SECTION 0.25 0.5 0.75
162. *PRINT MEMBER SECTION FORCES
163. PARAMETER
164. CODE BS5950
165. TRACK 2 ALL
166. *UNL 3 MEM 101 201
167. LZ 14 MEM 101 201
168. LY 3 MEM 101 201
169. *MX 0.6 MEM 101 201
171. UNL 3 MEM 1 2 5 6
172. LZ 34 MEM 1 TO 6
173. LY 1.5 MEM 1 TO 6
174. CHECK CODE ALL
STEEL DESIGN

```

STAAD.Pro CODE CHECKING - (BSI)

PROGRAM CODE REVISION V2.9_5950-1_2000

FRAME 1
 5

-- PAGE NO.