

□

```
*****
*
*          STAAD.Pro
*          Version 2006    Bld 1002.US
*          Proprietary Program of
*          Research Engineers, Intl.
*          Date= DEC 25, 2007
*          Time= 15:43:34
*
*          USER ID: roarck
*
*****
```

□

1. STAAD SPACE BLDG -27(HEAT EXCHANGE FACILITY)

INPUT FILE: BLDG-27 STEEL Structure.STD

2. START JOB INFORMATION

3. ENGINEER DATE 29-OCT-07

4. END JOB INFORMATION

5. INPUT WIDTH 79

6. *****

7. UNIT METER KN

8. JOINT COORDINATES

```
9. 1 0 0 0; 2 0 5.312 0.662; 3 0 6.317 0.503; 4 0 7.056 -0.14; 5 0 7.253 -1.111
10. 6 0 7.317 -5.809; 7 0 7.347 -8.999; 8 0 7.306 -12.459; 9 0 7.253 -16.887
11. 10 0 7.056 -17.856; 11 0 6.317 -18.5; 12 0 5.312 -18.659; 13 0 0 -17.997
12. 14 6.5 0 0; 15 6.5 5.312 0.662; 16 6.5 6.317 0.503; 17 6.5 7.056 -0.14
13. 18 6.5 7.253 -1.111; 19 6.5 7.317 -5.809; 20 6.5 7.347 -8.999
14. 21 6.5 7.306 -12.459; 22 6.5 7.253 -16.887; 23 6.5 7.056 -17.856
15. 24 6.5 6.317 -18.5; 25 6.5 5.312 -18.659; 26 6.5 0 -17.997; 27 12.5 0 0
16. 28 12.5 5.312 0.662; 29 12.5 6.317 0.503; 30 12.5 7.056 -0.14
17. 31 12.5 7.253 -1.111; 32 12.5 7.317 -5.809; 33 12.5 7.347 -8.999
18. 34 12.5 7.306 -12.459; 35 12.5 7.253 -16.887; 36 12.5 7.056 -17.856
19. 37 12.5 6.317 -18.5; 38 12.5 5.312 -18.659; 39 12.5 0 -17.997; 40 19 0 0
20. 41 19 5.312 0.662; 42 19 6.317 0.503; 43 19 7.056 -0.14; 44 19 7.253 -1.111
21. 45 19 7.317 -5.809; 46 19 7.347 -8.999; 47 19 7.306 -12.459
22. 48 19 7.253 -16.887; 49 19 7.056 -17.856; 50 19 6.317 -18.5
23. 51 19 5.312 -18.659; 52 19 0 -17.997; 53 20.5 7.056 -0.14
24. 54 20.5 7.056 -17.856; 55 -1.5 7.056 -0.14; 56 -1.5 7.056 -17.856
25. 57 22 7.317 -5.809; 58 22 7.306 -12.459; 59 -3 7.317 -5.809
26. 60 -3 7.306 -12.459; 61 22.2 7.347 -8.999; 62 -3.2 7.347 -8.999
27. 63 0 7.27428 -15.1088; 64 6.5 7.27428 -15.1088; 65 12.5 7.27428 -15.1088
28. 66 19 7.27428 -15.1088; 67 0 7.28269 -3.2908; 68 6.5 7.28269 -3.2908
29. 69 12.5 7.28269 -3.2908; 70 19 7.28269 -3.2908; 71 20.8 7.27428 -15.1088
30. 72 -1.8 7.27428 -15.1088; 73 20.8 7.28269 -3.2908; 74 -1.8 7.28269 -3.2908
31. 75 0 2.67927 0.333901; 76 6.5 2.67927 0.333901; 77 12.5 2.67927 0.333901
32. 78 19 2.67927 0.333901; 79 20.3 2.67927 0.333901; 80 -1.3 2.67927 0.333901
33. 81 0 2.67927 -18.3309; 82 6.5 2.67927 -18.3309; 83 12.5 2.67927 -18.3309
34. 84 19 2.67927 -18.3309; 85 20.3 2.67927 -18.3309; 86 -1.3 2.67927 -18.3309
35. 87 20.3 5.312 0.662; 88 20.3 5.312 -18.659; 89 -1.3 5.312 0.662
36. 90 -1.3 5.312 -18.659; 91 9.7 7.28269 -3.2908; 93 9.5 7.347 -8.999
37. 95 7.34728 -15.1088; 96 0 6.817 -5.809; 97 0 6.806 -12.459
38. 98 6.5 6.817 -5.809; 99 6.5 6.806 -12.459; 100 12.5 6.817 -5.809
39. 101 12.5 6.806 -12.459; 102 19 6.817 -5.809; 103 19 6.806 -12.459
40. 104 0 6.856 -0.14; 105 0 6.856 -17.856; 106 6.5 6.856 -0.14
```

BLDG -27(HEAT EXCHANGE FACILITY)

```
41. 107 6.5 6.856 -17.856; 108 12.5 6.856 -0.14; 109 12.5 6.856 -17.856
42. 110 19 6.856 -0.14; 111 19 6.856 -17.856; 112 0 6.556 -0.14
43. 113 0 6.556 -17.856; 114 6.5 6.556 -0.14; 115 6.5 6.556 -17.856
44. 116 12.5 6.556 -0.14; 117 12.5 6.556 -17.856; 118 19 6.556 -0.14
45. 119 19 6.556 -17.856; 128 0 6.556 -18.2917; 129 6.5 6.556 -18.2917
46. 130 12.5 6.556 -18.2917; 131 19 6.556 -18.2917; 132 0 6.556 0.295047
47. 133 6.5 6.556 0.295047; 134 12.5 6.556 0.295047; 135 19 6.556 0.295047
48. *****
49. MEMBER INCIDENCES
50. 1 1 75; 2 2 3; 3 3 132; 4 4 5; 5 5 67; 6 6 7; 7 7 8; 8 8 63; 9 10 9; 10 11 128
51. 11 12 11; 12 13 81; 13 14 76; 14 15 16; 15 16 133; 16 17 18; 17 18 68
52. 18 19 20; 19 20 21; 20 21 64; 21 23 22; 22 24 129; 23 25 24; 24 26 82
53. 25 27 77; 26 28 29; 27 29 134; 28 30 31; 29 31 69; 30 32 33; 31 33 34
54. 32 34 65; 33 36 35; 34 37 130; 35 38 37; 36 39 83; 37 40 78; 38 41 42
55. 39 42 135; 40 43 44; 41 44 70; 42 45 46; 43 46 47; 44 47 66; 45 49 48
56. 46 50 131; 47 51 50; 48 52 84; 52 63 9; 53 64 22; 54 65 35; 55 66 48; 56 67 6
57. 57 68 19; 58 69 32; 59 70 45; 95 75 2; 96 76 15; 97 77 28; 98 78 41; 99 81 12
58. 100 82 25; 101 83 38; 102 84 51; 201 53 43; 202 43 30; 203 30 17; 204 17 4
59. 205 4 55; 206 73 70; 207 70 69; 208 69 91; 209 68 67; 210 67 74; 211 57 45
60. 212 45 32; 213 32 19; 214 19 6; 215 6 59; 216 61 46; 217 46 33; 218 33 93
61. 220 7 62; 221 58 47; 222 47 34; 223 34 21; 224 21 8; 225 8 60; 226 71 66
62. 227 66 65; 228 65 95; 229 64 63; 230 63 72; 231 54 49; 232 49 36; 233 36 23
63. 234 23 10; 235 10 56; 236 91 68; 238 93 20; 240 95 64; 241 20 7; 301 79 78
64. 302 78 77; 303 77 76; 304 76 75; 305 75 80; 306 85 84; 307 84 83; 308 83 82
65. 309 82 81; 310 81 86; 311 87 41; 312 41 28; 313 28 15; 314 15 2; 315 2 89
66. 316 88 51; 317 51 38; 318 38 25; 319 25 12; 320 12 90; 501 55 67; 502 4 74
67. 503 57; 504 6 62; 505 62 8; 506 7 60; 507 72 10; 508 63 56; 509 43 73
68. 510 53 70; 511 45 61; 512 57 46; 513 46 58; 514 61 47; 515 71 49; 516 54 66
69. 522 17 91; 523 91 32; 524 30 91; 525 91 19; 530 19 93; 531 93 34; 532 32 93
70. 533 93 21; 538 34 95; 539 95 23; 540 36 95; 541 95 21; 542 97 8; 543 96 6
71. 544 99 21; 545 98 19; 546 101 34; 547 100 32; 548 103 47; 549 102 45
72. 550 105 10; 551 107 23; 552 109 36; 553 111 49; 554 104 4; 555 106 17
73. 556 108 30; 557 110 43; 558 113 128; 559 115 129; 560 117 130; 561 119 131
74. 562 128 10; 564 129 23; 566 130 36; 567 131 49; 568 118 135; 569 116 134
75. 570 114 133; 571 112 132; 572 132 4; 573 133 17; 574 134 30; 575 135 43
76. START GROUP DEFINITION
77. MEMBER
78. _COLUMN 1 TO 3 10 TO 15 22 TO 27 34 TO 39 46 TO 48 95 TO 102 562 564 566 567 -
79. 572 TO 575
80. _RAFTER 4 TO 9 16 TO 21 28 TO 33 40 TO 45 52 TO 59
81. _SEC_BEAM_ROOF 201 TO 218 220 TO 236 238 240 241
82. _SIDE_BEAM 301 TO 320
83. _BRACING 501 TO 516 522 TO 525 530 TO 533 538 TO 541
84. _STUBCOLUMN 542 TO 561 568 TO 571
85. END GROUP DEFINITION
86. *****
87. DEFINE MATERIAL START
88. ISOTROPIC STEEL
89. E 2.05E+008
90. POISSON 0.3
91. DENSITY 78
92. ALPHA 1 2E-005
93. DAMP 0.03
94. END DEFINE MATERIAL
95. MEMBER PROPERTY BRITISH
96. *****MAIN COLUMN*****
```

BLDG -27(HEAT EXCHANGE FACILITY) --- PAGE NO. 3

97. 1 12 13 24 25 36 37 48 TAPERED 0.3 0.006 0.35 0.2 0.01 0.2 0.01
98. 95 TO 102 TAPERED 0.35 0.006 0.4 0.2 0.01 0.2 0.01
99. 2 3 10 11 14 15 22 23 26 27 34 35 38 39 46 47 562 564 566 567 572 TO 574 -
100. 575 TAPERED 0.4 0.006 0.4 0.2 0.01 0.2 0.01
101. *****MAIN RAFTER *****
102. 4 TO 9 16 TO 21 28 TO 33 40 TO 45 52 TO 58 -
103. 59 TAPERED 0.4 0.006 0.4 0.2 0.01 0.2 0.01
104. *****SSC BEAM *****
105. 201 TO 218 220 TO 236 238 240 241 TAPERED 0.3 0.006 0.3 0.15 0.01 0.15 0.01
106. *****SIDE BEAM *****
107. 301 TO 320 TAPERED 0.25 0.006 0.25 0.25 0.012 0.25 0.012
108. *****STUB COLUMN *****
109. 542 TO 549 TAPERED 0.3 0.006 0.3 0.2 0.008 0.2 0.008
110. 550 TO 561 568 TO 571 TAPERED 0.3 0.006 0.3 0.2 0.008 0.2 0.008
111. *550 TO 561 568 TO 571 PRIS YD 0.4 2D 0.01
112. *****BRACING *****
113. 501 TO 516 522 TO 525 530 TO 533 538 TO 541 TABLE ST UA70X70X6
114. *****
115. CONSTANTS
116. BETA 90 MEMB 301 TO 320 542 TO 557
117. MATERIAL STEEL ALL
118. *****
119. SUPPORTS
120. 1 13 14 26 27 39 40 52 PINNED
121. 96 TO 119 PINNED
122. *4 6 8 10 17 19 21 23 30 32 34 36 43 45 47 49 PINNED
123. *4 6 8 10 17 19 21 23 30 32 34 36 43 45 47 49 128 TO 134 PINNED
124. *****
125. MEMBER RELEASE
126. 203 204 208 209 213 214 218 223 224 228 229 233 234 241 303 304 308 309 313 -
127. 314 318 319 START MZ
128. 202 203 207 212 213 217 222 223 227 232 233 236 238 240 302 303 307 308 312 -
129. 313 317 318 END MZ
130. MEMBER TRUSS
131. 501 TO 516 522 TO 525 530 TO 533 538 TO 541
132. DEFINE UBC LOAD
133. ZONE 0.15 I 1 RWX 4.5 RWZ 4.5 STYP 4 CT 0.0853 PX 0.381 PZ 0.381 NA 1 NV 1
134. JOINT WEIGHT
135. 4 WEIGHT 39.57
136. 6 WEIGHT 50.32
137. 8 WEIGHT 45.126
138. 10 WEIGHT 41.672
139. 17 WEIGHT 54.606
140. 19 WEIGHT 49.012
141. 21 WEIGHT 43.508
142. 23 WEIGHT 57.012
143. 30 WEIGHT 54.606
144. 32 WEIGHT 49.012
145. 34 WEIGHT 43.508
146. 36 WEIGHT 57.29
147. 43 WEIGHT 39.57
148. 45 WEIGHT 50.32
149. 47 WEIGHT 45.126
150. 49 WEIGHT 41.537
151. LOAD 21 EQX (EARTHQUAKE LOAD)
152. UBC LOAD X

BLDG -27(HEAT EXCHANGE FACILITY)

153. LOAD 22 EQZ (EARTHQUAKE LOAD)
154. UBC LOAD Z
155. LOAD 1 SELFWEIGHT
156. SELFWEIGHT Y -1
157. LOAD 2 DL
158. **DEAD LOAD = 0.8 KN/M^2
159. **BEAM SPACING = 3.3 M , 3.0 M & 2.7 M
160. **DL1 = 3.3X0.8 =2.66=2.7 KN/M
161. **DL2 = 3.0X0.8 =2.4 KN/M
162. **DL3 = 2.7X0.8 =2.16=2.2 KN/M
163. MEMBER LOAD
164. 216 TO 218 220 238 241 301 TO 310 UNI GY -2.7
165. 211 TO 215 221 TO 225 UNI GY -2.4
166. 206 TO 210 226 TO 230 236 240 UNI GY -2.2
167. 201 TO 205 231 TO 235 311 TO 320 UNI GY -2.2
168. *****
169. LOAD 3 LL
170. MEMBER LOAD
171. **LIVE LOAD = 0.6 KN/M^2
172. **BEAM SPACING = 3.3 M , 3.0 M & 2.7 M
173. **LL1 = 3.3X0.6 =1.98=2.0 KN/M
174. **LL2 = 3.0X0.6 =1.8 KN/M
175. **LL3 = 2.7X0.6 =1.62=1.65 KN/M
176. 216 TO 218 220 238 241 UNI GY -2
177. 211 TO 215 221 TO 225 UNI GY -1.8
178. 201 TO 210 226 TO 236 240 UNI GY -1.65
179. *****A/C EQUIPMENT S/W = 5 KN (POINT LOAD)
180. *JOINT LOAD
181. *20 33 FY -5
182. LOAD 4 PH(X-DIR)
183. *****
184. **PH =1.5% (1.4DL+1.6LL)
185. JOINT LOAD
186. 4 FX 0.88
187. 6 FX 1.47
188. 8 FX 1.4
189. 10 FX 0.9
190. 17 FX 1.33
191. 19 FX 1.43
192. 21 FX 1.35
193. 23 FX 1.37
194. 30 FX 1.33
195. 32 FX 1.43
196. 34 FX 1.35
197. 36 FX 1.37
198. 43 FX 0.88
199. 45 FX 1.47
200. 47 FX 1.4
201. 49 FX 0.91
202. LOAD 5 PH(Z-DIR)

259. *****
 260. **WL4(LIEWARD WALL)= 1.24(-0.5-0.2)X2.5 =2.17 KN/M
 261. **WL5(WINDWARD ROOF)= 1.24(-0.78-0.2)X3.0 =3.65(UP) KN/M
 262. **WL6(WINDWARD ROOF)= 1.24(-0.78-0.2)X2.66 =3.24(UP) KN/M
 263. **WL7(LIEWARD ROOF)= 1.24(-0.2-0.2)X3.0 =1.65(UP) KN/M
 264. **WL8(LIEWARD ROOF)= 1.24(-0.2-0.2)X2.66 =1.49(UP) KN/M
 265. MEMBER LOAD
 266. 306 TO 310 UNI GZ 2.83
 267. 301 TO 305 UNI GZ 3.48
 268. 316 TO 320 UNI GZ 1.77
 269. 221 TO 225 UNI Y 3.65
 270. 211 TO 215 UNI Y 1.49
 271. 226 TO 235 240 UNI Y 3.24
 272. 201 TO 210 236 UNI Y 1.32
 273. 216 TO 218 220 238 241 UNI Y 2.83
 274. *****
 275. LOAD 13 WL3 (90 DEG , INTERNAL SUCTION CPI=-0.3, WW&LW CPE=+0.2)
 276. **WIND LOAD(Q) = 1.24 KN/M^2
 277. **CPE(WINDWARD ROOF)=-0.2,CPE(LIEWARD ROOF=0.2)
 278. **CPE(WINDWARD WALL)=-0.8,CPE(LIEWARD WALL=-0.8)
 279. **BEAM SPACING (ROOF) = 3.3 M , 3.0 M & 2.7 M
 280. **BEAM SPACING (WALL) = 4.0M , 2.5 M
 281. **WIND LOAD = QX(CPE-CPI)XBEAM SPACING
 282. **WL1(WINDWARD WALL)= 1.24(-0.8+0.3)X4.0 =2.48 KN/M
 283. **WL2(WINDWARD WALL)= 1.24(-0.8+0.3)X2.5 =1.55 KN/M
 284. **WL3(LIEWARD WALL)= 1.24(-0.8+0.3)X4.0 =2.48 KN/M
 285. **WL4(LIEWARD WALL)= 1.24(-0.8+0.3)X2.5 =1.55 KN/M
 286. **WL5(WINDWARD ROOF)= 1.24(0.2+0.3)X3.0 =1.86(DN) KN/M
 287. **WL6(WINDWARD ROOF)= 1.24(0.2+0.3)X2.66 =1.65(DN) KN/M
 288. **WL7(LIEWARD ROOF)= 1.24(0.2+0.3)X3.0 =1.86(DN) KN/M
 289. **WL8(LIEWARD ROOF)= 1.24(0.2+0.3)X2.66 =1.65(DN) KN/M
 290. MEMBER LOAD
 291. 306 TO 310 UNI GZ -2.48
 292. 301 TO 305 UNI GZ 2.48
 293. 316 TO 320 UNI GZ -1.55
 294. 311 TO 315 UNI GZ 1.55
 295. 221 TO 225 UNI Y -1.86
 296. 211 TO 215 UNI Y -1.86
 297. 226 TO 235 240 UNI Y -1.65
 298. 201 TO 210 236 UNI Y -1.65
 299. 216 TO 218 220 238 241 UNI Y -2.05
 300. *****
 301. LOAD 14 WL4 (90 DEG , INTERNAL PRESSURE CPI=+0.2, WW&LW CPE=-0.7)
 302. **WIND LOAD(Q) = 1.24 KN/M^2
 303. **CPE(WINDWARD ROOF)=-0.7,CPE(LIEWARD ROOF=-0.7)
 304. **CPE(WINDWARD WALL)=-0.8,CPE(LIEWARD WALL=-0.8)
 305. **BEAM SPACING (ROOF) = 3.3 M , 3.0 M & 2.7 M
 306. **BEAM SPACING (WALL) = 4.0M , 2.5 M
 307. **WIND LOAD = QX(CPE-CPI)XBEAM SPACING
 308. **WL1(WINDWARD WALL)= 1.24(-0.8-0.2)X4.0 =4.97 KN/M
 309. **WL2(WINDWARD WALL)= 1.24(-0.8-0.2)X2.5 =3.1 KN/M
 310. **WL3(LIEWARD WALL)= 1.24(-0.8-0.2)X4.0 =4.97 KN/M
 311. **WL4(LIEWARD WALL)= 1.24(-0.8-0.2)X2.5 =3.1 KN/M
 312. **WL5(WINDWARD ROOF)= 1.24(-0.7-0.2)X3.0 =3.35(UP) KN/M
 313. **WL6(WINDWARD ROOF)= 1.24(-0.7-0.2)X2.66 =2.97(UP) KN/M
 314. **WL7(LIEWARD ROOF)= 1.24(-0.7-0.2)X3.0 =3.35(UP) KN/M

203. *****
 204. **PH =1.5% (1.4DL+1.6LL)
 205. JOINT LOAD
 206. 4 FZ 0.88
 207. 6 FZ 1.47
 208. 8 FZ 1.4
 209. 10 FZ 0.9
 210. 17 FZ 1.33
 211. 19 FZ 1.43
 212. 21 FZ 1.35
 213. 23 FZ 1.37
 214. 30 FZ 1.33
 215. 32 FZ 1.43
 216. 34 FZ 1.35
 217. 36 FZ 1.37
 218. 43 FZ 0.88
 219. 45 FZ 1.47
 220. 47 FZ 1.4
 221. 49 FZ 0.91
 222. *****
 223. LOAD 11 WL1 (0 DEG,INTERNAL SUCTION (CPI=-0.3)
 224. **WIND LOAD(Q) = 1.24 KN/M^2
 225. **CPE(WINDWARD ROOF)=-0.78,CPE(LIEWARD ROOF=-0.2)
 226. **CPE(WINDWARD WALL)=-0.77,CPE(LIEWARD WALL=-0.5)
 227. **BEAM SPACING (ROOF) = 3.3 M , 3.0 M & 2.7 M
 228. **BEAM SPACING (WALL) = 4.0M , 2.5 M
 229. **WIND LOAD = QX(CPE-CPI)XBEAM SPACING
 230. **WL1(WINDWARD WALL)= 1.24(0.77+0.3)X4.0 =5.31 KN/M
 231. **WL2(WINDWARD WALL)= 1.24(0.77+0.3)X2.5 =3.32 KN/M
 232. **WL3(LIEWARD WALL)= 1.24(-0.5+0.3)X4.0 =0.99 KN/M
 233. **WL4(LIEWARD WALL)= 1.24(-0.5+0.3)X2.5 =0.62 KN/M
 234. **WL5(WINDWARD ROOF)= 1.24(-0.78+0.3)X3.0 =1.79(UP) KN/M
 235. **WL6(WINDWARD ROOF)= 1.24(-0.78+0.3)X2.66 =1.58(UP) KN/M
 236. **WL7(LIEWARD ROOF)= 1.24(0.2+0.3)X3.0 =1.86(DN) KN/M
 237. **WL8(LIEWARD ROOF)= 1.24(0.2+0.3)X2.66 =1.65(DN) KN/M
 238. MEMBER LOAD
 239. 306 TO 310 UNI GZ 5.31
 240. 221 TO 225 UNI Y 1.79
 241. 211 TO 215 UNI Y -1.86
 242. 301 TO 305 UNI GZ 0.99
 243. 316 TO 320 UNI GZ 3.32
 244. 311 TO 315 UNI GZ 0.62
 245. 226 TO 235 240 UNI Y 1.58
 246. 201 TO 210 236 UNI Y -1.65
 247. 216 TO 218 220 238 241 UNI Y -0.04
 248. *****
 249. LOAD 12 WL2 (0 DEG , INTERNAL PRESSURE CPI=+0.2)
 250. **WIND LOAD(Q) = 1.24 KN/M^2
 251. **CPE(WINDWARD ROOF)=-0.78,CPE(LIEWARD ROOF)=-0.2
 252. **CPE(WINDWARD WALL)=-0.77,CPE(LIEWARD WALL)=-0.5
 253. **BEAM SPACING (ROOF) = 3.3 M , 3.0 M & 2.7 M
 254. **BEAM SPACING (WALL) = 4.0M , 2.5 M
 255. **WIND LOAD = QX(CPE-CPI)XBEAM SPACING
 256. **WL1(WINDWARD WALL)= 1.24(0.77-0.2)X4.0 =2.83 KN/M
 257. **WL2(WINDWARD WALL)= 1.24(0.77-0.2)X2.5 =1.77 KN/M
 258. **WL3(LIEWARD WALL)= 1.24(-0.5-0.2)X4.0 =3.48 KN/M

BLDG -27(HEAT EXCHANGE FACILITY)

371. **WL8(LEEWARD ROOF)= 1.24(-0.2-0.2)X2.66 =1.49 (UP)KN/M
 372. 306 TO 310 UNI GZ -3.48
 373. 301 TO 305 UNI GZ -2.83
 374. 316 TO 320 UNI GZ -2.17
 375. 311 TO 315 UNI GZ -1.77
 376. 221 TO 225 UNI Y 1.49
 377. 211 TO 215 UNI Y 3.65
 378. 226 TO 235 240 UNI Y 1.32
 379. 201 TO 210 236 UNI Y 3.24
 380. 216 218 220 238 UNI Y 2.83
 381. 241 UNI Y 2.83
 382. 217 UNI Y 2.83
 383. 217 UNI Y 2.83
 384. *****
 385. ** SERVICEABILITY**
 386. *****
 387. LOAD COMB 101 1.0DL+1.0LL
 388. 1 1.0 2 1.0 3 1.0
 389. LOAD COMB 102 1.0DL+0.5LL
 390. 1 1.0 2 1.0 3 0.5
 391. LOAD COMB 103 0.8DL+0.8LL+0.8WL1
 392. 1 0.8 2 0.8 3 0.8 11 0.8
 393. LOAD COMB 104 1.0DL+1.0WL1
 394. 1 1.0 2 1.0 11 1.0
 395. LOAD COMB 105 0.8DL+0.8LL+0.8WL2
 396. 1 0.8 2 0.8 3 0.8 12 0.8
 397. LOAD COMB 106 1.0DL+1.0WL2
 398. 1 1.0 2 1.0 12 1.0
 399. LOAD COMB 107 0.8DL+0.8LL+0.8WL3
 400. 1 0.8 2 0.8 3 0.8 13 0.8
 401. LOAD COMB 108 1.0DL+1.0WL3
 402. 1 1.0 2 1.0 13 1.0
 403. LOAD COMB 109 0.8DL+0.8LL+0.8WL4
 404. 1 0.8 2 0.8 3 0.8 14 0.8
 405. LOAD COMB 110 1.0DL+1.0WL4
 406. 1 1.0 2 1.0 14 1.0
 407. LOAD COMB 111 0.8DL+0.8LL+0.8WL5
 408. 1 0.8 2 0.8 3 0.8 15 0.8
 409. LOAD COMB 112 1.0DL+1.0WL4
 410. 1 1.0 2 1.0 15 1.0
 411. LOAD COMB 113 0.8DL+0.8LL+0.8WL6
 412. 1 0.8 2 0.8 3 0.8 16 0.8
 413. LOAD COMB 114 1.0DL+1.0WL6
 414. 1 1.0 2 1.0 16 1.0
 415. *****EQX & EQZ *****
 416. **DL+EQL/1.4 = 1.0DL+0.72EQX+0.22 EQZ, EQL=EQX+0.3EQZ
 417. **0.9 DL+EQL/1.4 =0.9 DL+0.72 EQX+0.22EQZ
 418. **DL 0.75(LL+(EQL/1.4)) =1.0 DL+0.75 LL+0.54 EQX+0.17EQZ
 419. *****
 420. LOAD COMB 115 DL+0.72EQX+0.22EQZ
 421. 1 1.0 2 1.0 21 0.72 22 0.22
 422. LOAD COMB 116 DL+0.72EQX-0.22EQZ
 423. 1 1.0 2 1.0 21 0.72 22 -0.22
 424. LOAD COMB 117 DL-0.72EQX+0.22EQZ
 425. 1 1.0 2 1.0 21 -0.72 22 0.22
 426. LOAD COMB 118 DL-0.72EQX+0.22EQZ

BLDG -27(HEAT EXCHANGE FACILITY)

315. **WL8(LEEWARD ROOF)= 1.24(-0.7-0.2)X2.66=2.97 (UP)KN/M
 316. MEMBER LOAD
 317. 306 TO 310 UNI GZ -4.97
 318. 301 TO 305 UNI GZ 4.97
 319. 316 TO 320 UNI GZ -3.1
 320. 311 TO 315 UNI GZ 3.1
 321. 221 TO 225 UNI Y 3.35
 322. 211 TO 215 UNI Y 3.35
 323. 226 TO 235 240 UNI Y 2.97
 324. 201 TO 210 236 UNI Y 2.97
 325. 216 TO 218 220 238 241 UNI Y 3.69
 326. *****
 327. LOAD 15 WL5 (0 DEG , INTERNAL SUCTION CPI=-0.3, LEE WARD -0.7, REVERSE)
 328. MEMBER LOAD
 329. **WIND LOAD (Q) = 1.24 KN/M^2
 330. **CPE (WINDWARD ROOF)=-0.78,CPE (LEEWARD ROOF=0.2)
 331. **CPE (WINDWARD WALL)=0.77,CPE (LEEWARD WALL=-0.5)
 332. **BEAM SPACING (ROOF) = 3.3 M , 3.0 M & 2.7 M
 333. **BEAM SPACING (WALL) = 4.0M , 2.5 M
 334. **WIND LOAD = QX(CPE-CPT)XBEAM SPACING
 335. **WL1 (WINDWARD WALL)= 1.24(0.77+0.3)X4.0 =5.31 KN/M
 336. **WL2 (WINDWARD WALL)= 1.24(0.77+0.3)X2.5 =3.32 KN/M
 337. **WL3 (LEEWARD WALL)= 1.24(-0.5+0.3)X4.0 =0.99 KN/M
 338. **WL4 (LEEWARD WALL)= 1.24(-0.5+0.3)X2.5 =0.62 KN/M
 339. **WL5 (WINDWARD ROOF)= 1.24(-0.78+0.3)X3.0 =1.79 (UP) KN/M
 340. **WL6 (WINDWARD ROOF)= 1.24(-0.78+0.3)X2.66 =1.58 (UP) KN/M
 341. **WL7 (LEEWARD ROOF)= 1.24(0.2+0.3)X3.0 =1.86 (DN) KN/M
 342. **WL8 (LEEWARD ROOF)= 1.24(0.2+0.3)X2.66 =1.65 (DN) KN/M
 343. 306 TO 310 UNI GZ -0.99
 344. 301 TO 305 UNI GZ -5.31
 345. 316 TO 320 UNI GZ -0.62
 346. 311 TO 315 UNI GZ -3.32
 347. 221 TO 225 UNI Y -1.86
 348. 211 TO 215 UNI Y 1.79
 349. 226 TO 235 240 UNI Y -1.65
 350. 201 TO 210 236 UNI Y 1.58
 351. 216 218 220 238 UNI Y -0.04
 352. 241 UNI Y -0.04
 353. 217 UNI Y -0.04
 354. 217 UNI Y -0.04
 355. *****
 356. LOAD 16 WL6 (0 DEG , INTERNAL PRESSURE CPI=+0.2, LEE WARD -0.2, REVERSE)
 357. MEMBER LOAD
 358. **WIND LOAD (Q) = 1.24 KN/M^2
 359. **CPE (WINDWARD ROOF)=-0.78,CPE (LEEWARD ROOF)=-0.2
 360. **CPE (WINDWARD WALL)=+0.77,CPE (LEEWARD WALL)=-0.5
 361. **BEAM SPACING (ROOF) = 3.3 M , 3.0 M & 2.7 M
 362. **BEAM SPACING (WALL) = 4.0M , 2.5 M
 363. **WIND LOAD = QX(CPE-CPT)XBEAM SPACING
 364. **WL1 (WINDWARD WALL)= 1.24(0.77-0.2)X4.0 =2.83 KN/M
 365. **WL2 (WINDWARD WALL)= 1.24(0.77-0.2)X2.5 =1.77 KN/M
 366. **WL3 (LEEWARD WALL)= 1.24(-0.5-0.2)X4.0 =3.48 KN/M
 367. **WL4 (LEEWARD WALL)= 1.24(-0.5-0.2)X2.5 =2.17 KN/M
 368. **WL5 (WINDWARD ROOF)= 1.24(-0.78-0.2)X3.0 =-3.65 (UP) KN/M
 369. **WL6 (WINDWARD ROOF)= 1.24(-0.78-0.2)X2.66 =-3.24 (UP) KN/M
 370. **WL7 (LEEWARD ROOF)= 1.24(-0.2-0.2)X3.0 =1.65 (UP) KN/M

BLDG -27(HEAT EXCHANGE FACILITY)

```

427. 1 1.0 2 1.0 21 -0.72 22 -0.22
428. LOAD COMB 119 DL+0.72EQZ+0.22EQX
429. 1 1.0 2 1.0 22 0.72 21 0.22
430. LOAD COMB 120 DL+0.72EQZ-0.22EQX
431. 1 1.0 2 1.0 22 0.72 21 -0.22
432. LOAD COMB 121 DL-0.72EQZ+0.22EQX
433. 1 1.0 2 1.0 22 -0.72 21 0.22
434. LOAD COMB 122 DL-0.72EQZ-0.22EQX
435. 1 1.0 2 1.0 22 -0.72 21 -0.22
436. LOAD COMB 123 0.9DL+0.72EQX+0.22EQZ
437. 1 0.9 2 0.9 21 0.72 22 0.22
438. LOAD COMB 124 0.9DL+0.72EQX-0.22EQZ
439. 1 0.9 2 0.9 21 0.72 22 -0.22
440. LOAD COMB 125 0.9DL-0.72EQX+0.22EQZ
441. 1 0.9 2 0.9 21 -0.72 22 0.22
442. LOAD COMB 126 0.9DL-0.72EQX+0.22EQZ
443. 1 0.9 2 0.9 21 -0.72 22 -0.22
444. LOAD COMB 127 0.9DL+0.72EQZ+0.22EQX
445. 1 0.9 2 0.9 22 0.72 21 0.22
446. LOAD COMB 128 0.9DL+0.72EQZ-0.22EQX
447. 1 0.9 2 0.9 22 0.72 21 -0.22
448. LOAD COMB 129 0.9DL-0.72EQZ+0.22EQX
449. 1 0.9 2 0.9 22 -0.72 21 0.22
450. LOAD COMB 130 0.9DL-0.72EQZ-0.22EQX
451. 1 0.9 2 0.9 22 -0.72 21 -0.22
452. LOAD COMB 131 1.0DL+0.75LL+0.54EQX+0.17 EQZ
453. 1 1.0 2 1.0 3 0.75 21 0.54 22 0.17
454. LOAD COMB 132 1.0DL+0.75LL+0.54EQX-0.17 EQZ
455. 1 1.0 2 1.0 3 0.75 21 0.54 22 -0.17
456. LOAD COMB 133 1.0DL+0.75LL-0.54EQX+0.17 EQZ
457. 1 1.0 2 1.0 3 0.75 21 -0.54 22 0.17
458. LOAD COMB 134 1.0DL+0.75LL-0.54EQX-0.17 EQZ
459. 1 1.0 2 1.0 3 0.75 21 -0.54 22 -0.17
460. LOAD COMB 135 1.0DL+0.75LL+0.54EQZ+0.17 EQX
461. 1 1.0 2 1.0 3 0.75 22 0.54 21 0.17
462. LOAD COMB 136 1.0DL+0.75LL+0.54EQZ-0.17 EQX
463. 1 1.0 2 1.0 3 0.75 22 0.54 21 -0.17
464. LOAD COMB 137 1.0DL+0.75LL-0.54EQZ+0.17 EQX
465. 1 1.0 2 1.0 3 0.75 22 -0.54 21 0.17
466. LOAD COMB 138 1.0DL+0.75LL-0.54EQZ-0.17 EQX
467. 1 1.0 2 1.0 3 0.75 22 -0.54 21 -0.17
468. *****
469. ** STEEL DESIGN **
470. *****
471. LOAD COMB 200 1.4DL+1.6LL
472. 1 1.4 2 1.4 3 1.6
473. *****WL1*****
474. LOAD COMB 201 1.2DL+1.2LL+1.2WL1
475. 1 1.2 2 1.2 3 1.2 11 1.2
476. LOAD COMB 202 1.4DL+1.4WL1
477. 1 1.4 2 1.4 11 1.4
478. LOAD COMB 203 1DL+1.4WL1
479. 1 1.0 2 1.0 11 1.4
480. *****WL2*****
481. LOAD COMB 204 1.2DL+1.2LL+1.2WL2
482. 1 1.2 2 1.2 3 1.2 12 1.2
483. LOAD COMB 205 1.4DL+1.4WL2
484. 1 1.4 2 1.4 12 1.4
485. LOAD COMB 206 1DL+1.4WL2
486. 1 1.0 2 1.0 12 1.4
487. *****WL3*****
488. LOAD COMB 207 1.2DL+1.2LL+1.2WL3
489. 1 1.2 2 1.2 3 1.2 13 1.2
490. LOAD COMB 208 1.4DL+1.4WL3
491. 1 1.4 2 1.4 13 1.4
492. LOAD COMB 209 1DL+1.4WL3
493. 1 1.0 2 1.0 13 1.4
494. *****WL4*****
495. LOAD COMB 210 1.2DL+1.2LL+1.2WL4
496. 1 1.2 2 1.2 3 1.2 14 1.2
497. LOAD COMB 211 1.4DL+1.4WL4
498. 1 1.4 2 1.4 14 1.4
499. LOAD COMB 212 1DL+1.4WL4
500. 1 1.0 2 1.0 14 1.4
501. *****WL5*****
502. LOAD COMB 213 1.2DL+1.2LL+1.2WL5
503. 1 1.2 2 1.2 3 1.2 15 1.2
504. LOAD COMB 214 1.4DL+1.4WL5
505. 1 1.4 2 1.4 15 1.4
506. LOAD COMB 215 1DL+1.4WL5
507. 1 1.0 2 1.0 15 1.4
508. *****WL6*****
509. LOAD COMB 216 1.2DL+1.2LL+1.2WL6
510. 1 1.2 2 1.2 3 1.2 16 1.2
511. LOAD COMB 217 1.4DL+1.4WL6
512. 1 1.4 2 1.4 16 1.4
513. LOAD COMB 218 1DL+1.4WL6
514. 1 1.0 2 1.0 16 1.4
515. *****EQX & EQZ *****
516. LOAD COMB 219 1.2DL+0.5LL+1.0EQX+0.3 EQZ
517. 1 1.2 2 1.2 3 0.5 21 1.0 22 0.3
518. LOAD COMB 220 1.2DL+0.5LL+1.0EQX-0.3 EQZ
519. 1 1.2 2 1.2 3 0.5 21 1.0 22 -0.3
520. LOAD COMB 221 1.2DL+0.5LL-1.0EQX+0.3 EQZ
521. 1 1.2 2 1.2 3 0.5 21 -1.0 22 0.3
522. LOAD COMB 222 1.2DL+0.5LL-1.0EQX-0.3 EQZ
523. 1 1.2 2 1.2 3 0.5 21 -1.0 22 -0.3
524. LOAD COMB 223 1.2DL+0.5LL+1.0EQZ+0.3 EQX
525. 1 1.2 2 1.2 3 0.5 22 1.0 21 0.3
526. LOAD COMB 224 1.2DL+0.5LL+1.0EQZ-0.3 EQX
527. 1 1.2 2 1.2 3 0.5 22 1.0 21 -0.3
528. LOAD COMB 225 1.2DL+0.5LL-1.0EQZ+0.3 EQX
529. 1 1.2 2 1.2 3 0.5 22 -1.0 21 0.3
530. LOAD COMB 226 1.2DL+0.5LL-1.0EQZ-0.3 EQX
531. 1 1.0 2 1.2 3 0.5 22 -1.0 21 -0.3
532. LOAD COMB 227 0.9DL+1.0EQX+0.3EQZ
533. 1 0.9 2 0.9 21 1.0 22 0.3
534. LOAD COMB 228 0.9DL+1.0EQX-0.3EQZ2
535. 1 0.9 2 0.9 21 1.0 22 -0.3
536. LOAD COMB 229 0.9DL-1.0EQX+0.3EQZ
537. 1 0.9 2 0.9 21 -1.0 22 0.3
538. LOAD COMB 230 0.9DL-1.0EQX+0.3EQZ

```

539. 1 0.9 2 0.9 21 -1.0 22 -0.3
540. LOAD COMB 231 0.9DL+1.0EQZ+0.3EQX
541. 1 0.9 2 0.9 22 1.0 21 0.3
542. LOAD COMB 232 0.9DL+1.0EQZ-0.3EQX
543. 1 0.9 2 0.9 22 1.0 21 -0.3
544. LOAD COMB 233 0.9DL-1.0EQZ+0.3EQX
545. 1 0.9 2 0.9 22 -1.0 21 0.3
546. LOAD COMB 234 0.9DL-1.0EQZ-0.3EQX
547. 1 0.9 2 0.9 22 -1.0 21 -0.3
548. LOAD COMB 235 1.0DL+1.0LL+1.0PHX
549. 1 1.0 2 1.0 3 1.0 4 1.0
550. LOAD COMB 236 1.0DL+1.0LL+1.0PHZ
551. 1 1.0 2 1.0 3 1.0 5 1.0
552. *****DEFLECTION*****
553. LOAD COMB 301 SELF+DL
554. 1 1.0 2 1.0
555. LOAD COMB 302 LL
556. 3 1.0
557. LOAD COMB 303 0.8(LL+WL1)
558. 3 0.8 11 0.8
559. LOAD COMB 304 0.8(LL+WL2)
560. 3 0.8 12 0.8
561. LOAD COMB 305 0.8(LL+WL3)
562. 3 0.8 13 0.8
563. LOAD COMB 306 0.8(LL+WL4)
564. 3 0.8 14 0.8
565. LOAD COMB 307 0.8(LL+WL5)
566. 3 0.8 15 0.8
567. LOAD COMB 308 0.8(LL+WL6)
568. 3 0.8 16 0.8
569. LOAD COMB 309 0.8(LL+EQX/1.4+0.3EQZ/1.4)
570. 3 0.8 21 0.57 22 0.17
571. LOAD COMB 310 0.8(LL+EQX/1.4-0.3EQZ/1.4)
572. 3 0.8 21 0.57 22 -0.17
573. LOAD COMB 311 0.8(LL-EQX/1.4+0.3EQZ/1.4)
574. 3 0.8 21 -0.57 22 0.17
575. LOAD COMB 312 0.8(LL-EQX/1.4-0.3EQZ/1.4)
576. 3 0.8 21 -0.57 22 -0.17
577. LOAD COMB 313 0.8(LL+EQZ/1.4+0.3EQX/1.4)
578. 3 0.8 22 0.57 21 0.17
579. LOAD COMB 314 0.8(LL+EQZ/1.4-0.3EQX/1.4)
580. 3 0.8 22 0.57 21 -0.17
581. LOAD COMB 315 0.8(LL-EQZ/1.4+0.3EQX/1.4)
582. 3 0.8 22 -0.57 21 0.17
583. LOAD COMB 316 0.8(LL-EQZ/1.4-0.3EQX/1.4)
584. 3 0.8 22 -0.57 21 -0.17
585. *****
586. PERFORM ANALYSIS

□

P R O B L E M S T A T I S T I C S

NUMBER OF JOINTS/MEMBER-ELEMENTS/SUPPORTS = 125/ 182/ 32
ORIGINAL/FINAL BAND-WIDTH= 119/ 15/ 81 DOF
TOTAL PRIMARY LOAD CASES = 13, TOTAL DEGREES OF FREEDOM = 654
SIZE OF STIFFNESS MATRIX = 53 DOUBLE KILO-WORDS
REQRD/AVAIL. DISK SPACE = 13.0/ 22202.7 MB

□

**WARNING: IF THIS UBC/IBC ANALYSIS HAS TENSION/COMPRESSION
OR REPEAT LOAD OR RE-ANALYSIS OR SELECT OPTIMIZE, THEN EACH
UBC/IBC CASE SHOULD BE FOLLOWED BY PERFORM ANALYSIS & CHANGE.

*

* X DIRECTION : Ta = 0.381 Tb = 0.115 Tuser = 0.381 *

* T = 0.381, LOAD FACTOR = 1.000 *

* UBC TYPE = 97 *

* UBC FACTOR V = 0.1222 x 761.80 = 93.11 KN *

*

*

* Z DIRECTION : Ta = 0.381 Tb = 0.028 Tuser = 0.381 *

* T = 0.381, LOAD FACTOR = 1.000 *

* UBC TYPE = 97 *

* UBC FACTOR V = 0.1222 x 761.80 = 93.11 KN *

*

587. LOAD LIST 101 TO 138

588. PRINT SUPPORT REACTION

□ SUPPORT REACTION

□

SUPPORT REACTIONS -UNIT KN METE STRUCTURE TYPE = SPACE

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM-Z
1	101	0.92	15.43	1.24	0.00	0.00	0.00
	102	0.91	16.23	1.34	0.00	0.00	0.00
	103	0.74	3.75	-1.67	0.00	0.00	0.00
	104	0.90	6.29	-1.88	0.00	0.00	0.00
	105	0.68	-11.74	-7.55	0.00	0.00	0.00
	106	0.84	-13.07	-9.22	0.00	0.00	0.00
	107	0.72	-6.74	-5.35	0.00	0.00	0.00
	108	0.88	-6.83	-6.47	0.00	0.00	0.00
	109	0.65	-21.01	-11.06	0.00	0.00	0.00
	110	0.80	-24.66	-13.62	0.00	0.00	0.00
	111	0.79	51.90	14.39	0.00	0.00	0.00
	112	0.98	66.47	18.19	0.00	0.00	0.00
	113	0.75	35.33	8.38	0.00	0.00	0.00
	114	0.92	45.77	10.69	0.00	0.00	0.00
	115	0.94	17.45	1.50	0.00	0.00	0.00
	116	0.94	16.68	1.40	0.00	0.00	0.00
	117	0.87	17.39	1.49	0.00	0.00	0.00
	118	0.87	16.61	1.40	0.00	0.00	0.00
	119	0.92	18.31	1.61	0.00	0.00	0.00
	120	0.90	18.29	1.61	0.00	0.00	0.00
13	121	0.92	15.77	1.29	0.00	0.00	0.00
	122	0.90	15.75	1.29	0.00	0.00	0.00
	123	0.85	15.75	1.36	0.00	0.00	0.00
	124	0.85	14.97	1.26	0.00	0.00	0.00
	125	0.78	15.68	1.35	0.00	0.00	0.00
	126	0.78	14.91	1.25	0.00	0.00	0.00
	127	0.83	16.61	1.47	0.00	0.00	0.00
	128	0.81	16.59	1.46	0.00	0.00	0.00
	129	0.83	14.07	1.14	0.00	0.00	0.00
	130	0.81	14.05	1.14	0.00	0.00	0.00
	131	0.94	16.15	1.33	0.00	0.00	0.00
	132	0.94	15.55	1.26	0.00	0.00	0.00
	133	0.89	16.11	1.32	0.00	0.00	0.00
	134	0.89	15.51	1.25	0.00	0.00	0.00
	135	0.92	16.79	1.41	0.00	0.00	0.00
	136	0.91	16.78	1.41	0.00	0.00	0.00
	137	0.92	14.89	1.17	0.00	0.00	0.00
	138	0.91	14.87	1.17	0.00	0.00	0.00
	139	0.92	15.32	-1.22	0.00	0.00	0.00
	140	0.91	16.15	-1.33	0.00	0.00	0.00
14	141	0.79	51.80	-14.37	0.00	0.00	0.00
	142	0.98	66.41	-18.19	0.00	0.00	0.00
	143	0.75	35.30	-8.38	0.00	0.00	0.00
	144	0.92	45.78	-10.69	0.00	0.00	0.00
	145	0.72	-6.86	5.36	0.00	0.00	0.00
	146	0.88	-6.91	6.48	0.00	0.00	0.00
	147	0.65	-20.98	11.06	0.00	0.00	0.00
	148	0.80	-24.56	13.60	0.00	0.00	0.00
	149	0.92	15.77	1.29	0.00	0.00	0.00
	150	0.90	15.75	1.29	0.00	0.00	0.00
	151	0.85	15.75	1.36	0.00	0.00	0.00
	152	0.85	14.97	1.26	0.00	0.00	0.00
	153	0.78	15.68	1.35	0.00	0.00	0.00
	154	0.78	14.91	1.25	0.00	0.00	0.00
	155	0.83	16.61	1.47	0.00	0.00	0.00
	156	0.81	16.59	1.46	0.00	0.00	0.00
	157	0.83	14.07	1.14	0.00	0.00	0.00
	158	0.81	14.05	1.14	0.00	0.00	0.00
	159	0.94	16.15	1.33	0.00	0.00	0.00
	160	0.94	15.55	1.26	0.00	0.00	0.00

□

SUPPORT REACTIONS -UNIT KN METE STRUCTURE TYPE = SPACE

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM-Z
14	111	0.74	3.63	1.69	0.00	0.00	0.00
	112	0.91	6.20	1.89	0.00	0.00	0.00
	113	0.68	-11.75	7.55	0.00	0.00	0.00
	114	0.84	-13.03	9.21	0.00	0.00	0.00
	115	0.94	16.62	-1.40	0.00	0.00	0.00
	116	0.94	17.40	-1.50	0.00	0.00	0.00
	117	0.87	16.56	-1.39	0.00	0.00	0.00
	118	0.87	17.34	-1.49	0.00	0.00	0.00
	119	0.92	15.72	-1.28	0.00	0.00	0.00
	120	0.90	15.70	-1.28	0.00	0.00	0.00
	121	0.92	18.26	-1.60	0.00	0.00	0.00
	122	0.90	18.24	-1.60	0.00	0.00	0.00
	123	0.85	14.92	-1.25	0.00	0.00	0.00
	124	0.85	15.70	-1.35	0.00	0.00	0.00
	125	0.78	14.86	-1.24	0.00	0.00	0.00
	126	0.78	15.64	-1.34	0.00	0.00	0.00
	127	0.83	14.02	-1.14	0.00	0.00	0.00
	128	0.81	14.00	-1.14	0.00	0.00	0.00
	129	0.83	16.56	-1.46	0.00	0.00	0.00
	130	0.81	16.55	-1.46	0.00	0.00	0.00
	131	0.94	15.46	-1.24	0.00	0.00	0.00
14	132	0.94	16.06	-1.32	0.00	0.00	0.00
	133	0.89	15.41	-1.24	0.00	0.00	0.00
	134	0.89	16.01	-1.31	0.00	0.00	0.00
	135	0.93	14.79	-1.16	0.00	0.00	0.00
	136	0.91	14.77	-1.16	0.00	0.00	0.00
	137	0.93	16.70	-1.40	0.00	0.00	0.00
	138	0.91	16.68	-1.40	0.00	0.00	0.00
	139	0.02	22.29	1.74	0.00	0.00	0.00
	140	0.02	23.14	1.86	0.00	0.00	0.00
	141	0.01	6.92	-2.04	0.00	0.00	0.00
	142	0.02	10.35	-2.32	0.00	0.00	0.00
	143	0.02	-13.72	-9.77	0.00	0.00	0.00
	144	0.03	-15.45	-11.99	0.00	0.00	0.00
	145	0.01	-6.64	-6.83	0.00	0.00	0.00
	146	0.02	-6.60	-8.31	0.00	0.00	0.00
	147	0.02	-26.02	-14.39	0.00	0.00	0.00
	148	0.03	-30.83	-17.77	0.00	0.00	0.00
	149	0.02	68.96	18.83	0.00	0.00	0.00
	150	0.04	87.90	23.77	0.00	0.00	0.00
	151	0.03	47.10	10.96	0.00	0.00	0.00
14	152	0.03	60.58	13.92	0.00	0.00	0.00
	153	0.05	23.94	1.96	0.00	0.00	0.00
	154	0.05	23.03	1.85	0.00	0.00	0.00
	155	0.00	24.95	2.09	0.00	0.00	0.00
	156	0.00	24.04	1.98	0.00	0.00	0.00
	157	0.03	25.33	2.14	0.00	0.00	0.00
	158	0.02	25.63	2.18	0.00	0.00	0.00
	159	0.00	0.00	0.00	0.00	0.00	0.00
	160	0.00	0.00	0.00	0.00	0.00	0.00
	161	0.00	0.00	0.00	0.00	0.00	0.00
	162	0.00	0.00	0.00	0.00	0.00	0.00
	163	0.00	0.00	0.00	0.00	0.00	0.00
	164	0.00	0.00	0.00	0.00	0.00	0.00
	165	0.00	0.00	0.00	0.00	0.00	0.00
	166	0.00	0.00	0.00	0.00	0.00	0.00
	167	0.00	0.00	0.00	0.00	0.00	0.00
	168	0.00	0.00	0.00	0.00	0.00	0.00
	169	0.00	0.00	0.00	0.00	0.00	0.00
	170	0.00	0.00	0.00	0.00	0.00	0.00
	171	0.00	0.00	0.00	0.00	0.00	0.00

□

SUPPORT REACTIONS -UNIT KN METE STRUCTURE TYPE = SPACE

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM-Z
121	0.03	22.35	1.76	0.00	0.00	0.00	0.00
122	0.02	22.65	1.80	0.00	0.00	0.00	0.00
123	0.05	21.55	1.77	0.00	0.00	0.00	0.00
124	0.05	20.64	1.65	0.00	0.00	0.00	0.00
125	0.00	22.55	1.89	0.00	0.00	0.00	0.00
126	0.00	21.64	1.78	0.00	0.00	0.00	0.00
127	0.03	22.93	1.94	0.00	0.00	0.00	0.00
128	0.02	23.23	1.98	0.00	0.00	0.00	0.00
129	0.03	19.95	1.57	0.00	0.00	0.00	0.00
130	0.02	20.25	1.60	0.00	0.00	0.00	0.00
131	0.04	22.69	1.80	0.00	0.00	0.00	0.00
132	0.04	21.99	1.71	0.00	0.00	0.00	0.00
133	0.01	23.44	1.89	0.00	0.00	0.00	0.00
134	0.01	22.74	1.80	0.00	0.00	0.00	0.00
135	0.03	23.71	1.93	0.00	0.00	0.00	0.00
136	0.02	23.95	1.96	0.00	0.00	0.00	0.00
137	0.03	21.48	1.65	0.00	0.00	0.00	0.00
138	0.02	21.72	1.67	0.00	0.00	0.00	0.00
139	0.02	22.07	-1.72	0.00	0.00	0.00	0.00
140	0.02	22.96	-1.83	0.00	0.00	0.00	0.00
141	0.02	68.75	-18.81	0.00	0.00	0.00	0.00
142	0.04	87.73	-23.75	0.00	0.00	0.00	0.00
143	0.03	47.02	-10.95	0.00	0.00	0.00	0.00
144	0.04	60.57	-13.92	0.00	0.00	0.00	0.00
145	0.01	-6.87	6.86	0.00	0.00	0.00	0.00
146	0.02	-6.79	8.33	0.00	0.00	0.00	0.00
147	0.02	-26.01	14.39	0.00	0.00	0.00	0.00
148	0.03	-30.72	17.75	0.00	0.00	0.00	0.00
149	0.01	6.72	2.06	0.00	0.00	0.00	0.00
150	0.02	10.19	2.34	0.00	0.00	0.00	0.00
151	0.02	-13.78	9.78	0.00	0.00	0.00	0.00
152	0.03	-15.43	11.99	0.00	0.00	0.00	0.00
153	0.05	22.92	-1.83	0.00	0.00	0.00	0.00
154	0.05	23.83	-1.95	0.00	0.00	0.00	0.00
155	0.00	23.89	-1.96	0.00	0.00	0.00	0.00
156	0.00	24.80	-2.07	0.00	0.00	0.00	0.00
157	0.03	22.22	-1.75	0.00	0.00	0.00	0.00
158	0.02	22.52	-1.78	0.00	0.00	0.00	0.00
159	0.03	25.21	-2.12	0.00	0.00	0.00	0.00
160	0.02	25.50	-2.16	0.00	0.00	0.00	0.00
161	0.05	20.53	-1.64	0.00	0.00	0.00	0.00
162	0.05	21.45	-1.75	0.00	0.00	0.00	0.00
163	0.00	21.51	-1.76	0.00	0.00	0.00	0.00
164	0.00	22.42	-1.88	0.00	0.00	0.00	0.00
165	0.03	19.84	-1.55	0.00	0.00	0.00	0.00
166	0.02	20.13	-1.59	0.00	0.00	0.00	0.00
167	0.03	22.82	-1.93	0.00	0.00	0.00	0.00
168	0.02	23.12	-1.96	0.00	0.00	0.00	0.00

□

SUPPORT REACTIONS -UNIT KN METE STRUCTURE TYPE = SPACE

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM-Z
131	0.04	21.80	-1.68	0.00	0.00	0.00	0.00
132	0.04	22.50	-1.77	0.00	0.00	0.00	0.00
133	0.01	22.53	-1.78	0.00	0.00	0.00	0.00
134	0.01	23.23	-1.86	0.00	0.00	0.00	0.00
135	0.03	21.28	-1.62	0.00	0.00	0.00	0.00
136	0.02	21.51	-1.65	0.00	0.00	0.00	0.00
137	0.03	23.52	-1.90	0.00	0.00	0.00	0.00
138	0.02	23.75	-1.93	0.00	0.00	0.00	0.00
139	-0.02	22.29	1.74	0.00	0.00	0.00	0.00
140	-0.02	23.14	1.86	0.00	0.00	0.00	0.00
141	-0.01	6.92	-2.04	0.00	0.00	0.00	0.00
142	-0.02	10.35	-2.32	0.00	0.00	0.00	0.00
143	-0.02	-13.72	-9.77	0.00	0.00	0.00	0.00
144	-0.03	-15.45	-11.99	0.00	0.00	0.00	0.00
145	-0.01	-6.64	-6.83	0.00	0.00	0.00	0.00
146	-0.02	-6.60	-8.31	0.00	0.00	0.00	0.00
147	-0.02	-26.02	-14.39	0.00	0.00	0.00	0.00
148	-0.03	-30.83	-17.77	0.00	0.00	0.00	0.00
149	-0.02	68.96	18.83	0.00	0.00	0.00	0.00
150	-0.04	87.89	23.77	0.00	0.00	0.00	0.00
151	-0.03	47.08	10.95	0.00	0.00	0.00	0.00
152	-0.04	60.55	13.92	0.00	0.00	0.00	0.00
153	0.00	24.94	2.09	0.00	0.00	0.00	0.00
154	0.00	24.03	1.97	0.00	0.00	0.00	0.00
155	-0.05	23.95	1.97	0.00	0.00	0.00	0.00
156	-0.05	23.04	1.85	0.00	0.00	0.00	0.00
157	-0.02	25.63	2.18	0.00	0.00	0.00	0.00
158	-0.03	25.33	2.14	0.00	0.00	0.00	0.00
159	-0.02	22.65	1.80	0.00	0.00	0.00	0.00
160	-0.03	22.35	1.76	0.00	0.00	0.00	0.00
161	0.00	22.54	1.89	0.00	0.00	0.00	0.00
162	0.00	21.63	1.78	0.00	0.00	0.00	0.00
163	-0.05	21.55	1.77	0.00	0.00	0.00	0.00
164	-0.05	20.64	1.65	0.00	0.00	0.00	0.00
165	-0.02	23.23	1.98	0.00	0.00	0.00	0.00
166	-0.03	22.93	1.94	0.00	0.00	0.00	0.00
167	-0.02	20.25	1.60	0.00	0.00	0.00	0.00
168	-0.03	19.95	1.57	0.00	0.00	0.00	0.00
169	-0.01	23.44	1.89	0.00	0.00	0.00	0.00
170	-0.01	22.74	1.80	0.00	0.00	0.00	0.00
171	-0.04	22.70	1.80	0.00	0.00	0.00	0.00
172	-0.04	21.99	1.71	0.00	0.00	0.00	0.00
173	-0.02	23.95	1.96	0.00	0.00	0.00	0.00
174	-0.03	23.72	1.93	0.00	0.00	0.00	0.00
175	-0.02	21.72	1.67	0.00	0.00	0.00	0.00
176	-0.03	21.48	1.65	0.00	0.00	0.00	0.00
177	-0.02	22.09	-1.72	0.00	0.00	0.00	0.00
178	-0.02	22.98	-1.84	0.00	0.00	0.00	0.00

39

□

SUPPORT REACTIONS -UNIT KN METE STRUCTURE TYPE = SPACE

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM-Z
103	-0.02	68.78	-18.81	0.00	0.00	0.00	0.00
104	-0.04	87.76	-23.75	0.00	0.00	0.00	0.00
105	-0.03	47.04	-10.95	0.00	0.00	0.00	0.00
106	-0.04	60.58	-13.92	0.00	0.00	0.00	0.00
107	-0.01	-6.84	6.85	0.00	0.00	0.00	0.00
108	-0.02	-6.77	8.33	0.00	0.00	0.00	0.00
109	-0.02	-26.00	14.39	0.00	0.00	0.00	0.00
110	-0.03	-30.72	17.75	0.00	0.00	0.00	0.00
111	-0.01	6.73	2.06	0.00	0.00	0.00	0.00
112	-0.02	10.20	2.34	0.00	0.00	0.00	0.00
113	-0.02	-13.84	9.79	0.00	0.00	0.00	0.00
114	-0.03	-15.51	12.00	0.00	0.00	0.00	0.00
115	0.00	23.91	-1.96	0.00	0.00	0.00	0.00
116	0.00	24.82	-2.07	0.00	0.00	0.00	0.00
117	-0.05	22.94	-1.84	0.00	0.00	0.00	0.00
118	-0.05	23.85	-1.95	0.00	0.00	0.00	0.00
119	-0.02	22.53	-1.79	0.00	0.00	0.00	0.00
120	-0.03	22.24	-1.75	0.00	0.00	0.00	0.00
121	-0.02	25.52	-2.16	0.00	0.00	0.00	0.00
122	-0.03	25.23	-2.13	0.00	0.00	0.00	0.00
123	0.00	21.52	-1.76	0.00	0.00	0.00	0.00
124	0.00	22.43	-1.88	0.00	0.00	0.00	0.00
125	-0.05	20.55	-1.64	0.00	0.00	0.00	0.00
126	-0.05	21.46	-1.76	0.00	0.00	0.00	0.00
127	-0.02	20.14	-1.59	0.00	0.00	0.00	0.00
128	-0.03	19.85	-1.55	0.00	0.00	0.00	0.00
129	-0.02	23.13	-1.97	0.00	0.00	0.00	0.00
130	-0.03	22.84	-1.93	0.00	0.00	0.00	0.00
131	-0.01	22.55	-1.78	0.00	0.00	0.00	0.00
132	-0.01	23.25	-1.87	0.00	0.00	0.00	0.00
133	-0.04	21.82	-1.69	0.00	0.00	0.00	0.00
134	-0.04	22.53	-1.78	0.00	0.00	0.00	0.00
135	-0.02	21.53	-1.65	0.00	0.00	0.00	0.00
136	-0.03	21.30	-1.62	0.00	0.00	0.00	0.00
137	-0.02	23.77	-1.93	0.00	0.00	0.00	0.00
138	-0.03	23.55	-1.90	0.00	0.00	0.00	0.00
40	101	-0.92	15.43	1.24	0.00	0.00	0.00
102	-0.91	16.23	1.34	0.00	0.00	0.00	0.00
103	-0.74	3.75	-1.67	0.00	0.00	0.00	0.00
104	-0.91	6.29	-1.88	0.00	0.00	0.00	0.00
105	-0.68	-11.74	-7.55	0.00	0.00	0.00	0.00
106	-0.84	-13.07	-9.22	0.00	0.00	0.00	0.00
107	-0.72	-6.74	-5.35	0.00	0.00	0.00	0.00
108	-0.88	-6.83	-6.47	0.00	0.00	0.00	0.00
109	-0.65	-21.01	-11.06	0.00	0.00	0.00	0.00
110	-0.80	-24.66	-13.62	0.00	0.00	0.00	0.00
111	-0.79	51.90	14.39	0.00	0.00	0.00	0.00
112	-0.98	66.47	18.19	0.00	0.00	0.00	0.00

□

SUPPORT REACTIONS -UNIT KN METE STRUCTURE TYPE = SPACE

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM-Z
113	-0.75	35.32	8.38	0.00	0.00	0.00	0.00
114	-0.92	45.75	10.69	0.00	0.00	0.00	0.00
115	-0.87	17.39	1.49	0.00	0.00	0.00	0.00
116	-0.87	16.61	1.40	0.00	0.00	0.00	0.00
117	-0.94	17.45	1.50	0.00	0.00	0.00	0.00
118	-0.94	16.68	1.40	0.00	0.00	0.00	0.00
119	-0.90	18.29	1.61	0.00	0.00	0.00	0.00
120	-0.92	18.31	1.61	0.00	0.00	0.00	0.00
121	-0.90	15.75	1.29	0.00	0.00	0.00	0.00
122	-0.92	15.77	1.29	0.00	0.00	0.00	0.00
123	-0.78	15.69	1.35	0.00	0.00	0.00	0.00
124	-0.78	14.91	1.25	0.00	0.00	0.00	0.00
125	-0.85	15.75	1.36	0.00	0.00	0.00	0.00
126	-0.85	14.97	1.26	0.00	0.00	0.00	0.00
127	-0.81	16.59	1.46	0.00	0.00	0.00	0.00
128	-0.83	16.61	1.47	0.00	0.00	0.00	0.00
129	-0.81	14.05	1.14	0.00	0.00	0.00	0.00
130	-0.83	14.07	1.15	0.00	0.00	0.00	0.00
131	-0.89	16.11	1.32	0.00	0.00	0.00	0.00
132	-0.89	15.51	1.25	0.00	0.00	0.00	0.00
133	-0.94	16.15	1.33	0.00	0.00	0.00	0.00
134	-0.94	15.55	1.26	0.00	0.00	0.00	0.00
135	-0.91	16.78	1.41	0.00	0.00	0.00	0.00
136	-0.93	16.79	1.41	0.00	0.00	0.00	0.00
137	-0.91	14.87	1.17	0.00	0.00	0.00	0.00
138	-0.93	14.89	1.17	0.00	0.00	0.00	0.00
52	101	-0.92	15.32	-1.22	0.00	0.00	0.00
102	-0.91	16.15	-1.33	0.00	0.00	0.00	0.00
103	-0.79	51.80	-14.37	0.00	0.00	0.00	0.00
104	-0.98	66.41	-18.19	0.00	0.00	0.00	0.00
105	-0.75	35.30	-8.38	0.00	0.00	0.00	0.00
106	-0.92	45.78	-10.69	0.00	0.00	0.00	0.00
107	-0.72	-6.86	5.36	0.00	0.00	0.00	0.00
108	-0.88	-6.91	6.48	0.00	0.00	0.00	0.00
109	-0.65	-20.98	11.06	0.00	0.00	0.00	0.00
110	-0.80	-24.56	13.60	0.00	0.00	0.00	0.00
111	-0.74	3.63	1.69	0.00	0.00	0.00	0.00
112	-0.91	6.20	1.89	0.00	0.00	0.00	0.00
113	-0.68	-11.81	7.56	0.00	0.00	0.00	0.00
114	-0.84	-13.10	9.23	0.00	0.00	0.00	0.00
115	-0.87	16.56	-1.39	0.00	0.00	0.00	0.00
116	-0.87	17.34	-1.49	0.00	0.00	0.00	0.00
117	-0.94	16.62	-1.40	0.00	0.00	0.00	0.00
118	-0.94	17.40	-1.50	0.00	0.00	0.00	0.00
119	-0.90	15.70	-1.28	0.00	0.00	0.00	0.00
120	-0.92	15.72	-1.28	0.00	0.00	0.00	0.00
121	-0.90	18.24	-1.60	0.00	0.00	0.00	0.00
122	-0.92	18.26	-1.60	0.00	0.00	0.00	0.00

□

SUPPORT REACTIONS -UNIT KN METE STRUCTURE TYPE = SPACE

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM-Z
123	-0.78	14.86	-1.24	0.00	0.00	0.00	0.00
124	-0.78	15.64	-1.34	0.00	0.00	0.00	0.00
125	-0.85	14.92	-1.25	0.00	0.00	0.00	0.00
126	-0.85	15.70	-1.35	0.00	0.00	0.00	0.00
127	-0.81	14.00	-1.14	0.00	0.00	0.00	0.00
128	-0.83	14.02	-1.14	0.00	0.00	0.00	0.00
129	-0.81	16.54	-1.46	0.00	0.00	0.00	0.00
130	-0.83	16.56	-1.46	0.00	0.00	0.00	0.00
131	-0.89	15.41	-1.24	0.00	0.00	0.00	0.00
132	-0.89	16.01	-1.31	0.00	0.00	0.00	0.00
133	-0.94	15.46	-1.24	0.00	0.00	0.00	0.00
134	-0.94	16.06	-1.32	0.00	0.00	0.00	0.00
135	-0.91	14.77	-1.16	0.00	0.00	0.00	0.00
136	-0.93	14.79	-1.16	0.00	0.00	0.00	0.00
137	-0.91	16.68	-1.40	0.00	0.00	0.00	0.00
138	-0.93	16.69	-1.40	0.00	0.00	0.00	0.00
96	101	3.25	70.18	-13.12	0.00	0.00	0.00
102	2.51	57.16	-10.78	0.00	0.00	0.00	0.00
103	3.83	71.13	-5.22	0.00	0.00	0.00	0.00
104	3.32	62.86	-1.86	0.00	0.00	0.00	0.00
105	1.64	35.40	-1.47	0.00	0.00	0.00	0.00
106	0.58	18.20	2.83	0.00	0.00	0.00	0.00
107	3.81	77.59	-14.18	0.00	0.00	0.00	0.00
108	3.29	70.93	-13.07	0.00	0.00	0.00	0.00
109	0.41	17.88	-2.77	0.00	0.00	0.00	0.00
110	-0.95	-3.70	1.20	0.00	0.00	0.00	0.00
111	1.42	41.84	-16.39	0.00	0.00	0.00	0.00
112	0.30	26.25	-15.82	0.00	0.00	0.00	0.00
113	0.15	17.92	-8.50	0.00	0.00	0.00	0.00
114	-1.27	-3.65	-9.97	0.00	0.00	0.00	0.00
115	-4.39	43.61	-9.16	0.00	0.00	0.00	0.00
116	-4.40	43.69	-7.78	0.00	0.00	0.00	0.00
117	7.96	44.57	-9.13	0.00	0.00	0.00	0.00
118	7.95	44.65	-7.74	0.00	0.00	0.00	0.00
119	-0.10	43.85	-10.72	0.00	0.00	0.00	0.00
120	3.67	44.14	-10.71	0.00	0.00	0.00	0.00
121	-0.11	44.12	-6.19	0.00	0.00	0.00	0.00
122	3.66	44.42	-6.18	0.00	0.00	0.00	0.00
123	-4.57	39.20	-8.32	0.00	0.00	0.00	0.00
124	-4.58	39.28	-6.93	0.00	0.00	0.00	0.00
125	7.78	40.16	-8.28	0.00	0.00	0.00	0.00
126	7.77	40.24	-6.90	0.00	0.00	0.00	0.00
127	-0.28	39.43	-9.88	0.00	0.00	0.00	0.00
128	3.49	39.73	-9.87	0.00	0.00	0.00	0.00
129	-0.29	39.71	-5.35	0.00	0.00	0.00	0.00
130	3.48	40.00	-5.33	0.00	0.00	0.00	0.00
131	-1.75	63.28	-12.50	0.00	0.00	0.00	0.00
132	-1.75	63.34	-11.43	0.00	0.00	0.00	0.00

□

SUPPORT REACTIONS -UNIT KN METE STRUCTURE TYPE = SPACE

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM-Z
133	7.51	64.00	-12.47	0.00	0.00	0.00	0.00
134	7.51	64.06	-11.40	0.00	0.00	0.00	0.00
135	1.43	63.45	-13.65	0.00	0.00	0.00	0.00
136	4.34	63.68	-13.65	0.00	0.00	0.00	0.00
137	1.42	63.66	-10.25	0.00	0.00	0.00	0.00
138	4.33	63.89	-10.25	0.00	0.00	0.00	0.00
97	101	3.27	66.63	12.50	0.00	0.00	0.00
102	2.53	54.28	10.32	0.00	0.00	0.00	0.00
103	1.42	39.36	15.35	0.00	0.00	0.00	0.00
104	0.29	24.49	14.82	0.00	0.00	0.00	0.00
105	0.20	16.82	8.01	0.00	0.00	0.00	0.00
106	-1.23	-3.69	5.65	0.00	0.00	0.00	0.00
107	3.84	73.67	13.45	0.00	0.00	0.00	0.00
108	3.32	67.37	12.44	0.00	0.00	0.00	0.00
109	0.41	17.01	2.73	0.00	0.00	0.00	0.00
110	-0.98	-3.44	-0.96	0.00	0.00	0.00	0.00
111	3.86	67.86	5.27	0.00	0.00	0.00	0.00
112	3.35	60.12	2.22	0.00	0.00	0.00	0.00
113	1.59	33.83	1.65	0.00	0.00	0.00	0.00
114	0.51	17.57	-2.30	0.00	0.00	0.00	0.00
115	-3.95	41.52	7.47	0.00	0.00	0.00	0.00
116	-3.95	41.43	8.83	0.00	0.00	0.00	0.00
117	7.52	42.41	7.44	0.00	0.00	0.00	0.00
118	7.53	42.32	8.80	0.00	0.00	0.00	0.00
119	0.03	41.93	5.92	0.00	0.00	0.00	0.00
120	3.54	42.20	5.91	0.00	0.00	0.00	0.00
121	0.04	41.64	10.36	0.00	0.00	0.00	0.00
122	3.54	41.91	10.35	0.00	0.00	0.00	0.00
123	-4.13	37.33	6.66	0.00	0.00	0.00	0.00
124	-4.13	37.24	8.02	0.00	0.00	0.00	0.00
125	7.35	38.22	6.62	0.00	0.00	0.00	0.00
126	7.35	38.13	7.98	0.00	0.00	0.00	0.00
127	-0.15	37.74	5.10	0.00	0.00	0.00	0.00
128	3.36	38.01	5.09	0.00	0.00	0.00	0.00
129	-0.14	37.44	9.55	0.00	0.00	0.00	0.00
130	3.37	37.72	9.54	0.00	0.00	0.00	0.00
131	-1.40	60.15	10.90	0.00	0.00	0.00	0.00
132	-1.40	60.08	11.95	0.00	0.00	0.00	0.00
133	7.20	60.82	10.87	0.00	0.00	0.00	0.00
134	7.21	60.75	11.92	0.00	0.00	0.00	0.00
135	1.54	60.46	9.75	0.00	0.00	0.00	0.00
136	4.25	60.67	9.74	0.00	0.00	0.00	0.00
137	1.55	60.24	13.08	0.00	0.00	0.00	0.00
138	4.26	60.45	13.07	0.00	0.00	0.00	0.00
98	101	0.01	58.82	-2.93	0.00	0.00	0.00
102	0.01	47.94	-2.57	0.00	0.00	0.00	0.00
103	0.01	60.31	4.06	0.00	0.00	0.00	0.00
104	0.01	53.62	5.80	0.00	0.00	0.00	0.00

□

SUPPORT REACTIONS -UNIT KN METE STRUCTURE TYPE = SPACE

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM-Z
105	0.01	30.26	3.00	0.00	0.00	0.00	0.00
106	0.01	16.05	4.46	0.00	0.00	0.00	0.00
107	0.01	64.98	-2.73	0.00	0.00	0.00	0.00
108	0.01	59.46	-2.70	0.00	0.00	0.00	0.00
109	0.01	15.22	-0.24	0.00	0.00	0.00	0.00
110	0.01	-2.74	0.41	0.00	0.00	0.00	0.00
111	0.00	34.31	-9.39	0.00	0.00	0.00	0.00
112	0.00	21.12	-11.03	0.00	0.00	0.00	0.00
113	0.00	14.70	-5.48	0.00	0.00	0.00	0.00
114	0.00	-3.40	-6.13	0.00	0.00	0.00	0.00
115	0.01	37.52	-2.57	0.00	0.00	0.00	0.00
116	0.01	37.61	-1.13	0.00	0.00	0.00	0.00
117	0.01	36.51	-3.29	0.00	0.00	0.00	0.00
118	0.01	36.60	-1.85	0.00	0.00	0.00	0.00
119	0.01	37.06	-4.46	0.00	0.00	0.00	0.00
120	0.01	36.75	-4.68	0.00	0.00	0.00	0.00
121	0.01	37.36	0.26	0.00	0.00	0.00	0.00
122	0.01	37.05	0.04	0.00	0.00	0.00	0.00
123	0.00	33.81	-2.35	0.00	0.00	0.00	0.00
124	0.00	33.90	-0.91	0.00	0.00	0.00	0.00
125	0.01	32.80	-3.07	0.00	0.00	0.00	0.00
126	0.01	32.89	-1.63	0.00	0.00	0.00	0.00
127	0.01	33.35	-4.24	0.00	0.00	0.00	0.00
128	0.01	33.05	-4.46	0.00	0.00	0.00	0.00
129	0.01	33.66	0.48	0.00	0.00	0.00	0.00
130	0.01	33.35	0.26	0.00	0.00	0.00	0.00
131	0.01	53.73	-3.04	0.00	0.00	0.00	0.00
132	0.01	53.80	-1.92	0.00	0.00	0.00	0.00
133	0.01	52.97	-3.58	0.00	0.00	0.00	0.00
134	0.01	53.04	-2.46	0.00	0.00	0.00	0.00
135	0.01	53.39	-4.43	0.00	0.00	0.00	0.00
136	0.01	53.15	-4.60	0.00	0.00	0.00	0.00
137	0.01	53.62	-0.89	0.00	0.00	0.00	0.00
138	0.01	53.38	-1.06	0.00	0.00	0.00	0.00
99	101	55.53	2.59	0.00	0.00	0.00	0.00
102	0.01	45.27	2.32	0.00	0.00	0.00	0.00
103	0.00	32.09	8.50	0.00	0.00	0.00	0.00
104	0.00	19.59	10.10	0.00	0.00	0.00	0.00
105	0.00	13.71	5.10	0.00	0.00	0.00	0.00
106	0.00	-3.37	5.84	0.00	0.00	0.00	0.00
107	0.01	61.35	2.30	0.00	0.00	0.00	0.00
108	0.01	56.17	2.35	0.00	0.00	0.00	0.00
109	0.00	14.43	0.26	0.00	0.00	0.00	0.00
110	0.00	-2.48	-0.20	0.00	0.00	0.00	0.00
111	0.01	57.20	-3.73	0.00	0.00	0.00	0.00
112	0.01	50.99	-5.19	0.00	0.00	0.00	0.00
113	0.01	28.77	-2.72	0.00	0.00	0.00	0.00
114	0.01	15.45	-3.93	0.00	0.00	0.00	0.00

□

SUPPORT REACTIONS -UNIT KN METE STRUCTURE TYPE = SPACE

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM-Z
115	0.00	35.55	0.85	0.00	0.00	0.00	0.00
116	0.00	35.45	2.27	0.00	0.00	0.00	0.00
117	0.01	34.58	1.85	0.00	0.00	0.00	0.00
118	0.01	34.48	3.27	0.00	0.00	0.00	0.00
119	0.01	35.33	-0.41	0.00	0.00	0.00	0.00
120	0.01	35.03	-0.10	0.00	0.00	0.00	0.00
121	0.01	35.00	4.22	0.00	0.00	0.00	0.00
122	0.01	34.71	4.53	0.00	0.00	0.00	0.00
123	0.00	32.05	0.65	0.00	0.00	0.00	0.00
124	0.00	31.95	2.06	0.00	0.00	0.00	0.00
125	0.01	31.08	1.65	0.00	0.00	0.00	0.00
126	0.01	30.98	3.06	0.00	0.00	0.00	0.00
127	0.01	31.83	-0.61	0.00	0.00	0.00	0.00
128	0.01	31.53	-0.31	0.00	0.00	0.00	0.00
129	0.01	31.50	4.02	0.00	0.00	0.00	0.00
130	0.01	31.20	4.32	0.00	0.00	0.00	0.00
131	0.01	50.81	1.53	0.00	0.00	0.00	0.00
132	0.01	50.73	2.63	0.00	0.00	0.00	0.00
133	0.01	50.08	2.28	0.00	0.00	0.00	0.00
134	0.01	50.00	3.38	0.00	0.00	0.00	0.00
135	0.01	50.64	0.60	0.00	0.00	0.00	0.00
136	0.01	50.41	0.84	0.00	0.00	0.00	0.00
137	0.01	50.40	4.07	0.00	0.00	0.00	0.00
138	0.01	50.17	4.31	0.00	0.00	0.00	0.00
100	101	58.81	-2.78	0.00	0.00	0.00	0.00
102	-0.01	47.94	-2.45	0.00	0.00	0.00	0.00
103	-0.01	60.30	4.21	0.00	0.00	0.00	0.00
104	-0.01	53.61	5.94	0.00	0.00	0.00	0.00
105	-0.01	30.25	3.08	0.00	0.00	0.00	0.00
106	-0.01	16.06	4.53	0.00	0.00	0.00	0.00
107	-0.01	64.97	-2.58	0.00	0.00	0.00	0.00
108	-0.01	59.45	-2.56	0.00	0.00	0.00	0.00
109	-0.01	15.23	-0.19	0.00	0.00	0.00	0.00
110	-0.01	-2.73	0.43	0.00	0.00	0.00	0.00
111	0.00	34.37	-9.40	0.00	0.00	0.00	0.00
112	0.00	21.20	-11.08	0.00	0.00	0.00	0.00
113	0.00	10.26	0.67	0.00	0.00	0.00	0.00
114	0.00	-8.93	1.51	0.00	0.00	0.00	0.00
115	-0.01	36.50	-3.20	0.00	0.00	0.00	0.00
116	-0.01	36.60	-1.76	0.00	0.00	0.00	0.00
117	-0.01	37.51	-2.47	0.00	0.00	0.00	0.00
118	-0.01	37.61	-1.03	0.00	0.00	0.00	0.00
119	-0.01	36.75	-4.58	0.00	0.00	0.00	0.00
120	-0.01	37.06	-4.36	0.00	0.00	0.00	0.00
121	-0.01	37.05	0.13	0.00	0.00	0.00	0.00
122	-0.01	37.36	0.36	0.00	0.00	0.00	0.00
123	-0.01	32.80	-2.99	0.00	0.00	0.00	0.00
124	-0.01	32.89	-1.55	0.00	0.00	0.00	0.00

□

SUPPORT REACTIONS -UNIT KN METE STRUCTURE TYPE = SPACE

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM-Z
□	125	0.00	33.81	-2.26	0.00	0.00	0.00
	126	0.00	33.90	-0.82	0.00	0.00	0.00
	127	-0.01	33.04	-4.37	0.00	0.00	0.00
	128	-0.01	33.35	-4.15	0.00	0.00	0.00
	129	-0.01	33.35	0.35	0.00	0.00	0.00
	130	-0.01	33.66	0.57	0.00	0.00	0.00
	131	-0.01	52.96	-3.45	0.00	0.00	0.00
	132	-0.01	53.03	-2.33	0.00	0.00	0.00
	133	-0.01	53.72	-2.90	0.00	0.00	0.00
	134	-0.01	53.79	-1.79	0.00	0.00	0.00
	135	-0.01	53.14	-4.47	0.00	0.00	0.00
	136	-0.01	53.38	-4.30	0.00	0.00	0.00
	137	-0.01	53.37	-0.93	0.00	0.00	0.00
	138	-0.01	53.61	-0.76	0.00	0.00	0.00
101	101	-0.01	55.53	2.66	0.00	0.00	0.00
	102	-0.01	45.27	2.38	0.00	0.00	0.00
	103	0.00	32.09	8.59	0.00	0.00	0.00
	104	0.00	19.59	10.18	0.00	0.00	0.00
	105	0.00	13.71	5.14	0.00	0.00	0.00
	106	0.00	-3.38	5.86	0.00	0.00	0.00
	107	-0.01	61.35	2.39	0.00	0.00	0.00
	108	-0.01	56.17	2.43	0.00	0.00	0.00
	109	0.00	14.43	0.28	0.00	0.00	0.00
	110	0.00	-2.48	-0.21	0.00	0.00	0.00
	111	-0.01	57.26	-3.61	0.00	0.00	0.00
	112	-0.01	51.06	-5.07	0.00	0.00	0.00
	113	-0.01	24.70	-8.53	0.00	0.00	0.00
	114	-0.01	10.36	-11.22	0.00	0.00	0.00
	115	-0.01	34.58	1.89	0.00	0.00	0.00
	116	-0.01	34.48	3.31	0.00	0.00	0.00
103	117	0.00	35.55	0.90	0.00	0.00	0.00
	118	0.00	35.45	2.31	0.00	0.00	0.00
	119	-0.01	35.03	-0.06	0.00	0.00	0.00
	120	-0.01	35.33	-0.37	0.00	0.00	0.00
	121	-0.01	34.70	4.57	0.00	0.00	0.00
	122	-0.01	35.00	4.27	0.00	0.00	0.00
	123	-0.01	31.08	1.68	0.00	0.00	0.00
	124	-0.01	30.98	3.10	0.00	0.00	0.00
	125	0.00	32.05	0.69	0.00	0.00	0.00
	126	0.00	31.95	2.10	0.00	0.00	0.00
	127	-0.01	31.53	-0.27	0.00	0.00	0.00
	128	-0.01	31.82	-0.58	0.00	0.00	0.00
	129	-0.01	31.20	4.36	0.00	0.00	0.00
	130	-0.01	31.50	4.06	0.00	0.00	0.00
	131	-0.01	50.07	2.34	0.00	0.00	0.00
	132	-0.01	50.00	3.44	0.00	0.00	0.00
	133	-0.01	50.81	1.60	0.00	0.00	0.00
	134	-0.01	50.73	2.69	0.00	0.00	0.00

□

SUPPORT REACTIONS -UNIT KN METE STRUCTURE TYPE = SPACE

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM-Z
□	135	-0.01	50.41	0.90	0.00	0.00	0.00
	136	-0.01	50.64	0.67	0.00	0.00	0.00
	137	-0.01	50.17	4.37	0.00	0.00	0.00
	138	-0.01	50.40	4.14	0.00	0.00	0.00
	102	101	-3.32	70.19	-13.12	0.00	0.00
	102	102	-2.57	57.16	-10.78	0.00	0.00
	103	103	-3.91	71.13	-5.22	0.00	0.00
	104	104	-3.39	62.86	-1.86	0.00	0.00
	105	105	-1.68	35.40	-1.47	0.00	0.00
	106	106	-0.60	18.20	2.83	0.00	0.00
	107	107	-3.89	77.59	-14.18	0.00	0.00
	108	108	-3.37	70.94	-13.07	0.00	0.00
	109	109	-0.43	17.88	-2.77	0.00	0.00
	110	110	0.96	-3.70	1.20	0.00	0.00
101	111	-1.45	41.91	-16.48	0.00	0.00	0.00
	112	-0.32	26.33	-15.93	0.00	0.00	0.00
	113	-0.19	13.48	-2.40	0.00	0.00	0.00
	114	1.26	-9.20	1.66	0.00	0.00	0.00
	115	-8.01	44.57	-9.13	0.00	0.00	0.00
	116	-8.01	44.66	-7.74	0.00	0.00	0.00
	117	4.36	43.61	-9.16	0.00	0.00	0.00
	118	4.36	43.70	-7.78	0.00	0.00	0.00
	119	-3.72	44.14	-10.71	0.00	0.00	0.00
	120	0.06	43.85	-10.72	0.00	0.00	0.00
	121	-3.71	44.42	-6.18	0.00	0.00	0.00
	122	0.07	44.13	-6.19	0.00	0.00	0.00
	123	-7.83	40.16	-8.28	0.00	0.00	0.00
	124	-7.83	40.24	-6.90	0.00	0.00	0.00
	125	4.54	39.20	-8.31	0.00	0.00	0.00
	126	4.55	39.28	-6.93	0.00	0.00	0.00
103	127	-3.54	39.73	-9.87	0.00	0.00	0.00
	128	0.24	39.44	-9.88	0.00	0.00	0.00
	129	-3.53	40.01	-5.34	0.00	0.00	0.00
	130	0.25	39.71	-5.35	0.00	0.00	0.00
	131	-7.59	64.00	-12.47	0.00	0.00	0.00
	132	-7.59	64.07	-11.40	0.00	0.00	0.00
	133	1.69	63.28	-12.50	0.00	0.00	0.00
	134	1.69	63.35	-11.43	0.00	0.00	0.00
	135	-4.41	63.69	-13.64	0.00	0.00	0.00
	136	-1.49	63.46	-13.65	0.00	0.00	0.00
	137	-4.40	63.89	-10.25	0.00	0.00	0.00
	138	-1.48	63.66	-10.25	0.00	0.00	0.00
	103	101	-3.29	66.63	12.50	0.00	0.00
	103	102	-2.54	54.28	10.32	0.00	0.00
	103	103	-1.44	39.36	15.35	0.00	0.00
	104	-0.31	24.49	14.82	0.00	0.00	0.00
	105	-0.21	16.82	8.01	0.00	0.00	0.00
	106	1.23	-3.69	5.65	0.00	0.00	0.00

□

SUPPORT REACTIONS -UNIT KN METE STRUCTURE TYPE = SPACE

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM-Z
107		-3.86	73.67	13.45	0.00	0.00	0.00
108		-3.33	67.37	12.44	0.00	0.00	0.00
109		-0.41	17.02	2.73	0.00	0.00	0.00
110		0.98	-3.44	-0.96	0.00	0.00	0.00
111		-3.87	67.92	5.36	0.00	0.00	0.00
112		-3.35	60.19	2.33	0.00	0.00	0.00
113		-1.62	29.75	-4.19	0.00	0.00	0.00
114		-0.53	12.48	-9.60	0.00	0.00	0.00
115		-7.53	42.41	7.44	0.00	0.00	0.00
116		-7.54	42.32	8.80	0.00	0.00	0.00
117		3.94	41.52	7.47	0.00	0.00	0.00
118		3.94	41.43	8.83	0.00	0.00	0.00
119		-3.55	42.20	5.91	0.00	0.00	0.00
120		-0.04	41.93	5.92	0.00	0.00	0.00
121		-3.55	41.91	10.35	0.00	0.00	0.00
122		-0.05	41.64	10.36	0.00	0.00	0.00
123		-7.35	38.22	6.63	0.00	0.00	0.00
124		-7.36	38.13	7.98	0.00	0.00	0.00
125		4.12	37.33	6.66	0.00	0.00	0.00
126		4.12	37.24	8.02	0.00	0.00	0.00
127		-3.37	38.01	5.09	0.00	0.00	0.00
128		0.14	37.74	5.10	0.00	0.00	0.00
129		-3.37	37.72	9.54	0.00	0.00	0.00
130		0.13	37.45	9.55	0.00	0.00	0.00
131		-7.22	60.82	10.87	0.00	0.00	0.00
132		-7.22	60.75	11.92	0.00	0.00	0.00
133		1.39	60.15	10.90	0.00	0.00	0.00
134		1.39	60.08	11.95	0.00	0.00	0.00
135		-4.27	60.67	9.74	0.00	0.00	0.00
136		-1.56	60.46	9.75	0.00	0.00	0.00
137		-4.27	60.45	13.07	0.00	0.00	0.00
138		-1.56	60.24	13.08	0.00	0.00	0.00
104	101	22.34	44.19	-7.93	0.00	0.00	0.00
102	102	17.34	37.81	-7.34	0.00	0.00	0.00
103	25.70	50.61	-8.97	0.00	0.00	0.00	0.00
104	22.12	50.50	-10.04	0.00	0.00	0.00	0.00
105	10.82	42.47	-8.21	0.00	0.00	0.00	0.00
106	3.52	40.32	-9.08	0.00	0.00	0.00	0.00
107	25.40	56.05	-8.64	0.00	0.00	0.00	0.00
108	21.75	57.30	-9.62	0.00	0.00	0.00	0.00
109	2.52	38.06	-7.52	0.00	0.00	0.00	0.00
110	-6.85	34.81	-8.22	0.00	0.00	0.00	0.00
111	11.22	2.22	-1.33	0.00	0.00	0.00	0.00
112	4.02	-9.99	-0.49	0.00	0.00	0.00	0.00
113	2.72	2.81	-2.37	0.00	0.00	0.00	0.00
114	-6.60	-9.26	-1.79	0.00	0.00	0.00	0.00
115	2.48	30.73	-7.95	0.00	0.00	0.00	0.00
116	2.47	31.51	-5.63	0.00	0.00	0.00	0.00

□

SUPPORT REACTIONS -UNIT KN METE STRUCTURE TYPE = SPACE

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM-Z
117		22.21	31.34	-7.88	0.00	0.00	0.00
118		22.20	32.13	-5.56	0.00	0.00	0.00
119		9.35	30.05	-10.56	0.00	0.00	0.00
120		15.38	30.24	-10.54	0.00	0.00	0.00
121		9.31	32.61	-2.97	0.00	0.00	0.00
122		15.33	32.80	-2.94	0.00	0.00	0.00
123		1.25	27.58	-7.27	0.00	0.00	0.00
124		1.24	28.37	-4.95	0.00	0.00	0.00
125		20.98	28.20	-7.20	0.00	0.00	0.00
126		20.97	28.98	-4.88	0.00	0.00	0.00
127		8.11	26.91	-9.89	0.00	0.00	0.00
128		14.14	27.10	-9.86	0.00	0.00	0.00
129		8.07	29.47	-2.29	0.00	0.00	0.00
130		14.10	29.66	-2.27	0.00	0.00	0.00
131		12.45	40.46	-8.56	0.00	0.00	0.00
132		12.44	41.07	-6.77	0.00	0.00	0.00
133		27.25	40.93	-8.51	0.00	0.00	0.00
134		27.24	41.53	-6.71	0.00	0.00	0.00
135		17.53	39.96	-10.49	0.00	0.00	0.00
136		22.19	40.11	-10.48	0.00	0.00	0.00
137		17.50	41.89	-4.80	0.00	0.00	0.00
138		22.16	42.03	-4.78	0.00	0.00	0.00
105	101	22.47	45.52	8.24	0.00	0.00	0.00
102	17.44	38.86	7.58	0.00	0.00	0.00	0.00
103	11.29	2.91	1.51	0.00	0.00	0.00	0.00
104	4.05	-9.69	0.56	0.00	0.00	0.00	0.00
105	2.71	3.02	2.39	0.00	0.00	0.00	0.00
106	-6.67	-9.55	1.66	0.00	0.00	0.00	0.00
107	25.55	57.55	9.03	0.00	0.00	0.00	0.00
108	21.87	58.61	9.96	0.00	0.00	0.00	0.00
109	2.52	38.28	7.57	0.00	0.00	0.00	0.00
110	-6.91	34.52	8.14	0.00	0.00	0.00	0.00
111	25.85	52.11	9.26	0.00	0.00	0.00	0.00
112	22.24	51.81	10.25	0.00	0.00	0.00	0.00
113	10.88	43.14	8.34	0.00	0.00	0.00	0.00
114	3.54	40.59	9.10	0.00	0.00	0.00	0.00
115	2.31	32.27	5.77	0.00	0.00	0.00	0.00
116	2.32	31.49	8.13	0.00	0.00	0.00	0.00
117	22.49	32.90	5.70	0.00	0.00	0.00	0.00
118	22.50	32.12	8.06	0.00	0.00	0.00	0.00
119	9.31	33.38	3.07	0.00	0.00	0.00	0.00
120	15.47	33.57	3.05	0.00	0.00	0.00	0.00
121	9.34	30.82	10.78	0.00	0.00	0.00	0.00
122	15.51	31.01	10.76	0.00	0.00	0.00	0.00
123	1.07	29.05	5.08	0.00	0.00	0.00	0.00
124	1.08	28.27	7.43	0.00	0.00	0.00	0.00
125	21.25	29.68	5.01	0.00	0.00	0.00	0.00
126	21.26	28.90	7.37	0.00	0.00	0.00	0.00

□

SUPPORT REACTIONS -UNIT KN METE STRUCTURE TYPE = SPACE

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM-Z
106	127	8.06	30.16	2.38	0.00	0.00	0.00
	128	14.23	30.35	2.36	0.00	0.00	0.00
	129	8.10	27.60	10.09	0.00	0.00	0.00
	130	14.27	27.79	10.07	0.00	0.00	0.00
	131	12.38	42.26	7.02	0.00	0.00	0.00
	132	12.39	41.65	8.84	0.00	0.00	0.00
	133	27.52	42.73	6.97	0.00	0.00	0.00
	134	27.53	42.13	8.79	0.00	0.00	0.00
	135	17.56	43.08	5.03	0.00	0.00	0.00
	136	22.32	43.23	5.01	0.00	0.00	0.00
	137	17.59	41.16	10.81	0.00	0.00	0.00
	138	22.35	41.31	10.79	0.00	0.00	0.00
	101	0.50	52.43	-13.66	0.00	0.00	0.00
	102	0.74	45.13	-12.32	0.00	0.00	0.00
	103	0.03	59.87	-14.13	0.00	0.00	0.00
	104	0.51	60.24	-14.98	0.00	0.00	0.00
107	105	0.72	52.34	-11.95	0.00	0.00	0.00
	106	1.37	50.82	-12.25	0.00	0.00	0.00
	107	0.04	67.33	-14.90	0.00	0.00	0.00
	108	0.52	69.56	-15.94	0.00	0.00	0.00
	109	1.10	48.42	-10.83	0.00	0.00	0.00
	110	1.85	45.92	-10.85	0.00	0.00	0.00
	111	0.74	0.62	-4.60	0.00	0.00	0.00
	112	1.39	-13.83	-3.06	0.00	0.00	0.00
	113	1.13	2.89	-4.53	0.00	0.00	0.00
	114	1.88	-10.99	-2.98	0.00	0.00	0.00
	115	0.14	38.05	-10.75	0.00	0.00	0.00
	116	0.14	38.99	-7.97	0.00	0.00	0.00
	117	1.81	36.66	-13.99	0.00	0.00	0.00
	118	1.81	37.61	-11.21	0.00	0.00	0.00
	119	0.72	36.50	-15.02	0.00	0.00	0.00
	120	1.23	36.08	-16.01	0.00	0.00	0.00
108	121	0.72	39.58	-5.95	0.00	0.00	0.00
	122	1.23	39.16	-6.94	0.00	0.00	0.00
	123	0.04	34.27	-9.65	0.00	0.00	0.00
	124	0.04	35.21	-6.88	0.00	0.00	0.00
	125	1.71	32.88	-12.89	0.00	0.00	0.00
	126	1.71	33.82	-10.12	0.00	0.00	0.00
	127	0.62	32.72	-13.92	0.00	0.00	0.00
	128	1.13	32.29	-14.91	0.00	0.00	0.00
	129	0.62	35.80	-4.85	0.00	0.00	0.00
	130	1.13	35.37	-5.84	0.00	0.00	0.00
	131	-0.01	48.94	-12.85	0.00	0.00	0.00
	132	-0.01	49.66	-10.71	0.00	0.00	0.00
	133	1.25	47.90	-15.28	0.00	0.00	0.00
	134	1.25	48.62	-13.14	0.00	0.00	0.00
	135	0.42	47.79	-16.01	0.00	0.00	0.00
	136	0.82	47.46	-16.78	0.00	0.00	0.00

□

SUPPORT REACTIONS -UNIT KN METE STRUCTURE TYPE = SPACE

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM-Z
107	137	0.42	50.10	-9.21	0.00	0.00	0.00
	138	0.82	49.77	-9.97	0.00	0.00	0.00
	101	0.55	54.09	13.69	0.00	0.00	0.00
	102	0.78	46.45	12.33	0.00	0.00	0.00
	103	0.76	1.53	4.51	0.00	0.00	0.00
	104	1.41	-13.36	2.91	0.00	0.00	0.00
	105	1.15	3.22	4.45	0.00	0.00	0.00
	106	1.89	-11.25	2.84	0.00	0.00	0.00
	107	0.09	69.17	14.98	0.00	0.00	0.00
	108	0.57	71.19	16.00	0.00	0.00	0.00
	109	1.12	48.74	10.83	0.00	0.00	0.00
	110	1.86	45.65	10.80	0.00	0.00	0.00
	111	0.08	61.67	14.23	0.00	0.00	0.00
	112	0.56	61.81	15.06	0.00	0.00	0.00
	113	0.75	53.18	11.96	0.00	0.00	0.00
	114	1.40	51.20	12.22	0.00	0.00	0.00
108	115	0.15	39.96	8.02	0.00	0.00	0.00
	116	0.15	39.02	10.83	0.00	0.00	0.00
	117	1.86	38.61	11.11	0.00	0.00	0.00
	118	1.86	37.67	13.92	0.00	0.00	0.00
	119	0.75	40.56	5.90	0.00	0.00	0.00
	120	1.27	40.14	6.84	0.00	0.00	0.00
	121	0.75	37.48	15.09	0.00	0.00	0.00
	122	1.27	37.07	16.03	0.00	0.00	0.00
	123	0.05	36.08	6.92	0.00	0.00	0.00
	124	0.05	35.14	9.73	0.00	0.00	0.00
	125	1.76	34.73	10.01	0.00	0.00	0.00
	126	1.76	33.79	12.82	0.00	0.00	0.00
	127	0.65	36.67	4.80	0.00	0.00	0.00
	128	1.17	36.26	5.74	0.00	0.00	0.00
	129	0.65	33.60	13.99	0.00	0.00	0.00
	130	1.17	33.19	14.94	0.00	0.00	0.00
109	131	0.02	51.14	10.77	0.00	0.00	0.00
	132	0.02	50.41	12.94	0.00	0.00	0.00
	133	1.31	50.12	13.08	0.00	0.00	0.00
	134	1.31	49.40	15.26	0.00	0.00	0.00
	135	0.46	51.58	9.20	0.00	0.00	0.00
	136	0.87	51.26	9.93	0.00	0.00	0.00
	137	0.46	49.27	16.09	0.00	0.00	0.00
	138	0.87	48.96	16.82	0.00	0.00	0.00
	101	-0.50	52.43	-13.72	0.00	0.00	0.00
	102	-0.73	45.13	-12.37	0.00	0.00	0.00
	103	-0.03	59.87	-14.19	0.00	0.00	0.00
	104	-0.50	60.24	-15.04	0.00	0.00	0.00
	105	-0.72	52.34	-11.98	0.00	0.00	0.00
	106	-1.37	50.83	-12.27	0.00	0.00	0.00
	107	-0.03	67.33	-14.96	0.00	0.00	0.00
	108	-0.51	69.56	-16.00	0.00	0.00	0.00

□

SUPPORT REACTIONS -UNIT KN METE STRUCTURE TYPE = SPACE

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM-Z
109	-1.10	48.43	-10.85	0.00	0.00	0.00	0.00
110	-1.85	45.94	-10.86	0.00	0.00	0.00	0.00
111	-0.73	0.62	-4.61	0.00	0.00	0.00	0.00
112	-1.39	-13.83	-3.06	0.00	0.00	0.00	0.00
113	-1.12	3.41	-5.70	0.00	0.00	0.00	0.00
114	-1.88	-10.34	-4.43	0.00	0.00	0.00	0.00
115	-1.79	36.68	-14.01	0.00	0.00	0.00	0.00
116	-1.79	37.62	-11.24	0.00	0.00	0.00	0.00
117	-0.14	38.05	-10.80	0.00	0.00	0.00	0.00
118	-0.14	38.99	-8.02	0.00	0.00	0.00	0.00
119	-1.22	36.08	-16.05	0.00	0.00	0.00	0.00
120	-0.72	36.50	-15.07	0.00	0.00	0.00	0.00
121	-1.22	39.17	-6.97	0.00	0.00	0.00	0.00
122	-0.72	39.59	-5.99	0.00	0.00	0.00	0.00
123	-1.70	32.89	-12.91	0.00	0.00	0.00	0.00
124	-1.70	33.84	-10.14	0.00	0.00	0.00	0.00
125	-0.05	34.27	-9.69	0.00	0.00	0.00	0.00
126	-0.05	35.21	-6.92	0.00	0.00	0.00	0.00
127	-1.12	32.30	-14.95	0.00	0.00	0.00	0.00
128	-0.62	32.72	-13.96	0.00	0.00	0.00	0.00
129	-1.12	35.38	-5.87	0.00	0.00	0.00	0.00
130	-0.62	35.80	-4.88	0.00	0.00	0.00	0.00
131	-1.23	47.91	-15.32	0.00	0.00	0.00	0.00
132	-1.23	48.63	-13.18	0.00	0.00	0.00	0.00
133	0.00	48.94	-12.91	0.00	0.00	0.00	0.00
134	0.00	49.66	-10.76	0.00	0.00	0.00	0.00
135	-0.81	47.47	-16.83	0.00	0.00	0.00	0.00
136	-0.42	47.79	-16.07	0.00	0.00	0.00	0.00
137	-0.81	49.78	-10.02	0.00	0.00	0.00	0.00
138	-0.42	50.10	-9.26	0.00	0.00	0.00	0.00
109	101	-0.55	54.06	13.76	0.00	0.00	0.00
102	-0.78	46.43	12.38	0.00	0.00	0.00	0.00
103	-0.76	1.51	4.59	0.00	0.00	0.00	0.00
104	-1.41	-13.38	2.98	0.00	0.00	0.00	0.00
105	-1.15	3.21	4.49	0.00	0.00	0.00	0.00
106	-1.89	-11.26	2.86	0.00	0.00	0.00	0.00
107	-0.09	69.14	15.06	0.00	0.00	0.00	0.00
108	-0.57	71.16	16.07	0.00	0.00	0.00	0.00
109	-1.12	48.73	10.84	0.00	0.00	0.00	0.00
110	-1.86	45.65	10.80	0.00	0.00	0.00	0.00
111	-0.08	61.65	14.25	0.00	0.00	0.00	0.00
112	-0.56	61.79	15.06	0.00	0.00	0.00	0.00
113	-0.75	53.73	12.96	0.00	0.00	0.00	0.00
114	-1.40	51.89	13.45	0.00	0.00	0.00	0.00
115	-1.86	38.60	11.14	0.00	0.00	0.00	0.00
116	-1.86	37.66	13.96	0.00	0.00	0.00	0.00
117	-0.15	39.94	8.06	0.00	0.00	0.00	0.00
118	-0.15	39.00	10.88	0.00	0.00	0.00	0.00

□

SUPPORT REACTIONS -UNIT KN METE STRUCTURE TYPE = SPACE

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM-Z
119	-1.27	40.14	6.87	0.00	0.00	0.00	0.00
120	-0.75	40.55	5.93	0.00	0.00	0.00	0.00
121	-1.27	37.05	16.09	0.00	0.00	0.00	0.00
122	-0.75	37.46	15.15	0.00	0.00	0.00	0.00
123	-1.76	34.72	10.04	0.00	0.00	0.00	0.00
124	-1.76	33.78	12.85	0.00	0.00	0.00	0.00
125	-0.05	36.06	6.96	0.00	0.00	0.00	0.00
126	-0.05	35.12	9.77	0.00	0.00	0.00	0.00
127	-1.17	36.26	5.77	0.00	0.00	0.00	0.00
128	-0.65	36.67	4.83	0.00	0.00	0.00	0.00
129	-1.17	33.17	14.99	0.00	0.00	0.00	0.00
130	-0.65	33.58	14.04	0.00	0.00	0.00	0.00
131	-1.31	50.11	13.14	0.00	0.00	0.00	0.00
132	-1.31	49.38	15.32	0.00	0.00	0.00	0.00
133	-0.02	51.12	10.83	0.00	0.00	0.00	0.00
134	-0.02	50.39	13.01	0.00	0.00	0.00	0.00
135	-0.87	51.24	9.98	0.00	0.00	0.00	0.00
136	-0.46	51.56	9.25	0.00	0.00	0.00	0.00
137	-0.87	48.93	16.89	0.00	0.00	0.00	0.00
138	-0.46	49.25	16.17	0.00	0.00	0.00	0.00
110	101	-22.26	44.19	-7.93	0.00	0.00	0.00
102	-17.27	37.81	-7.34	0.00	0.00	0.00	0.00
103	-25.60	50.61	-8.97	0.00	0.00	0.00	0.00
104	-22.03	50.50	-10.04	0.00	0.00	0.00	0.00
105	-10.77	42.47	-8.21	0.00	0.00	0.00	0.00
106	-3.49	40.32	-9.08	0.00	0.00	0.00	0.00
107	-25.30	56.05	-8.64	0.00	0.00	0.00	0.00
108	-21.66	57.30	-9.62	0.00	0.00	0.00	0.00
109	-2.50	38.06	-7.52	0.00	0.00	0.00	0.00
110	6.84	34.81	-8.22	0.00	0.00	0.00	0.00
111	-11.17	2.21	-1.31	0.00	0.00	0.00	0.00
112	-4.00	-10.00	-0.46	0.00	0.00	0.00	0.00
113	-2.68	3.31	-3.55	0.00	0.00	0.00	0.00
114	6.62	-8.63	-3.26	0.00	0.00	0.00	0.00
115	-22.09	31.34	-7.88	0.00	0.00	0.00	0.00
116	-22.08	32.12	-5.56	0.00	0.00	0.00	0.00
117	-2.49	30.73	-7.95	0.00	0.00	0.00	0.00
118	-2.48	31.51	-5.63	0.00	0.00	0.00	0.00
119	-15.30	30.24	-10.54	0.00	0.00	0.00	0.00
120	-9.31	30.05	-10.56	0.00	0.00	0.00	0.00
121	-15.26	32.80	-2.95	0.00	0.00	0.00	0.00
122	-9.27	32.61	-2.97	0.00	0.00	0.00	0.00
123	-20.86	28.20	-7.20	0.00	0.00	0.00	0.00
124	-20.85	28.98	-4.88	0.00	0.00	0.00	0.00
125	-1.27	27.58	-7.27	0.00	0.00	0.00	0.00
126	-1.25	28.37	-4.95	0.00	0.00	0.00	0.00
127	-14.07	27.09	-9.86	0.00	0.00	0.00	0.00
128	-8.08	26.91	-9.88	0.00	0.00	0.00	0.00

□

SUPPORT REACTIONS -UNIT KN METE STRUCTURE TYPE = SPACE

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM-Z
□	129	-14.03	29.66	-2.27	0.00	0.00	0.00
	130	-8.04	29.47	-2.29	0.00	0.00	0.00
	131	-27.12	40.92	-8.51	0.00	0.00	0.00
	132	-27.11	41.53	-6.71	0.00	0.00	0.00
	133	-12.42	40.46	-8.56	0.00	0.00	0.00
	134	-12.41	41.07	-6.77	0.00	0.00	0.00
	135	-22.09	40.11	-10.48	0.00	0.00	0.00
	136	-17.46	39.96	-10.49	0.00	0.00	0.00
	137	-22.06	42.03	-4.78	0.00	0.00	0.00
	138	-17.43	41.89	-4.80	0.00	0.00	0.00
	111	101	-22.47	45.52	8.24	0.00	0.00
	102	-17.44	38.86	7.58	0.00	0.00	0.00
	103	-11.29	2.91	1.51	0.00	0.00	0.00
	104	-4.05	-9.69	0.56	0.00	0.00	0.00
	105	-2.72	3.02	2.39	0.00	0.00	0.00
	106	6.67	-9.55	1.66	0.00	0.00	0.00
	107	-25.55	57.55	9.03	0.00	0.00	0.00
	108	-21.87	58.61	9.96	0.00	0.00	0.00
	109	-2.52	38.28	7.57	0.00	0.00	0.00
	110	6.91	34.52	8.14	0.00	0.00	0.00
	111	-25.85	52.10	9.25	0.00	0.00	0.00
	112	-22.25	51.80	10.23	0.00	0.00	0.00
	113	-10.87	43.69	9.34	0.00	0.00	0.00
	114	-3.53	41.29	10.35	0.00	0.00	0.00
	115	-22.49	32.90	5.70	0.00	0.00	0.00
	116	-22.50	32.12	8.06	0.00	0.00	0.00
	117	-2.32	32.27	5.77	0.00	0.00	0.00
	118	-2.33	31.49	8.12	0.00	0.00	0.00
	119	-15.47	33.57	3.06	0.00	0.00	0.00
	120	-9.31	33.38	3.08	0.00	0.00	0.00
	121	-15.51	31.01	10.75	0.00	0.00	0.00
	122	-9.35	30.82	10.77	0.00	0.00	0.00
	123	-21.25	29.68	5.01	0.00	0.00	0.00
	124	-21.26	28.90	7.36	0.00	0.00	0.00
	125	-1.08	29.05	5.08	0.00	0.00	0.00
	126	-1.09	28.27	7.43	0.00	0.00	0.00
	127	-14.23	30.35	2.37	0.00	0.00	0.00
	128	-8.07	30.16	2.39	0.00	0.00	0.00
	129	-14.27	27.79	10.06	0.00	0.00	0.00
	130	-8.11	27.60	10.08	0.00	0.00	0.00
	131	-27.52	42.73	6.97	0.00	0.00	0.00
	132	-27.53	42.13	8.79	0.00	0.00	0.00
	133	-12.39	42.26	7.03	0.00	0.00	0.00
	134	-12.40	41.65	8.84	0.00	0.00	0.00
	135	-22.33	43.22	5.02	0.00	0.00	0.00
	136	-17.56	43.08	5.03	0.00	0.00	0.00
	137	-22.35	41.31	10.79	0.00	0.00	0.00
	138	-17.59	41.16	10.80	0.00	0.00	0.00

□

SUPPORT REACTIONS -UNIT KN METE STRUCTURE TYPE = SPACE

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM-Z
□	112	101	-0.01	2.30	0.41	0.00	0.00
	102	102	0.02	2.12	1.37	0.00	0.00
	103	103	-0.03	5.07	-5.31	0.00	0.00
	104	104	0.00	5.98	-4.71	0.00	0.00
	105	105	0.04	11.69	-10.32	0.00	0.00
	106	106	0.10	14.25	-10.97	0.00	0.00
	107	107	-0.02	9.27	-9.30	0.00	0.00
	108	108	0.01	11.24	-9.70	0.00	0.00
	109	109	0.09	15.65	-13.19	0.00	0.00
	110	110	0.15	19.21	-14.56	0.00	0.00
	111	111	-0.01	-13.83	20.02	0.00	0.00
	112	112	0.03	-17.65	26.96	0.00	0.00
	113	113	0.04	-6.93	13.04	0.00	0.00
	114	114	0.09	-9.01	18.23	0.00	0.00
	115	115	0.01	2.02	1.77	0.00	0.00
	116	116	0.01	1.84	2.91	0.00	0.00
	117	117	0.06	2.04	1.76	0.00	0.00
	118	118	0.06	1.86	2.90	0.00	0.00
	119	119	0.03	2.23	0.47	0.00	0.00
	120	120	0.04	2.24	0.47	0.00	0.00
	121	121	0.03	1.65	4.20	0.00	0.00
	122	122	0.04	1.65	4.20	0.00	0.00
	123	123	0.01	1.83	1.53	0.00	0.00
	124	124	0.01	1.65	2.67	0.00	0.00
	125	125	0.05	1.85	1.53	0.00	0.00
	126	126	0.05	1.67	2.67	0.00	0.00
	127	127	0.03	2.04	0.24	0.00	0.00
	128	128	0.04	2.04	0.23	0.00	0.00
	129	129	0.03	1.45	3.97	0.00	0.00
	130	130	0.04	1.46	3.97	0.00	0.00
	131	131	-0.01	2.27	0.45	0.00	0.00
	132	132	-0.01	2.14	1.33	0.00	0.00
	133	133	0.02	2.29	0.45	0.00	0.00
	134	134	0.02	2.15	1.33	0.00	0.00
	135	135	0.00	2.43	-0.51	0.00	0.00
	136	136	0.01	2.43	-0.51	0.00	0.00
	137	137	0.00	1.99	2.29	0.00	0.00
	138	138	0.01	1.99	2.29	0.00	0.00
	113	101	-0.01	2.34	-0.12	0.00	0.00
	102	102	0.01	2.15	-1.15	0.00	0.00
	103	103	-0.01	-13.79	-19.80	0.00	0.00
	104	104	0.03	-17.62	-26.82	0.00	0.00
	105	105	0.04	-6.91	-12.99	0.00	0.00
	106	106	0.09	-9.02	-18.30	0.00	0.00
	107	107	-0.02	9.32	9.63	0.00	0.00
	108	108	0.01	11.27	9.97	0.00	0.00
	109	109	0.08	15.64	13.19	0.00	0.00
	110	110	0.15	19.17	14.42	0.00	0.00

□

SUPPORT REACTIONS -UNIT KN METE STRUCTURE TYPE = SPACE

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM-Z
111	-0.03	5.11	5.59	0.00	0.00	0.00	0.00
112	0.00	6.01	4.92	0.00	0.00	0.00	0.00
113	0.04	11.70	10.41	0.00	0.00	0.00	0.00
114	0.09	14.24	10.95	0.00	0.00	0.00	0.00
115	0.01	1.87	-2.77	0.00	0.00	0.00	0.00
116	0.01	2.05	-1.60	0.00	0.00	0.00	0.00
117	0.06	1.88	-2.76	0.00	0.00	0.00	0.00
118	0.06	2.06	-1.60	0.00	0.00	0.00	0.00
119	0.03	1.67	-4.09	0.00	0.00	0.00	0.00
120	0.04	1.67	-4.08	0.00	0.00	0.00	0.00
121	0.03	2.26	-0.28	0.00	0.00	0.00	0.00
122	0.04	2.26	-0.28	0.00	0.00	0.00	0.00
123	0.01	1.67	-2.55	0.00	0.00	0.00	0.00
124	0.01	1.85	-1.39	0.00	0.00	0.00	0.00
125	0.05	1.69	-2.54	0.00	0.00	0.00	0.00
126	0.05	1.87	-1.38	0.00	0.00	0.00	0.00
127	0.02	1.47	-3.87	0.00	0.00	0.00	0.00
128	0.04	1.48	-3.87	0.00	0.00	0.00	0.00
129	0.02	2.06	-0.06	0.00	0.00	0.00	0.00
130	0.04	2.07	-0.06	0.00	0.00	0.00	0.00
131	-0.01	2.17	-1.08	0.00	0.00	0.00	0.00
132	-0.01	2.31	-0.19	0.00	0.00	0.00	0.00
133	0.02	2.19	-1.08	0.00	0.00	0.00	0.00
134	0.02	2.33	-0.18	0.00	0.00	0.00	0.00
135	0.00	2.03	-2.06	0.00	0.00	0.00	0.00
136	0.01	2.03	-2.06	0.00	0.00	0.00	0.00
137	0.00	2.47	0.79	0.00	0.00	0.00	0.00
138	0.01	2.47	0.80	0.00	0.00	0.00	0.00
139	-0.08	3.29	-0.38	0.00	0.00	0.00	0.00
140	-0.08	3.04	1.13	0.00	0.00	0.00	0.00
141	-0.08	6.78	-7.32	0.00	0.00	0.00	0.00
142	-0.08	7.98	-6.12	0.00	0.00	0.00	0.00
143	-0.06	15.42	-13.37	0.00	0.00	0.00	0.00
144	-0.06	18.78	-13.69	0.00	0.00	0.00	0.00
145	-0.08	12.36	-13.27	0.00	0.00	0.00	0.00
146	-0.08	14.96	-13.56	0.00	0.00	0.00	0.00
147	-0.05	20.62	-17.13	0.00	0.00	0.00	0.00
148	-0.05	25.28	-18.38	0.00	0.00	0.00	0.00
149	-0.05	-17.77	25.00	0.00	0.00	0.00	0.00
150	-0.05	-22.71	34.28	0.00	0.00	0.00	0.00
151	-0.04	-8.81	16.66	0.00	0.00	0.00	0.00
152	-0.04	-11.51	23.85	0.00	0.00	0.00	0.00
153	-0.11	2.78	2.77	0.00	0.00	0.00	0.00
154	-0.11	2.57	4.14	0.00	0.00	0.00	0.00
155	-0.03	3.01	1.14	0.00	0.00	0.00	0.00
156	-0.03	2.80	2.51	0.00	0.00	0.00	0.00
157	-0.08	3.10	0.65	0.00	0.00	0.00	0.00
158	-0.06	3.17	0.15	0.00	0.00	0.00	0.00

□

SUPPORT REACTIONS -UNIT KN METE STRUCTURE TYPE = SPACE

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM-Z
121	-0.08	2.41	5.13	0.00	0.00	0.00	0.00
122	-0.06	2.48	4.64	0.00	0.00	0.00	0.00
123	-0.10	2.50	2.51	0.00	0.00	0.00	0.00
124	-0.10	2.29	3.88	0.00	0.00	0.00	0.00
125	-0.02	2.73	0.88	0.00	0.00	0.00	0.00
126	-0.02	2.52	2.25	0.00	0.00	0.00	0.00
127	-0.07	2.82	0.39	0.00	0.00	0.00	0.00
128	-0.05	2.89	-0.11	0.00	0.00	0.00	0.00
129	-0.07	2.13	4.87	0.00	0.00	0.00	0.00
130	-0.05	2.20	4.37	0.00	0.00	0.00	0.00
131	-0.11	3.16	0.45	0.00	0.00	0.00	0.00
132	-0.11	3.00	1.51	0.00	0.00	0.00	0.00
133	-0.05	3.33	-0.77	0.00	0.00	0.00	0.00
134	-0.05	3.17	0.29	0.00	0.00	0.00	0.00
135	-0.09	3.40	-1.12	0.00	0.00	0.00	0.00
136	-0.07	3.45	-1.50	0.00	0.00	0.00	0.00
137	-0.09	2.88	2.25	0.00	0.00	0.00	0.00
138	-0.07	2.93	1.86	0.00	0.00	0.00	0.00
139	-0.08	3.31	0.55	0.00	0.00	0.00	0.00
140	-0.07	3.06	-1.01	0.00	0.00	0.00	0.00
141	-0.05	-17.74	-24.89	0.00	0.00	0.00	0.00
142	-0.05	-22.68	-34.23	0.00	0.00	0.00	0.00
143	-0.04	-8.80	-16.64	0.00	0.00	0.00	0.00
144	-0.04	-11.51	-23.92	0.00	0.00	0.00	0.00
145	-0.07	12.38	13.46	0.00	0.00	0.00	0.00
146	-0.08	14.97	13.70	0.00	0.00	0.00	0.00
147	-0.05	20.60	17.08	0.00	0.00	0.00	0.00
148	-0.04	25.24	18.24	0.00	0.00	0.00	0.00
149	-0.07	6.81	7.52	0.00	0.00	0.00	0.00
150	-0.08	8.00	6.28	0.00	0.00	0.00	0.00
151	-0.06	15.41	13.40	0.00	0.00	0.00	0.00
152	-0.06	18.75	13.63	0.00	0.00	0.00	0.00
153	-0.11	2.59	-4.04	0.00	0.00	0.00	0.00
154	-0.11	2.80	-2.64	0.00	0.00	0.00	0.00
155	-0.03	2.81	-2.49	0.00	0.00	0.00	0.00
156	-0.02	3.02	-1.10	0.00	0.00	0.00	0.00
157	-0.08	2.42	-5.08	0.00	0.00	0.00	0.00
158	-0.05	2.49	-4.61	0.00	0.00	0.00	0.00
159	-0.08	3.12	-0.52	0.00	0.00	0.00	0.00
160	-0.05	3.19	-0.05	0.00	0.00	0.00	0.00
161	-0.10	2.31	-3.78	0.00	0.00	0.00	0.00
162	-0.10	2.52	-2.39	0.00	0.00	0.00	0.00
163	-0.02	2.52	-2.23	0.00	0.00	0.00	0.00
164	-0.02	2.74	-0.84	0.00	0.00	0.00	0.00
165	-0.07	2.14	-4.83	0.00	0.00	0.00	0.00
166	-0.05	2.21	-4.35	0.00	0.00	0.00	0.00
167	-0.07	2.84	-0.27	0.00	0.00	0.00	0.00
168	-0.05	2.91	0.21	0.00	0.00	0.00	0.00

□

SUPPORT REACTIONS -UNIT KN METE STRUCTURE TYPE = SPACE

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM-Z
131	-0.11	3.02	-1.35	0.00	0.00	0.00	0.00
132	-0.11	3.18	-0.27	0.00	0.00	0.00	0.00
133	-0.05	3.18	-0.19	0.00	0.00	0.00	0.00
134	-0.05	3.35	0.89	0.00	0.00	0.00	0.00
135	-0.09	2.90	-2.12	0.00	0.00	0.00	0.00
136	-0.07	2.95	-1.76	0.00	0.00	0.00	0.00
137	-0.09	3.42	1.30	0.00	0.00	0.00	0.00
138	-0.07	3.47	1.67	0.00	0.00	0.00	0.00
116	101	0.08	3.29	-0.42	0.00	0.00	0.00
102	0.08	3.04	1.10	0.00	0.00	0.00	0.00
103	0.08	6.78	-7.36	0.00	0.00	0.00	0.00
104	0.08	7.98	-6.16	0.00	0.00	0.00	0.00
105	0.06	15.42	-13.40	0.00	0.00	0.00	0.00
106	0.06	18.78	-13.71	0.00	0.00	0.00	0.00
107	0.08	12.36	-13.31	0.00	0.00	0.00	0.00
108	0.08	14.96	-13.59	0.00	0.00	0.00	0.00
109	0.05	20.62	-17.14	0.00	0.00	0.00	0.00
110	0.05	25.28	-18.39	0.00	0.00	0.00	0.00
111	0.05	-17.77	24.99	0.00	0.00	0.00	0.00
112	0.05	-22.71	34.27	0.00	0.00	0.00	0.00
113	0.04	-8.72	15.87	0.00	0.00	0.00	0.00
114	0.04	-11.39	22.88	0.00	0.00	0.00	0.00
115	0.03	3.01	1.12	0.00	0.00	0.00	0.00
116	0.03	2.80	2.49	0.00	0.00	0.00	0.00
117	0.11	2.79	2.74	0.00	0.00	0.00	0.00
118	0.11	2.57	4.11	0.00	0.00	0.00	0.00
119	0.06	3.18	0.13	0.00	0.00	0.00	0.00
120	0.08	3.11	0.62	0.00	0.00	0.00	0.00
121	0.06	2.48	4.61	0.00	0.00	0.00	0.00
122	0.08	2.41	5.11	0.00	0.00	0.00	0.00
123	0.02	2.73	0.86	0.00	0.00	0.00	0.00
124	0.02	2.52	2.23	0.00	0.00	0.00	0.00
125	0.10	2.51	2.48	0.00	0.00	0.00	0.00
126	0.10	2.30	3.85	0.00	0.00	0.00	0.00
127	0.05	2.90	-0.13	0.00	0.00	0.00	0.00
128	0.08	2.83	0.36	0.00	0.00	0.00	0.00
129	0.05	2.20	4.35	0.00	0.00	0.00	0.00
130	0.08	2.13	4.85	0.00	0.00	0.00	0.00
131	0.05	3.33	-0.80	0.00	0.00	0.00	0.00
132	0.05	3.17	0.26	0.00	0.00	0.00	0.00
133	0.11	3.16	0.42	0.00	0.00	0.00	0.00
134	0.11	3.00	1.48	0.00	0.00	0.00	0.00
135	0.07	3.45	-1.53	0.00	0.00	0.00	0.00
136	0.09	3.40	-1.15	0.00	0.00	0.00	0.00
137	0.07	2.93	1.83	0.00	0.00	0.00	0.00
138	0.09	2.88	2.21	0.00	0.00	0.00	0.00
117	101	0.08	3.32	0.58	0.00	0.00	0.00
102	0.07	3.06	-0.98	0.00	0.00	0.00	0.00

□

SUPPORT REACTIONS -UNIT KN METE STRUCTURE TYPE = SPACE

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM-Z
103	0.05	-17.73	-24.85	0.00	0.00	0.00	0.00
104	0.05	-22.67	-34.19	0.00	0.00	0.00	0.00
105	0.04	-8.80	-16.62	0.00	0.00	0.00	0.00
106	0.04	-11.51	-23.91	0.00	0.00	0.00	0.00
107	0.07	12.39	13.49	0.00	0.00	0.00	0.00
108	0.08	14.97	13.74	0.00	0.00	0.00	0.00
109	0.05	20.60	17.09	0.00	0.00	0.00	0.00
110	0.04	25.24	18.23	0.00	0.00	0.00	0.00
111	0.07	6.81	7.52	0.00	0.00	0.00	0.00
112	0.08	8.00	6.27	0.00	0.00	0.00	0.00
113	0.06	15.49	14.10	0.00	0.00	0.00	0.00
114	0.06	18.85	14.49	0.00	0.00	0.00	0.00
115	0.02	2.81	-2.47	0.00	0.00	0.00	0.00
116	0.02	3.02	-1.08	0.00	0.00	0.00	0.00
117	0.11	2.59	-4.02	0.00	0.00	0.00	0.00
118	0.11	2.80	-2.62	0.00	0.00	0.00	0.00
119	0.05	2.49	-4.60	0.00	0.00	0.00	0.00
120	0.08	2.42	-5.07	0.00	0.00	0.00	0.00
121	0.05	3.19	-0.02	0.00	0.00	0.00	0.00
122	0.08	3.12	-0.50	0.00	0.00	0.00	0.00
123	0.02	2.53	-2.22	0.00	0.00	0.00	0.00
124	0.02	2.74	-0.82	0.00	0.00	0.00	0.00
125	0.10	2.31	-3.76	0.00	0.00	0.00	0.00
126	0.10	2.52	-2.37	0.00	0.00	0.00	0.00
127	0.05	2.21	-4.34	0.00	0.00	0.00	0.00
128	0.07	2.14	-4.81	0.00	0.00	0.00	0.00
129	0.05	2.91	0.23	0.00	0.00	0.00	0.00
130	0.07	2.84	-0.24	0.00	0.00	0.00	0.00
131	0.05	3.19	-0.16	0.00	0.00	0.00	0.00
132	0.05	3.35	0.92	0.00	0.00	0.00	0.00
133	0.11	3.02	-1.32	0.00	0.00	0.00	0.00
134	0.11	3.19	-0.24	0.00	0.00	0.00	0.00
135	0.07	2.95	-1.73	0.00	0.00	0.00	0.00
136	0.09	2.90	-2.10	0.00	0.00	0.00	0.00
137	0.07	3.48	1.70	0.00	0.00	0.00	0.00
138	0.09	3.43	1.33	0.00	0.00	0.00	0.00
118	101	0.01	2.30	0.41	0.00	0.00	0.00
102	-0.02	2.12	1.37	0.00	0.00	0.00	0.00
103	0.03	5.07	-5.31	0.00	0.00	0.00	0.00
104	0.00	5.98	-4.71	0.00	0.00	0.00	0.00
105	-0.04	11.69	-10.32	0.00	0.00	0.00	0.00
106	-0.10	14.25	-10.97	0.00	0.00	0.00	0.00
107	0.02	9.27	-9.30	0.00	0.00	0.00	0.00
108	-0.01	11.23	-9.70	0.00	0.00	0.00	0.00
109	-0.09	15.65	-13.19	0.00	0.00	0.00	0.00
110	-0.15	19.21	-14.56	0.00	0.00	0.00	0.00
111	0.01	-13.84	20.03	0.00	0.00	0.00	0.00
112	-0.03	-17.65	26.97	0.00	0.00	0.00	0.00

□

SUPPORT REACTIONS -UNIT KN METE STRUCTURE TYPE = SPACE

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM-Z
113	-0.04	-6.83	12.25	0.00	0.00	0.00	0.00
114	-0.09	-8.90	17.24	0.00	0.00	0.00	0.00
115	-0.06	2.04	1.76	0.00	0.00	0.00	0.00
116	-0.06	1.86	2.90	0.00	0.00	0.00	0.00
117	-0.01	2.02	1.77	0.00	0.00	0.00	0.00
118	-0.01	1.84	2.91	0.00	0.00	0.00	0.00
119	-0.04	2.24	0.47	0.00	0.00	0.00	0.00
120	-0.03	2.23	0.47	0.00	0.00	0.00	0.00
121	-0.04	1.65	4.20	0.00	0.00	0.00	0.00
122	-0.03	1.65	4.20	0.00	0.00	0.00	0.00
123	-0.05	1.85	1.53	0.00	0.00	0.00	0.00
124	-0.05	1.67	2.67	0.00	0.00	0.00	0.00
125	-0.01	1.83	1.53	0.00	0.00	0.00	0.00
126	-0.01	1.65	2.67	0.00	0.00	0.00	0.00
127	-0.04	2.04	0.23	0.00	0.00	0.00	0.00
128	-0.03	2.04	0.24	0.00	0.00	0.00	0.00
129	-0.04	1.46	3.97	0.00	0.00	0.00	0.00
130	-0.02	1.45	3.97	0.00	0.00	0.00	0.00
131	-0.02	2.29	0.45	0.00	0.00	0.00	0.00
132	-0.02	2.15	1.33	0.00	0.00	0.00	0.00
133	0.01	2.27	0.45	0.00	0.00	0.00	0.00
134	0.01	2.14	1.33	0.00	0.00	0.00	0.00
135	-0.01	2.43	-0.51	0.00	0.00	0.00	0.00
136	0.00	2.43	-0.51	0.00	0.00	0.00	0.00
137	-0.01	1.99	2.29	0.00	0.00	0.00	0.00
138	0.00	1.99	2.29	0.00	0.00	0.00	0.00
119	101	0.01	2.34	-0.12	0.00	0.00	0.00
102	-0.01	2.15	-1.15	0.00	0.00	0.00	0.00
103	0.01	-13.79	-19.80	0.00	0.00	0.00	0.00
104	-0.03	-17.62	-26.82	0.00	0.00	0.00	0.00
105	-0.04	-6.91	-12.99	0.00	0.00	0.00	0.00
106	-0.09	-9.02	-18.30	0.00	0.00	0.00	0.00
107	0.02	9.32	9.63	0.00	0.00	0.00	0.00
108	-0.01	11.27	9.97	0.00	0.00	0.00	0.00
109	-0.08	15.64	13.19	0.00	0.00	0.00	0.00
110	-0.15	19.17	14.42	0.00	0.00	0.00	0.00
111	0.03	5.11	5.58	0.00	0.00	0.00	0.00
112	0.00	6.01	4.90	0.00	0.00	0.00	0.00
113	-0.04	11.77	11.11	0.00	0.00	0.00	0.00
114	-0.09	14.34	11.81	0.00	0.00	0.00	0.00
115	-0.06	1.88	-2.76	0.00	0.00	0.00	0.00
116	-0.06	2.06	-1.60	0.00	0.00	0.00	0.00
117	-0.01	1.87	-2.77	0.00	0.00	0.00	0.00
118	-0.01	2.05	-1.61	0.00	0.00	0.00	0.00
119	-0.04	1.67	-4.08	0.00	0.00	0.00	0.00
120	-0.03	1.67	-4.08	0.00	0.00	0.00	0.00
121	-0.04	2.26	-0.28	0.00	0.00	0.00	0.00
122	-0.03	2.26	-0.28	0.00	0.00	0.00	0.00

□

SUPPORT REACTIONS -UNIT KN METE STRUCTURE TYPE = SPACE

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM-Z
123	-0.05	1.69	-2.54	0.00	0.00	0.00	0.00
124	-0.05	1.87	-1.38	0.00	0.00	0.00	0.00
125	-0.01	1.67	-2.55	0.00	0.00	0.00	0.00
126	-0.01	1.85	-1.39	0.00	0.00	0.00	0.00
127	-0.04	1.48	-3.86	0.00	0.00	0.00	0.00
128	-0.02	1.47	-3.86	0.00	0.00	0.00	0.00
129	-0.04	2.07	-0.06	0.00	0.00	0.00	0.00
130	-0.02	2.06	-0.07	0.00	0.00	0.00	0.00
131	-0.02	2.19	-1.08	0.00	0.00	0.00	0.00
132	-0.02	2.33	-0.18	0.00	0.00	0.00	0.00
133	0.01	2.17	-1.08	0.00	0.00	0.00	0.00
134	0.01	2.31	-0.19	0.00	0.00	0.00	0.00
135	-0.01	2.03	-2.06	0.00	0.00	0.00	0.00
136	0.00	2.03	-2.06	0.00	0.00	0.00	0.00
137	-0.01	2.47	0.79	0.00	0.00	0.00	0.00
138	0.00	2.47	0.79	0.00	0.00	0.00	0.00

□

***** END OF LATEST ANALYSIS RESULT *****

589. LOAD LIST 301 TO 316

590. PRINT JOINT DISPLACEMENTS

□ JOINT DISPLACE □

□

JOINT DISPLACEMENT (CM RADIANS) STRUCTURE TYPE = SPACE

JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
1	301	0.0000	0.0000	0.0000	0.0001	-0.0003	0.0004
	302	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	303	0.0000	0.0000	0.0000	0.0002	-0.0004	0.0000
	304	0.0000	0.0000	0.0000	0.0008	0.0015	-0.0002
	305	0.0000	0.0000	0.0000	0.0006	-0.0011	-0.0001
	306	0.0000	0.0000	0.0000	0.0012	-0.0021	-0.0003
	307	0.0000	0.0000	0.0000	-0.0012	0.0023	0.0003
	308	0.0000	0.0000	0.0000	-0.0007	0.0012	0.0002
	309	0.0000	0.0000	0.0000	0.0000	0.0000	0.0001
	310	0.0000	0.0000	0.0000	0.0000	0.0000	0.0001
	311	0.0000	0.0000	0.0000	0.0000	0.0000	-0.0001
	312	0.0000	0.0000	0.0000	0.0000	0.0000	-0.0001
	313	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	314	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	315	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	316	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
2	301	0.0003	-0.0038	-0.0011	0.0000	0.0000	0.0005
	302	-0.0004	0.0006	0.0006	0.0000	0.0000	0.0001
	303	-0.0008	0.0027	0.0136	-0.0001	-0.0002	0.0001
	304	-0.0005	0.0057	0.0440	-0.0005	-0.0009	0.0000
	305	-0.0010	0.0050	0.0322	-0.0003	-0.0006	0.0001
	306	-0.0004	0.0075	0.0621	-0.0007	-0.0013	-0.0001
	307	0.0007	-0.0086	-0.0670	0.0007	0.0014	0.0000
	308	0.0007	-0.0051	-0.0362	0.0004	0.0007	-0.0001
	309	-0.0174	0.0004	0.0005	0.0000	0.0000	0.0001
	310	-0.0174	0.0006	0.0005	0.0000	0.0000	0.0001
	311	0.0167	0.0004	0.0005	0.0000	0.0000	0.0001
	312	0.0167	0.0006	0.0005	0.0000	0.0000	0.0001
	313	-0.0054	0.0001	0.0004	0.0000	0.0000	0.0001
	314	0.0048	0.0001	0.0004	0.0000	0.0000	0.0001
	315	-0.0054	0.0009	0.0006	0.0000	0.0000	0.0001
	316	0.0047	0.0009	0.0006	0.0000	0.0000	0.0001
3	301	0.0135	-0.0028	-0.0012	0.0000	0.0002	0.0000
	302	-0.0159	0.0007	0.0003	0.0000	-0.0007	0.0003
	303	-0.0230	0.0016	0.0015	-0.0001	-0.0010	0.0004
	304	0.0062	0.0015	0.0037	-0.0002	0.0002	-0.0001
	305	-0.0193	0.0021	0.0030	-0.0002	-0.0009	0.0004
	306	0.0226	0.0015	0.0050	-0.0003	0.0008	-0.0003
	307	-0.0139	-0.0021	-0.0056	0.0003	-0.0005	0.0002
	308	0.0052	-0.0017	-0.0032	0.0002	0.0003	-0.0001
	309	-0.0267	0.0004	0.0002	0.0000	-0.0009	0.0002
	310	-0.0268	0.0007	0.0002	0.0000	-0.0009	0.0002
	311	0.0013	0.0004	0.0002	0.0000	-0.0002	0.0002
	312	0.0012	0.0007	0.0002	0.0000	-0.0002	0.0002
	313	-0.0168	0.0001	0.0002	0.0000	-0.0006	0.0002
	314	-0.0085	0.0001	0.0002	0.0000	-0.0004	0.0002
	315	-0.0170	0.0011	0.0002	0.0000	-0.0006	0.0002
	316	-0.0087	0.0011	0.0002	0.0000	-0.0004	0.0002

□

JOINT DISPLACEMENT (CM RADIANS) STRUCTURE TYPE = SPACE

JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
4	301	0.0146	-0.0006	-0.0001	-0.0001	0.0005	-0.0009
	302	0.0100	-0.0003	-0.0008	-0.0001	0.0002	-0.0006
	303	0.0159	-0.0005	-0.0014	-0.0001	0.0003	-0.0010
	304	0.0014	-0.0003	-0.0003	-0.0001	0.0001	-0.0001
	305	0.0158	-0.0006	-0.0015	-0.0001	0.0003	-0.0010
	306	-0.0066	-0.0003	0.0003	0.0000	0.0000	0.0004
	307	0.0006	0.0005	0.0003	0.0000	-0.0001	0.0000
	308	-0.0076	0.0004	0.0008	0.0001	-0.0002	0.0005
	309	0.0145	-0.0002	-0.0004	0.0000	0.0001	-0.0007
	310	0.0145	-0.0002	-0.0009	0.0000	0.0001	-0.0007
	311	0.0015	-0.0002	-0.0004	0.0000	0.0002	-0.0003
	312	0.0015	-0.0002	-0.0009	0.0000	0.0002	-0.0003
	313	0.0099	-0.0002	0.0001	0.0000	0.0001	-0.0006
	314	0.0060	-0.0002	0.0001	0.0000	0.0002	-0.0004
	315	0.0099	-0.0002	-0.0014	-0.0001	0.0001	-0.0006
	316	0.0060	-0.0002	-0.0014	-0.0001	0.0002	-0.0004
5	301	-0.0114	-0.0153	-0.0027	-0.0002	0.0000	0.0012
	302	0.0064	-0.0093	-0.0024	-0.0001	0.0000	0.0000
	303	0.0086	-0.0175	-0.0042	-0.0002	0.0001	-0.0001
	304	-0.0039	-0.0046	-0.0010	0.0000	0.0000	0.0003
	305	0.0067	-0.0161	-0.0041	-0.0002	0.0001	0.0000
	306	-0.0110	0.0033	0.0009	0.0000	-0.0001	0.0005
	307	0.0077	0.0045	0.0009	0.0000	0.0000	-0.0005
	308	-0.0009	0.0099	0.0024	0.0001	0.0000	-0.0002
	309	0.0197	-0.0071	-0.0015	-0.0001	0.0000	-0.0004
	310	0.0198	-0.0077	-0.0022	-0.0001	0.0000	-0.0004
	311	-0.0096	-0.0071	-0.0016	-0.0001	0.0001	0.0002
	312	-0.0095	-0.0078	-0.0022	-0.0001	0.0001	0.0002
	313	0.0093	-0.0064	-0.0008	-0.0001	0.0000	-0.0002
	314	0.0005	-0.0064	-0.0008	-0.0001	0.0000	0.0000
	315	0.0096	-0.0085	-0.0030	-0.0001	0.0000	-0.0002
	316	0.0009	-0.0085	-0.0030	-0.0001	0.0000	0.0000
6	301	0.0014	-0.0022	-0.0013	-0.0001	0.0000	-0.0001
	302	0.0011	-0.0013	-0.0010	-0.0001	0.0000	-0.0001
	303	0.0017	-0.0018	-0.0012	0.0000	0.0000	-0.0001
	304	0.0001	0.0000	0.0000	0.0001	0.0000	0.0000
	305	0.0018	-0.0021	-0.0018	-0.0001	0.0000	0.0000
	306	-0.0008	0.0009	0.0006	0.0001	0.0000	0.0001
	307	0.0001	-0.0003	-0.0004	-0.0001	0.0000	0.0000
	308	-0.0005	0.0009	0.0007	0.0000	0.0000	0.0001
	309	0.0292	-0.0010	-0.0003	-0.0001	0.0000	-0.0004
	310	0.0292	-0.0010	-0.0013	-0.0001	0.0000	-0.0004
	311	-0.0274	-0.0011	-0.0003	-0.0001	0.0000	0.0003
	312	-0.0274	-0.0011	-0.0014	-0.0001	0.0000	0.0003
	313	0.0093	-0.0010	0.0009	0.0000	0.0000	-0.0002
	314	-0.0076	-0.0010	0.0009	0.0000	0.0000	0.0000
	315	0.0093	-0.0010	-0.0025	-0.0001	0.0000	-0.0002
	316	-0.0075	-0.0010	-0.0025	-0.0001	0.0000	0.0000

□

JOINT DISPLACEMENT (CM RADIANS) STRUCTURE TYPE = SPACE

JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
7	301	-0.0012	-0.1451	0.0001	0.0000	0.0000	0.0001
	302	-0.0006	-0.0857	0.0001	0.0000	0.0000	0.0000
	303	-0.0004	-0.0692	-0.0004	0.0000	0.0000	0.0000
	304	0.0002	0.0295	-0.0004	0.0000	0.0000	0.0000
	305	-0.0010	-0.1388	0.0001	0.0000	0.0000	0.0000
	306	0.0004	0.0592	0.0000	0.0000	0.0000	0.0000
	307	-0.0006	-0.0713	0.0005	0.0000	0.0000	0.0000
	308	0.0012	0.0283	0.0004	0.0000	0.0000	0.0000
	309	0.0276	-0.0685	0.0005	0.0000	0.0000	0.0000
	310	0.0276	-0.0686	-0.0005	0.0000	0.0000	0.0000
	311	-0.0286	-0.0686	0.0005	0.0000	0.0000	0.0000
	312	-0.0286	-0.0687	-0.0005	0.0000	0.0000	0.0000
	313	0.0079	-0.0684	0.0017	0.0000	0.0000	0.0000
	314	-0.0089	-0.0685	0.0017	0.0000	0.0000	0.0000
	315	0.0079	-0.0687	-0.0016	0.0000	0.0000	0.0000
	316	-0.0089	-0.0687	-0.0016	0.0000	0.0000	0.0000
8	301	0.0012	-0.0021	0.0013	0.0001	0.0000	-0.0001
	302	0.0010	-0.0012	0.0011	0.0001	0.0000	-0.0001
	303	0.0001	-0.0003	0.0003	0.0001	0.0000	0.0000
	304	-0.0008	0.0008	-0.0008	0.0000	0.0000	0.0001
	305	0.0016	-0.0020	0.0019	0.0001	0.0000	-0.0001
	306	-0.0007	0.0008	-0.0006	-0.0001	0.0000	0.0001
	307	0.0015	-0.0017	0.0014	0.0000	0.0000	-0.0001
	308	0.0004	0.0000	0.0001	-0.0001	0.0000	0.0000
	309	0.0271	-0.0010	0.0014	0.0001	0.0000	-0.0004
	310	0.0271	-0.0010	0.0004	0.0001	0.0000	-0.0004
	311	-0.0255	-0.0010	0.0014	0.0001	0.0000	0.0003
	312	-0.0255	-0.0010	0.0004	0.0001	0.0000	0.0003
	313	0.0087	-0.0010	0.0025	0.0001	0.0000	-0.0002
	314	-0.0070	-0.0010	0.0025	0.0001	0.0000	0.0000
	315	0.0086	-0.0010	-0.0008	0.0000	0.0000	-0.0002
	316	-0.0071	-0.0010	-0.0007	0.0000	0.0000	0.0000
9	301	-0.0092	-0.0158	0.0027	0.0002	0.0000	0.0111
	302	0.0062	-0.0098	0.0025	0.0001	-0.0001	-0.0001
	303	0.0069	0.0043	-0.0008	0.0000	0.0000	-0.0005
	304	-0.0012	0.0101	-0.0024	-0.0001	0.0000	-0.0001
	305	0.0069	-0.0168	0.0042	0.0002	-0.0001	0.0000
	306	-0.0101	0.0037	-0.0010	-0.0001	0.0001	0.0005
	307	0.0086	-0.0181	0.0043	0.0002	-0.0001	-0.0001
	308	-0.0034	-0.0046	0.0010	0.0000	0.0000	0.0003
	309	0.0194	-0.0081	0.0023	0.0001	0.0000	-0.0004
	310	0.0193	-0.0075	0.0016	0.0001	0.0000	0.0000
	311	-0.0094	-0.0081	0.0023	0.0001	-0.0001	0.0002
	312	-0.0095	-0.0075	0.0016	0.0001	-0.0001	0.0002
	313	0.0094	-0.0088	0.0031	0.0001	0.0000	-0.0002
	314	0.0008	-0.0088	0.0031	0.0001	0.0000	0.0000
	315	0.0091	-0.0068	0.0009	0.0001	0.0000	-0.0002
	316	0.0005	-0.0068	0.0009	0.0001	0.0000	0.0000

□

JOINT DISPLACEMENT (CM RADIANS) STRUCTURE TYPE = SPACE

JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
10	301	0.0147	-0.0006	0.0001	0.0001	-0.0005	-0.0009
	302	0.0099	-0.0003	0.0009	0.0001	-0.0002	-0.0006
	303	0.0006	0.0005	-0.0003	0.0000	0.0001	0.0000
	304	-0.0075	0.0005	-0.0008	-0.0001	0.0002	0.0005
	305	0.0158	-0.0006	0.0015	0.0001	-0.0003	-0.0010
	306	-0.0066	-0.0002	-0.0003	0.0000	0.0000	0.0004
	307	0.0159	-0.0005	0.0014	0.0001	-0.0003	-0.0010
	308	0.0014	-0.0003	0.0003	0.0000	-0.0001	-0.0001
	309	0.0146	-0.0002	0.0009	0.0000	-0.0001	-0.0007
	310	0.0146	-0.0002	0.0004	0.0000	-0.0001	-0.0007
	311	0.0013	-0.0002	0.0009	0.0000	-0.0002	-0.0003
	312	0.0013	-0.0002	0.0005	0.0000	-0.0002	-0.0003
	313	0.0100	-0.0002	0.0015	0.0001	-0.0001	-0.0006
	314	0.0060	-0.0002	0.0015	0.0001	-0.0002	-0.0004
	315	0.0099	-0.0002	-0.0001	0.0000	-0.0001	-0.0006
	316	0.0060	-0.0002	-0.0001	0.0000	-0.0002	-0.0004
11	301	0.0129	-0.0027	0.0012	0.0000	-0.0002	0.0000
	302	-0.0158	0.0007	-0.0003	0.0000	0.0007	0.0003
	303	-0.0136	-0.0021	0.0056	-0.0003	0.0004	0.0002
	304	0.0052	-0.0017	0.0032	-0.0002	-0.0003	-0.0001
	305	-0.0193	0.0021	-0.0030	0.0002	0.0009	0.0004
	306	0.0223	0.0014	-0.0050	0.0003	-0.0008	-0.0003
	307	-0.0228	0.0016	-0.0016	0.0001	0.0010	0.0004
	308	0.0060	0.0015	-0.0037	0.0002	-0.0002	-0.0001
	309	-0.0267	0.0007	-0.0002	0.0000	0.0009	0.0002
	310	-0.0266	0.0004	-0.0002	0.0000	0.0009	0.0002
	311	0.0013	0.0007	-0.0002	0.0000	0.0002	0.0002
	312	0.0013	0.0004	-0.0002	0.0000	0.0002	0.0002
	313	-0.0169	0.0011	-0.0002	0.0000	0.0006	0.0002
	314	-0.0086	0.0011	-0.0002	0.0000	0.0004	0.0002
	315	-0.0168	0.0001	-0.0002	0.0000	0.0006	0.0002
	316	-0.0084	0.0001	-0.0002	0.0000	0.0004	0.0002
12	301	0.0002	-0.0037	0.0011	0.0000	0.0000	-0.0005
	302	-0.0005	0.0007	-0.0007	0.0000	0.0000	0.0001
	303	0.0007	-0.0085	0.0669	-0.0007	-0.0014	0.0000
	304	0.0007	-0.0051	0.0362	-0.0004	-0.0007	-0.0001
	305	-0.0011	0.0050	-0.0323	0.0003	0.0006	0.0001
	306	-0.0003	0.0075	-0.0621	0.0007	0.0013	-0.0001
	307	-0.0009	0.0027	-0.0136	0.0001	0.0002	0.0001
	308	-0.0005	0.0057	-0.0439	0.0005	0.0009	0.0000
	309	-0.0175	0.0006	-0.0005	0.0000	0.0000	0.0000
	310	-0.0175	0.0004	-0.0005	0.0000	0.0000	0.0000
	311	0.0167	0.0007	-0.0006	0.0000	0.0000	0.0001
	312	0.0167	0.0004	-0.0005	0.0000	0.0000	0.0001
	313	-0.0055	0.0010	-0.0006	0.0000	0.0000	0.0001
	314	0.0047	0.0010	-0.0006	0.0000	0.0000	0.0001
	315	-0.0055	0.0001	-0.0005	0.0000	0.0000	0.0001
	316	0.0047	0.0001	-0.0005	0.0000	0.0000	0.0001

□

JOINT DISPLACEMENT (CM RADIANS) STRUCTURE TYPE = SPACE

	JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
□	13	301	0.0000	0.0000	0.0000	-0.0001	0.0003	0.0004
		302	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
		303	0.0000	0.0000	0.0000	0.0012	-0.0023	0.0003
		304	0.0000	0.0000	0.0000	0.0007	-0.0012	0.0002
		305	0.0000	0.0000	0.0000	-0.0006	0.0011	-0.0001
		306	0.0000	0.0000	0.0000	-0.0012	0.0021	-0.0003
	14	307	0.0000	0.0000	0.0000	-0.0002	0.0004	0.0000
		308	0.0000	0.0000	0.0000	-0.0008	0.0015	-0.0002
		309	0.0000	0.0000	0.0000	0.0000	0.0000	0.0001
		310	0.0000	0.0000	0.0000	0.0000	0.0000	0.0001
		311	0.0000	0.0000	0.0000	0.0000	0.0000	-0.0001
		312	0.0000	0.0000	0.0000	0.0000	0.0000	-0.0001
		313	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
		314	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
		315	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
		316	0.0000	0.0000	0.0000	0.0000	0.0000	0.0006
15	301	0.0000	0.0000	0.0000	0.0000	0.0001	0.0000	
	302	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	
	303	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	
	304	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	
	305	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	
	306	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	
	307	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	
	308	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	
	309	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	
	310	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	

□

JOINT DISPLACEMENT (CM RADIANS) STRUCTURE TYPE = SPACE

	JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
□	16	301	-0.0251	-0.0043	-0.0017	0.0000	-0.0009	0.0004
		302	-0.0041	0.0007	0.0003	0.0000	-0.0002	0.0001
		303	-0.0068	0.0018	0.0020	-0.0001	-0.0003	0.0001
		304	-0.0013	0.0019	0.0048	-0.0003	0.0000	0.0000
		305	-0.0070	0.0024	0.0039	-0.0002	-0.0003	0.0001
		306	0.0017	0.0020	0.0065	-0.0004	0.0001	0.0000
	17	307	0.0008	-0.0027	-0.0073	0.0004	0.0000	0.0000
		308	0.0037	-0.0021	-0.0041	0.0002	0.0001	-0.0001
		309	-0.0244	0.0006	0.0003	0.0000	-0.0008	0.0002
		310	-0.0244	0.0010	0.0003	0.0000	-0.0008	0.0002
		311	0.0178	0.0002	0.0003	0.0000	0.0005	-0.0001
		312	0.0178	0.0006	0.0003	0.0000	0.0005	-0.0001
	18	313	-0.0096	0.0000	0.0003	0.0000	-0.0003	0.0001
		314	0.0030	-0.0001	0.0003	0.0000	0.0000	0.0000
		315	-0.0096	0.0012	0.0003	0.0000	-0.0003	0.0001
		316	0.0030	0.0011	0.0003	0.0000	0.0000	0.0000
301		0.0042	-0.0008	0.0006	-0.0001	-0.0002	-0.0002	
302		0.0028	-0.0003	-0.0008	-0.0001	0.0000	-0.0001	
□	19	303	0.0044	-0.0006	-0.0014	-0.0001	0.0000	-0.0002
		304	0.0004	-0.0004	-0.0005	0.0000	0.0000	0.0000
		305	0.0044	-0.0007	-0.0014	-0.0001	0.0000	-0.0002
		306	-0.0018	-0.0004	0.0002	0.0000	0.0000	0.0001
		307	0.0002	0.0006	0.0005	0.0001	0.0000	0.0000
		308	-0.0021	0.0005	0.0009	0.0001	0.0000	0.0001
	20	309	0.0123	-0.0002	-0.0006	0.0000	0.0001	-0.0006
		310	0.0123	-0.0003	-0.0012	-0.0001	0.0001	-0.0006
		311	-0.0079	-0.0002	0.0000	0.0000	0.0000	0.0004
		312	-0.0079	-0.0002	-0.0006	0.0000	0.0000	0.0004
		313	0.0052	-0.0002	0.0002	0.0000	0.0000	-0.0003
		314	-0.0008	-0.0002	0.0004	0.0000	0.0000	0.0000
	21	315	0.0052	-0.0003	-0.0016	-0.0001	0.0000	-0.0003
		316	-0.0008	-0.0003	-0.0014	-0.0001	0.0000	0.0000
		301	0.0200	-0.0179	-0.0024	-0.0002	0.0001	-0.0012
		302	0.0033	-0.0114	-0.0026	-0.0001	0.0000	-0.0001
303		0.0056	-0.0207	-0.0048	-0.0002	0.0000	-0.0002	
304		0.0013	-0.0053	-0.0013	0.0000	0.0000	-0.0001	
22	305	0.0059	-0.0199	-0.0046	-0.0002	0.0000	-0.0002	
	306	-0.0010	0.0039	0.0009	0.0001	0.0000	0.0000	
	307	-0.0011	0.0049	0.0012	0.0000	0.0000	0.0001	
	308	-0.0033	0.0117	0.0027	0.0001	0.0000	0.0001	
	309	0.0186	-0.0091	-0.0021	-0.0001	0.0000	-0.0003	
	310	0.0186	-0.0098	-0.0028	-0.0001	0.0000	-0.0003	
23	311	-0.0133	-0.0085	-0.0014	-0.0001	0.0000	0.0001	
	312	-0.0133	-0.0092	-0.0021	-0.0001	0.0000	0.0002	
	313	0.0074	-0.0080	-0.0009	-0.0001	0.0000	-0.0002	
	314	-0.0021	-0.0079	-0.0007	-0.0001	0.0000	0.0000	
	315	0.0074	-0.0104	-0.0034	-0.0001	0.0000	-0.0002	
	316	-0.0021	-0.0102	-0.0032	-0.0001	0.0000	0.0000	

□

□

JOINT DISPLACEMENT (CM RADIANS) STRUCTURE TYPE = SPACE

JOINT DISPLACEMENT (CM RADIANS) STRUCTURE TYPE = SPACE

JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
19	301	-0.0002	-0.0018	-0.0007	0.0000	0.0000	0.0000
	302	-0.0001	-0.0011	-0.0008	0.0000	0.0000	0.0000
	303	-0.0015	-0.0015	-0.0014	0.0000	0.0000	0.0000
	304	0.0000	0.0000	-0.0004	0.0000	0.0000	0.0000
	305	-0.0002	-0.0018	-0.0014	0.0000	0.0000	0.0000
	306	0.0000	0.0007	0.0003	0.0000	0.0000	0.0000
	307	-0.0001	-0.0002	0.0004	-0.0001	0.0000	0.0000
	308	0.0003	0.0007	0.0009	0.0000	0.0000	0.0000
	309	0.0291	-0.0009	-0.0004	0.0000	0.0000	-0.0006
	310	0.0291	-0.0009	-0.0014	0.0000	0.0000	-0.0006
	311	-0.0292	-0.0008	0.0002	0.0000	0.0000	0.0006
	312	-0.0292	-0.0008	-0.0009	0.0000	0.0000	0.0006
	313	0.0086	-0.0009	0.0011	0.0000	0.0000	-0.0002
	314	-0.0088	-0.0009	0.0012	0.0000	0.0000	0.0002
	315	0.0086	-0.0009	-0.0025	0.0000	0.0000	-0.0002
	316	-0.0088	-0.0009	-0.0023	0.0000	0.0000	0.0002
	20	301	-0.0003	-0.0101	0.0003	0.0000	0.0001
	302	-0.0002	-0.0595	0.0002	0.0000	0.0000	0.0000
	303	-0.0001	-0.0477	-0.0008	0.0000	0.0000	0.0000

□

□

20	304	0.0001	0.0209	-0.0008	0.0000	0.0000	0.0000
	305	-0.0003	-0.0962	0.0002	0.0000	0.0000	0.0000
	306	0.0001	0.0417	-0.0001	0.0000	0.0000	0.0000
	307	-0.0002	-0.0501	0.0011	0.0000	0.0000	0.0000
	308	0.0013	0.0195	0.0007	0.0000	0.0000	0.0000
	309	0.0281	-0.0478	0.0007	0.0000	0.0000	-0.0004
	310	0.0281	-0.0479	-0.0004	0.0000	0.0000	-0.0004
	311	-0.0283	-0.0473	0.0006	0.0000	0.0000	0.0005
	312	-0.0283	-0.0473	-0.0004	0.0000	0.0000	0.0005
	313	0.0083	-0.0475	0.0019	0.0000	0.0000	-0.0001
	314	-0.0085	-0.0474	0.0018	0.0000	0.0000	0.0001
	315	0.0083	-0.0478	-0.0016	0.0000	0.0000	-0.0001
	316	-0.0085	-0.0476	-0.0016	0.0000	0.0000	0.0001
	21	301	-0.0004	-0.0017	0.0011	0.0000	0.0000
	302	-0.0002	-0.0010	0.0011	0.0000	0.0000	0.0000
	303	-0.0001	-0.0002	-0.0003	0.0001	0.0000	0.0000
	304	0.0001	0.0007	-0.0011	0.0000	0.0000	0.0000
	305	-0.0003	-0.0017	0.0018	0.0000	0.0000	0.0000
	306	0.0001	0.0007	-0.0005	0.0000	0.0000	0.0000
	307	-0.0003	-0.0015	0.0018	0.0000	0.0000	0.0000
	308	0.0003	0.0000	0.0005	0.0000	0.0000	0.0000
	309	0.0270	-0.0008	0.0017	0.0000	0.0000	-0.0005
	310	-0.0270	-0.0008	0.0007	0.0000	0.0000	-0.0005
	311	-0.0273	-0.0008	0.0010	0.0000	0.0000	0.0005
	312	-0.0273	-0.0008	0.0000	0.0000	0.0000	0.0005
	313	0.0080	-0.0008	0.0027	0.0000	0.0000	-0.0002
	314	-0.0082	-0.0008	0.0024	0.0000	0.0000	0.0002
	315	-0.0079	-0.0008	-0.0007	0.0000	0.0000	-0.0002
	316	-0.0083	-0.0008	-0.0010	0.0000	0.0000	0.0002

□

JOINT DISPLACEMENT (CM RADIANS) STRUCTURE TYPE = SPACE

JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
31	301	-0.0204	-0.0180	-0.0024	-0.0002	-0.0001	0.0012
	302	-0.0036	-0.0114	-0.0026	-0.0001	0.0000	0.0001
	303	-0.0059	-0.0207	-0.0048	-0.0002	0.0000	0.0002
	304	-0.0014	-0.0053	-0.0013	0.0000	0.0000	0.0001
	305	-0.0063	-0.0199	-0.0046	-0.0002	0.0000	0.0002
	306	0.0012	0.0039	0.0009	0.0001	0.0000	0.0000
	307	0.0011	0.0049	0.0012	0.0000	0.0000	-0.0001
	308	0.0034	0.0103	0.0027	0.0001	0.0000	-0.0001
	309	0.0130	-0.0085	-0.0014	-0.0001	0.0000	-0.0001
	310	0.0130	-0.0092	-0.0021	-0.0001	0.0000	-0.0001
	311	-0.0187	-0.0091	-0.0021	-0.0001	0.0000	0.0004
	312	-0.0187	-0.0098	-0.0028	-0.0001	0.0000	0.0003
	313	0.0018	-0.0079	-0.0007	-0.0001	0.0000	0.0000
	314	-0.0076	-0.0080	-0.0009	-0.0001	0.0000	0.0002
	315	0.0019	-0.0102	-0.0032	-0.0001	0.0000	0.0000
	316	-0.0075	-0.0104	-0.0034	-0.0001	0.0000	0.0002
32	301	0.0005	-0.0018	-0.0007	0.0000	0.0000	0.0000
	302	0.0003	-0.0011	-0.0008	0.0000	0.0000	0.0000
	303	0.0004	-0.0015	-0.0015	0.0000	0.0000	0.0000
	304	0.0000	0.0000	-0.0004	0.0000	0.0000	0.0000
	305	0.0005	-0.0018	-0.0014	0.0000	0.0000	0.0000
	306	-0.0002	0.0007	0.0004	0.0000	0.0000	0.0000
	307	0.0001	-0.0002	0.0003	-0.0001	0.0000	0.0000
	308	0.0000	0.0010	0.0016	0.0001	0.0000	0.0000
	309	0.0295	-0.0008	0.0001	0.0000	0.0000	-0.0006
	310	0.0295	-0.0008	-0.0009	0.0000	0.0000	-0.0006
	311	-0.0290	-0.0009	-0.0004	0.0000	0.0000	0.0006
	312	-0.0290	-0.0009	-0.0015	0.0000	0.0000	0.0006
	313	0.0090	-0.0009	0.0012	0.0000	0.0000	-0.0002
	314	-0.0085	-0.0009	0.0010	0.0000	0.0000	0.0000
	315	0.0089	-0.0009	-0.0023	0.0000	0.0000	-0.0002
	316	-0.0085	-0.0009	-0.0025	0.0000	0.0000	0.0002
33	301	0.0005	-0.0100	0.0002	0.0000	0.0000	-0.0001
	302	0.0003	-0.0595	0.0001	0.0000	0.0000	0.0000
	303	0.0002	-0.0478	-0.0009	0.0000	0.0000	0.0000
	304	-0.0001	0.0209	-0.0008	0.0000	0.0000	0.0000
	305	0.0004	-0.0963	0.0002	0.0000	0.0000	0.0000
	306	-0.0002	0.0417	-0.0001	0.0000	0.0000	0.0000
	307	0.0002	-0.0508	0.0011	0.0000	0.0000	0.0000
	308	0.0015	0.0702	0.0008	0.0000	0.0000	0.0000
	309	0.0284	-0.0473	0.0006	0.0000	0.0000	-0.0005
	310	0.0284	-0.0474	-0.0005	0.0000	0.0000	-0.0005
	311	-0.0280	-0.0479	0.0006	0.0000	0.0000	0.0004
	312	-0.0280	-0.0479	-0.0004	0.0000	0.0000	0.0004
	313	0.0086	-0.0474	0.0018	0.0000	0.0000	-0.0001
	314	-0.0082	-0.0476	0.0018	0.0000	0.0000	0.0001
	315	0.0086	-0.0477	-0.0016	0.0000	0.0000	-0.0001
	316	-0.0082	-0.0478	-0.0016	0.0000	0.0000	0.0001

□

JOINT DISPLACEMENT (CM RADIANS) STRUCTURE TYPE = SPACE

JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
34	301	0.0005	-0.0017	0.0010	0.0000	0.0000	0.0000
	302	0.0002	-0.0010	0.0010	0.0000	0.0000	0.0000
	303	0.0001	-0.0002	-0.0003	0.0001	0.0000	0.0000
	304	-0.0001	0.0007	-0.0001	0.0000	0.0000	0.0000
	305	0.0004	-0.0017	0.0018	0.0000	0.0000	0.0000
	306	-0.0001	0.0007	-0.0005	0.0000	0.0000	0.0000
	307	0.0003	-0.0015	0.0018	0.0000	0.0000	0.0000
	308	0.0001	0.0002	0.0000	-0.0001	0.0000	0.0000
	309	0.0274	-0.0008	0.0010	0.0000	0.0000	-0.0005
	310	0.0274	-0.0008	-0.0001	0.0000	0.0000	-0.0005
	311	-0.0270	-0.0008	0.0017	0.0000	0.0000	0.0005
	312	-0.0270	-0.0008	0.0007	0.0000	0.0000	0.0005
	313	0.0083	-0.0008	0.0024	0.0000	0.0000	-0.0002
	314	-0.0079	-0.0008	0.0026	0.0000	0.0000	0.0002
	315	0.0083	-0.0008	-0.0010	0.0000	0.0000	-0.0002
	316	-0.0079	-0.0008	-0.0007	0.0000	0.0000	0.0002
35	301	-0.0176	-0.0186	0.0026	0.0002	0.0001	0.0011
	302	-0.0032	-0.0119	0.0027	0.0001	0.0000	0.0001
	303	0.0009	0.0046	-0.0011	0.0000	0.0000	-0.0001
	304	0.0030	0.0119	-0.0028	-0.0001	0.0000	-0.0001
	305	-0.0055	-0.0206	0.0048	0.0002	0.0000	0.0002
	306	0.0011	0.0044	-0.0010	-0.0001	0.0000	0.0000
	307	-0.0052	-0.0213	0.0049	0.0002	0.0000	0.0002
	308	-0.0011	-0.0066	0.0013	0.0001	0.0000	0.0001
	309	0.0133	-0.0096	0.0022	0.0001	0.0000	-0.0002
	310	0.0133	-0.0089	0.0015	0.0001	0.0000	-0.0002
	311	-0.0183	-0.0102	0.0029	0.0001	0.0000	0.0004
	312	-0.0184	-0.0095	0.0022	0.0001	0.0000	0.0004
	313	0.0022	-0.0106	0.0033	0.0001	0.0000	0.0000
	314	-0.0072	-0.0107	0.0036	0.0001	0.0000	0.0002
	315	0.0022	-0.0083	0.0008	0.0001	0.0000	0.0000
	316	-0.0073	-0.0085	0.0011	0.0001	0.0000	0.0002
36	301	-0.0041	-0.0008	-0.0006	0.0001	-0.0001	0.0002
	302	-0.0027	-0.0003	0.0008	0.0001	0.0000	0.0001
	303	-0.0002	0.0006	-0.0004	-0.0001	0.0000	0.0000
	304	0.0020	0.0006	-0.0009	-0.0001	0.0000	-0.0001
	305	-0.0043	-0.0008	0.0014	0.0001	0.0000	0.0002
	306	0.0018	-0.0004	-0.0002	0.0000	0.0000	-0.0001
	307	-0.0043	-0.0006	0.0015	0.0001	0.0000	0.0002
	308	-0.0004	-0.0005	0.0004	0.0001	0.0000	0.0000
	309	0.0081	-0.0002	0.0006	0.0000	0.0000	-0.0004
	310	0.0081	-0.0002	0.0001	0.0000	0.0000	-0.0004
	311	-0.0124	-0.0003	0.0012	0.0001	0.0001	0.0006
	312	-0.0124	-0.0002	0.0007	0.0000	0.0001	0.0006
	313	0.0009	-0.0003	0.0015	0.0001	0.0000	0.0000
	314	-0.0052	-0.0003	0.0017	0.0001	0.0000	0.0003
	315	0.0009	-0.0002	-0.0004	0.0000	0.0000	0.0000
	316	-0.0052	-0.0002	-0.0002	0.0000	0.0000	0.0003

□

JOINT DISPLACEMENT (CM RADIANS) STRUCTURE TYPE = SPACE

JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
37	301	0.0239	-0.0042	0.0017	0.0000	-0.0008	-0.0003
	302	0.0040	0.0008	-0.0004	0.0000	-0.0002	-0.0001
	303	-0.0007	-0.0027	0.0072	-0.0004	0.0000	0.0000
	304	-0.0035	-0.0021	0.0041	-0.0001	0.0001	0.0000
	305	0.0068	0.0024	-0.0039	0.0002	-0.0003	-0.0001
	306	-0.0018	0.0019	-0.0065	0.0004	0.0001	0.0000
	307	0.0065	0.0018	-0.0020	0.0001	-0.0003	-0.0001
	308	0.0012	0.0019	-0.0049	0.0003	0.0000	0.0000
	309	-0.0181	0.0006	-0.0003	0.0000	0.0005	0.0001
	310	-0.0181	0.0002	-0.0003	0.0000	0.0005	0.0001
	311	0.0245	0.0010	-0.0003	0.0000	-0.0008	-0.0002
	312	0.0245	0.0006	-0.0003	0.0000	-0.0008	-0.0002
	313	-0.0032	0.0012	-0.0003	0.0000	0.0001	0.0000
	314	0.0096	0.0013	-0.0003	0.0000	-0.0003	-0.0001
	315	-0.0032	0.0000	-0.0003	0.0000	0.0001	0.0000
	316	0.0095	0.0001	-0.0003	0.0000	-0.0003	-0.0001
	38	301	-0.0001	-0.0055	0.0011	0.0005	-0.0002
	302	0.0002	0.0007	-0.0008	0.0000	0.0002	0.0000
38	303	-0.0002	-0.0111	0.0873	-0.0009	0.0000	0.0000
	304	-0.0002	-0.0065	0.0471	-0.0005	-0.0001	0.0000
	305	0.0004	0.0063	-0.0420	0.0004	0.0003	0.0000
	306	0.0001	0.0099	-0.0811	0.0009	-0.0001	0.0000
	307	0.0003	0.0033	-0.0176	0.0002	0.0003	0.0000
	308	0.0001	0.0074	-0.0574	0.0006	0.0000	0.0000
	309	-0.0171	0.0006	-0.0006	0.0000	0.0000	0.0000
	310	-0.0171	0.0002	-0.0006	0.0000	0.0000	0.0000
	311	0.0173	0.0009	-0.0007	0.0000	0.0002	0.0000
	312	0.0173	0.0006	-0.0006	0.0000	0.0002	0.0000
	313	-0.0050	0.0010	-0.0007	0.0000	0.0001	0.0000
	314	0.0053	0.0011	-0.0007	0.0000	0.0002	0.0000
	315	-0.0050	0.0000	-0.0005	0.0000	0.0001	0.0000
	316	0.0053	0.0001	-0.0006	0.0000	0.0002	0.0000
	39	301	0.0000	0.0000	-0.0001	0.0043	-0.0006
	302	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	303	0.0000	0.0000	0.0000	0.0016	-0.0005	0.0001
	304	0.0000	0.0000	0.0000	0.0009	-0.0003	0.0000
39	305	0.0000	0.0000	0.0000	-0.0008	0.0000	0.0000
	306	0.0000	0.0000	0.0000	-0.0015	0.0004	-0.0001
	307	0.0000	0.0000	0.0000	-0.0003	0.0001	0.0000
	308	0.0000	0.0000	0.0000	-0.0011	0.0003	0.0000
	309	0.0000	0.0000	0.0000	0.0000	0.0003	0.0000
	310	0.0000	0.0000	0.0000	0.0000	0.0003	0.0000
	311	0.0000	0.0000	0.0000	0.0000	-0.0003	0.0000
	312	0.0000	0.0000	0.0000	0.0000	-0.0003	0.0000
	313	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	314	0.0000	0.0000	0.0000	0.0000	-0.0001	0.0000
	315	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	316	0.0000	0.0000	0.0000	0.0000	-0.0001	0.0000
	40	301	0.0000	0.0000	0.0000	0.0000	0.0000
	302	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	303	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	304	-0.0035	-0.0021	0.0041	-0.0001	0.0001	0.0000
	305	0.0068	0.0024	-0.0039	0.0002	-0.0003	-0.0001
	306	-0.0018	0.0019	-0.0065	0.0004	0.0001	0.0000
	307	0.0065	0.0018	-0.0020	0.0001	-0.0003	-0.0001
40	308	0.0012	0.0019	-0.0049	0.0003	0.0000	0.0000
	309	-0.0181	0.0006	-0.0003	0.0000	0.0005	0.0001
	310	-0.0181	0.0002	-0.0003	0.0000	0.0005	0.0001
	311	0.0245	0.0010	-0.0003	0.0000	-0.0008	-0.0002
	312	0.0245	0.0006	-0.0003	0.0000	-0.0008	-0.0002
	313	-0.0032	0.0012	-0.0003	0.0000	0.0001	0.0000
	314	0.0096	0.0013	-0.0003	0.0000	-0.0003	-0.0001
	315	-0.0032	0.0000	-0.0003	0.0000	0.0001	0.0000
	316	0.0095	0.0001	-0.0003	0.0000	-0.0003	-0.0001
	41	301	-0.0001	-0.0038	-0.0011	0.0000	0.0005
	302	0.0006	0.0006	0.0006	0.0000	0.0000	0.0000
	303	0.0010	0.0027	0.0136	-0.0001	0.0002	-0.0001
	304	0.0005	0.0057	0.0440	-0.0005	0.0009	0.0000
	305	0.0012	0.0050	0.0322	-0.0003	0.0006	-0.0001
	306	0.0003	0.0075	0.0621	-0.0007	0.0013	0.0001
	307	-0.0007	-0.0086	-0.0670	0.0007	-0.0014	0.0000
	308	-0.0008	-0.0051	-0.0361	0.0004	-0.0007	0.0001
	309	-0.0166	0.0004	0.0005	0.0000	0.0000	-0.0001
	310	-0.0166	0.0006	0.0005	0.0000	0.0000	-0.0001
	311	0.0175	0.0004	0.0005	0.0000	0.0000	-0.0001
	312	0.0175	0.0006	0.0005	0.0000	0.0000	-0.0001
	313	-0.0046	0.0001	0.0004	0.0000	0.0000	-0.0001
42	314	0.0055	0.0001	0.0004	0.0000	0.0000	-0.0001
	315	-0.0046	0.0009	0.0006	0.0000	0.0000	-0.0001
	316	0.0055	0.0009	0.0006	0.0000	0.0000	-0.0001
	42	301	-0.0133	-0.0028	-0.0012	0.0000	0.0000
	302	0.0161	0.0007	0.0003	0.0000	0.0007	-0.0003
	303	0.0231	0.0016	0.0015	-0.0001	0.0010	-0.0004
	304	-0.0062	0.0015	0.0037	-0.0002	-0.0002	0.0001
	305	0.0195	0.0021	0.0030	-0.0002	0.0009	-0.0004
	306	-0.0227	0.0015	0.0050	-0.0003	-0.0008	0.0003
	307	0.0139	-0.0021	-0.0056	0.0003	0.0005	-0.0002
	308	-0.0054	-0.0017	-0.0032	0.0002	-0.0003	0.0001
	309	-0.0012	0.0004	0.0002	0.0000	0.0002	-0.0002
	310	-0.0011	0.0007	0.0002	0.0000	0.0002	-0.0002
	311	0.0268	0.0004	0.0002	0.0000	0.0009	-0.0002
	312	0.0269	0.0007	0.0002	0.0000	0.0009	-0.0002
	313	0.0086	0.0001	0.0002	0.0000	0.0004	-0.0002
	314	0.0169	0.0001	0.0002	0.0000	0.0006	-0.0002
	315	0.0088	0.0011	0.0002	0.0000	0.0004	-0.0002
	316	0.0171	0.0011	0.0002	0.0000	0.0006	-0.0002

□

JOINT DISPLACEMENT (CM RADIANS) STRUCTURE TYPE = SPACE

JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
43	301	-0.0147	-0.0006	-0.0001	-0.0001	-0.0005	0.0009
	302	-0.0100	-0.0003	-0.0008	-0.0001	-0.0002	0.0006
	303	-0.0160	-0.0005	-0.0014	-0.0001	-0.0003	0.0010
	304	-0.0144	-0.0003	-0.0003	0.0000	-0.0001	0.0001
	305	-0.0159	-0.0006	-0.0015	-0.0001	-0.0003	0.0010
	306	0.0066	-0.0003	0.0003	0.0000	0.0000	-0.0004
	307	-0.0006	0.0005	0.0003	0.0000	0.0001	0.0000
	308	0.0076	0.0004	0.0009	0.0001	0.0002	-0.0005
	309	-0.0015	-0.0002	-0.0004	0.0000	-0.0002	0.0003
	310	-0.0015	-0.0002	-0.0009	0.0000	-0.0002	0.0003
	311	-0.0145	-0.0002	-0.0004	0.0000	-0.0001	0.0007
	312	-0.0145	-0.0002	-0.0009	0.0000	-0.0001	0.0007
	313	-0.0061	-0.0002	0.0001	0.0000	-0.0002	0.0004
	314	-0.0099	-0.0002	0.0001	0.0000	-0.0001	0.0006
	315	-0.0061	-0.0002	-0.0014	-0.0001	-0.0002	0.0004
	316	-0.0099	-0.0002	-0.0014	-0.0001	-0.0001	0.0006
	44	301	0.0112	-0.0153	-0.0027	0.0000	-0.0012
	302	-0.0065	-0.0093	-0.0024	-0.0001	0.0000	0.0001
	303	-0.0089	-0.0175	-0.0042	-0.0002	-0.0001	0.0001
	304	0.0039	-0.0046	-0.0010	0.0000	0.0000	-0.0003
	305	-0.0070	-0.0161	-0.0041	-0.0002	-0.0001	0.0000
	306	0.0111	0.0033	0.0009	0.0000	0.0001	-0.0005
	307	-0.0077	0.0046	0.0009	0.0000	0.0000	0.0005
	308	0.0012	0.0085	0.0023	0.0001	0.0000	0.0002
	309	0.0095	-0.0071	-0.0016	-0.0001	-0.0001	-0.0002
	310	0.0094	-0.0078	-0.0022	-0.0001	-0.0001	-0.0002
	311	-0.0198	-0.0071	-0.0015	-0.0001	0.0000	0.0004
	312	-0.0199	-0.0077	-0.0022	-0.0001	0.0000	0.0004
	313	-0.0007	-0.0064	-0.0008	-0.0001	0.0000	0.0000
	314	-0.0094	-0.0064	-0.0008	-0.0001	0.0000	0.0002
	315	-0.0010	-0.0085	-0.0030	-0.0001	0.0000	0.0000
	45	316	-0.0097	-0.0085	-0.0030	-0.0001	0.0002
	301	-0.0011	-0.0022	-0.0013	-0.0001	0.0000	0.0001
	302	-0.0009	-0.0013	-0.0010	-0.0001	0.0000	0.0001
	303	-0.0014	-0.0018	-0.0012	0.0000	0.0000	0.0001
	304	-0.0001	0.0000	0.0000	0.0001	0.0000	0.0000
	305	-0.0015	-0.0021	-0.0018	-0.0001	0.0000	0.0001
	306	0.0006	0.0009	0.0006	0.0001	0.0000	-0.0001
	307	-0.0001	-0.0003	-0.0004	-0.0001	0.0000	0.0000
	308	0.0006	0.0011	0.0014	0.0001	0.0000	-0.0001
	309	0.0276	-0.0011	-0.0003	-0.0001	0.0000	-0.0003
	310	-0.0276	-0.0011	-0.0014	-0.0001	0.0000	-0.0003
	311	-0.0291	-0.0010	-0.0003	-0.0001	0.0000	0.0004
	312	-0.0291	-0.0010	-0.0013	-0.0001	0.0000	0.0004
	313	0.0077	-0.0010	0.0009	0.0000	0.0000	0.0000
	314	-0.0092	-0.0010	0.0009	0.0000	0.0000	0.0002
	315	0.0077	-0.0010	-0.0025	-0.0001	0.0000	0.0000
	316	-0.0092	-0.0010	-0.0025	-0.0001	0.0000	0.0002

□

JOINT DISPLACEMENT (CM RADIANS) STRUCTURE TYPE = SPACE

JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
46	301	0.0014	-0.1451	0.0001	0.0000	0.0000	-0.0001
	302	0.0007	-0.0857	0.0001	0.0000	0.0000	0.0000
	303	0.0006	-0.0692	-0.0004	0.0000	0.0000	0.0000
	304	-0.0002	0.0295	-0.0004	0.0000	0.0000	0.0000
	305	0.0012	-0.1388	0.0001	0.0000	0.0000	0.0000
	306	-0.0005	0.0592	0.0000	0.0000	0.0000	0.0000
	307	0.0005	-0.0720	0.0005	0.0000	0.0000	0.0000
	308	0.0019	0.0792	0.0005	0.0000	0.0000	-0.0017
	309	0.0287	-0.0686	0.0005	0.0000	0.0000	0.0000
	310	0.0287	-0.0687	-0.0005	0.0000	0.0000	0.0000
	311	-0.0275	-0.0685	0.0005	0.0000	0.0000	0.0000
	312	-0.0275	-0.0686	-0.0005	0.0000	0.0000	0.0000
	313	0.0090	-0.0685	0.0017	0.0000	0.0000	0.0000
	314	-0.0078	-0.0684	0.0017	0.0000	0.0000	0.0000
	315	0.0090	-0.0687	-0.0016	0.0000	0.0000	0.0000
	316	-0.0078	-0.0687	-0.0016	0.0000	0.0000	0.0000
	47	301	-0.0012	-0.0021	0.0013	0.0000	0.0001
	302	-0.0010	-0.0012	0.0011	0.0001	0.0000	0.0001
	303	0.0000	-0.0003	0.0003	0.0001	0.0000	0.0000
	304	0.0008	0.0008	-0.0008	0.0000	0.0000	-0.0001
	305	-0.0016	-0.0020	0.0019	0.0001	0.0000	0.0000
	306	0.0007	0.0008	-0.0006	-0.0001	0.0000	-0.0001
	307	-0.0015	-0.0017	0.0014	0.0000	0.0000	0.0001
	308	-0.0002	0.0002	-0.0005	-0.0001	0.0000	0.0000
	309	0.0255	-0.0010	0.0014	0.0001	0.0000	-0.0003
	310	0.0255	-0.0010	0.0004	0.0001	0.0000	-0.0003
	311	-0.0271	-0.0010	0.0014	0.0001	0.0000	0.0004
	312	-0.0271	-0.0010	0.0004	0.0001	0.0000	0.0004
	313	0.0071	-0.0010	0.0025	0.0001	0.0000	0.0000
	314	-0.0086	-0.0010	0.0025	0.0001	0.0000	0.0002
	315	0.0071	-0.0010	-0.0007	0.0000	0.0000	0.0000
	48	316	-0.0086	-0.0010	-0.0008	0.0000	0.0002
	301	0.0092	-0.0158	0.0028	0.0002	0.0000	-0.0011
	302	-0.0062	-0.0098	0.0025	0.0001	0.0001	0.0001
	303	-0.0069	0.0043	-0.0008	0.0000	0.0000	0.0005
	304	0.0012	0.0101	-0.0024	-0.0001	0.0000	0.0001
	305	-0.0069	-0.0168	0.0042	0.0000	0.0001	0.0000
	306	0.0101	0.0037	-0.0010	-0.0001	-0.0001	-0.0005
	307	-0.0086	-0.0181	0.0043	0.0002	0.0001	0.0001
	308	0.0035	-0.0059	0.0011	0.0001	0.0000	-0.0003
	309	0.0094	-0.0081	0.0023	0.0001	0.0001	-0.0002
	310	0.0095	-0.0075	0.0023	0.0001	0.0001	-0.0002
	311	-0.0194	-0.0081	0.0023	0.0001	0.0000	0.0004
	312	-0.0193	-0.0075	0.0016	0.0001	0.0000	0.0000
	313	-0.0008	-0.0088	0.0031	0.0001	0.0000	0.0000
	314	-0.0094	-0.0088	0.0031	0.0001	0.0000	0.0002
	315	-0.0005	-0.0068	0.0009	0.0000	0.0000	0.0000
	316	-0.0091	-0.0068	0.0009	0.0001	0.0000	0.0002

□

JOINT DISPLACEMENT (CM RADIANS) STRUCTURE TYPE = SPACE

JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
55	301	0.0147	0.1182	0.0181	-0.0001	-0.0001	-0.0008
	302	0.0100	0.0845	0.0111	-0.0001	0.0000	-0.0006
	303	0.0159	0.1344	0.0184	-0.0001	0.0001	-0.0009
	304	0.0014	0.0108	0.0020	0.0000	0.0000	0.0001
	305	0.0159	0.1333	0.0177	-0.0001	0.0000	-0.0009
	306	-0.0066	-0.0580	-0.0073	0.0000	-0.0001	0.0004
	307	0.0006	0.0070	0.0000	0.0000	0.0000	0.0000
	308	-0.0076	-0.0630	-0.0087	0.0001	0.0000	0.0004
	309	0.0145	0.1024	0.0047	0.0000	0.0000	-0.0007
	310	0.0145	0.1024	0.0039	0.0000	0.0000	-0.0007
	311	0.0015	0.0328	0.0139	0.0000	0.0001	-0.0002
	312	0.0015	0.0328	0.0131	0.0000	0.0001	-0.0002
	313	0.0099	0.0780	0.0089	0.0000	0.0000	-0.0005
	314	0.0060	0.0572	0.0116	0.0000	0.0000	-0.0004
	315	0.0099	0.0780	0.0062	-0.0001	0.0000	-0.0005
	316	0.0061	0.0572	0.0089	-0.0001	0.0000	-0.0004
	301	0.0147	0.1185	-0.0198	0.0001	0.0000	-0.0008
	302	0.0100	0.0844	-0.0123	0.0001	0.0000	-0.0006
	303	0.0006	0.0070	-0.0002	0.0000	0.0000	0.0000
56	304	-0.0075	-0.0629	0.0096	-0.0001	0.0000	0.0004
	305	0.0158	0.1332	0.0195	0.0001	-0.0001	-0.0009
	306	-0.0066	-0.0579	0.0081	0.0000	0.0001	0.0004
	307	0.0159	0.1343	-0.0202	0.0001	-0.0001	-0.0009
	308	0.0014	0.0108	-0.0021	0.0000	0.0000	-0.0001
	309	0.0146	0.1031	-0.0055	0.0000	0.0000	-0.0007
	310	0.0146	0.1031	-0.0062	0.0000	0.0000	-0.0007
	311	0.0013	0.0320	-0.0135	0.0000	-0.0001	-0.0002
	312	0.0013	0.0320	-0.0142	0.0000	-0.0001	-0.0002
	313	0.0100	0.0782	-0.0074	0.0001	0.0000	-0.0005
	314	0.0060	0.0569	-0.0098	0.0001	0.0000	-0.0004
	315	0.0099	0.0781	-0.0099	0.0000	0.0000	-0.0005
	316	0.0060	0.0569	-0.0123	0.0000	0.0000	-0.0004
	301	-0.0011	-0.1729	0.0022	-0.0001	0.0000	-0.0008
	302	-0.0009	-0.1017	0.0015	-0.0001	0.0000	-0.0004
	303	-0.0014	-0.1654	0.0006	0.0000	0.0000	-0.0007
	304	-0.0001	-0.0140	-0.0009	0.0001	0.0000	-0.0001
	305	-0.0015	-0.1653	0.0024	-0.0001	0.0000	-0.0007
	306	0.0006	0.0700	-0.0009	0.0001	0.0000	0.0003
57	307	-0.0001	-0.0005	0.0018	-0.0001	0.0000	0.0000
	308	0.0006	0.0841	0.0017	0.0001	0.0000	0.0004
	309	0.0276	-0.1869	0.0004	-0.0001	0.0000	-0.0007
	310	0.0276	-0.1868	-0.0006	-0.0001	0.0000	-0.0007
	311	-0.0291	0.0242	0.0029	-0.0001	0.0000	0.0000
	312	-0.0291	0.0242	0.0019	-0.0001	0.0000	0.0000
	313	0.0077	-0.1129	0.0024	0.0000	0.0000	-0.0005
	314	-0.0092	-0.0500	0.0032	0.0000	0.0000	-0.0003
	315	0.0077	-0.1127	-0.0008	-0.0001	0.0000	-0.0005
	316	-0.0092	-0.0498	-0.0001	-0.0001	0.0000	-0.0003

□

JOINT DISPLACEMENT (CM RADIANS) STRUCTURE TYPE = SPACE

JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
58	301	-0.0012	-0.1734	-0.0017	0.0001	0.0000	-0.0008
	302	-0.0010	-0.1015	-0.0012	0.0001	0.0000	-0.0004
	303	0.0000	-0.0007	-0.0018	0.0001	0.0000	0.0000
	304	0.0008	0.0833	-0.0002	0.0000	0.0000	0.0004
	305	-0.0016	-0.1650	-0.0020	0.0001	0.0000	-0.0007
	306	0.0007	0.0699	0.0008	-0.0001	0.0000	0.0003
	307	-0.0015	-0.1650	-0.0001	0.0000	0.0000	-0.0007
	308	-0.0002	-0.0133	-0.0003	-0.0001	0.0000	-0.0001
	309	0.0255	-0.1790	-0.0009	0.0001	0.0000	-0.0007
	310	0.0255	-0.1791	-0.0019	0.0001	0.0000	-0.0007
	311	-0.0271	0.0167	-0.0001	0.0001	0.0000	0.0000
	312	-0.0271	0.0166	-0.0011	0.0001	0.0000	0.0000
	313	0.0071	-0.1103	0.0006	0.0001	0.0000	-0.0005
	314	-0.0086	-0.0520	0.0008	0.0001	0.0000	-0.0003
	315	0.0071	-0.1104	-0.0027	0.0000	0.0000	-0.0005
	316	-0.0086	-0.0521	-0.0025	0.0000	0.0000	-0.0003
59	301	0.0014	-0.1719	0.0023	-0.0001	0.0000	0.0008
	302	0.0011	-0.1010	0.0015	-0.0001	0.0000	0.0000
	303	0.0017	-0.1644	0.0007	0.0000	0.0000	0.0007
	304	0.0001	-0.0139	-0.0009	0.0001	0.0000	0.0001
	305	0.0018	-0.1643	0.0025	-0.0001	0.0000	0.0007
	306	-0.0008	0.0696	-0.0010	0.0001	0.0000	-0.0003
	307	0.0001	-0.0005	0.0018	-0.0001	0.0000	0.0000
	308	-0.0005	0.0842	-0.0008	0.0000	0.0000	-0.0004
	309	0.0292	0.0245	0.0029	-0.0001	0.0000	0.0000
	310	0.0292	0.0245	0.0019	-0.0001	0.0000	0.0000
	311	-0.0274	-0.1862	0.0005	-0.0001	0.0000	0.0007
	312	-0.0274	-0.1861	-0.0005	-0.0001	0.0000	0.0007
	313	0.0093	-0.0495	0.0032	0.0000	0.0000	0.0003
	314	-0.0076	-0.1123	0.0025	0.0000	0.0000	0.0005
	315	0.0093	-0.0494	-0.0001	-0.0001	0.0000	0.0003
	316	-0.0075	-0.1122	-0.0008	-0.0001	0.0000	0.0005
60	301	0.0012	-0.1732	-0.0016	0.0001	0.0000	0.0008
	302	0.0010	-0.1014	-0.0011	0.0001	0.0000	0.0004
	303	0.0001	-0.0005	-0.0017	0.0001	0.0000	0.0000
	304	-0.0008	0.0833	-0.0001	0.0000	0.0000	-0.0004
	305	0.0016	-0.1648	-0.0019	0.0001	0.0000	0.0007
	306	-0.0007	0.0698	0.0007	-0.0001	0.0000	-0.0003
	307	0.0015	-0.1650	-0.0002	0.0000	0.0000	0.0007
	308	0.0004	-0.0129	0.0016	-0.0001	0.0000	0.0001
	309	0.0271	0.0168	0.0000	0.0001	0.0000	0.0000
	310	0.0271	0.0168	-0.0010	0.0001	0.0000	0.0000
	311	-0.0255	-0.1790	-0.0008	0.0001	0.0000	0.0007
	312	-0.0255	-0.1790	-0.0018	0.0001	0.0000	0.0007
	313	0.0087	-0.0519	0.0009	0.0001	0.0000	0.0003
	314	-0.0070	-0.1102	0.0006	0.0001	0.0000	0.0005
	315	0.0086	-0.0520	-0.0005	0.0000	0.0000	0.0003
	316	-0.0071	-0.1103	-0.0027	0.0000	0.0000	0.0005

□

JOINT DISPLACEMENT (CM RADIANS) STRUCTURE TYPE = SPACE

JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
61	301	0.0018	-0.4874	0.0008	0.0000	0.0000	-0.0013
	302	0.0010	-0.2655	0.0005	0.0000	0.0000	-0.0007
	303	0.0008	-0.2160	0.0006	0.0000	0.0000	-0.0006
	304	-0.0003	0.0891	-0.0001	0.0000	0.0000	0.0002
	305	0.0016	-0.4301	0.0007	0.0000	0.0000	-0.0012
	306	-0.0006	0.1807	-0.0003	0.0000	0.0000	0.0005
	307	0.0007	-0.2109	0.0002	0.0000	0.0000	-0.0006
	308	0.0021	-0.4043	0.0007	0.0000	0.0000	-0.0015
	309	0.0288	-0.2132	-0.0001	0.0000	0.0000	-0.0006
	310	0.0288	-0.2133	0.0000	0.0000	0.0000	-0.0006
	311	-0.0272	-0.2115	0.0018	0.0000	0.0000	-0.0006
	312	-0.0272	-0.2116	0.0008	0.0000	0.0000	-0.0006
	313	0.0091	-0.2125	0.0017	0.0000	0.0000	-0.0006
	314	-0.0076	-0.2120	0.0023	0.0000	0.0000	-0.0006
	315	0.0091	-0.2128	-0.0016	0.0000	0.0000	-0.0006
	316	-0.0076	-0.2123	-0.0010	0.0000	0.0000	-0.0006
	62	301	-0.0016	-0.4874	0.0009	0.0000	0.0013
62	302	-0.0009	-0.2655	0.0005	0.0000	0.0000	0.0007
	303	-0.0006	-0.2160	0.0007	0.0000	0.0000	0.0006
	304	0.0003	0.0891	-0.0001	0.0000	0.0000	-0.0002
	305	-0.0014	-0.4301	0.0008	0.0000	0.0000	0.0012
	306	0.0005	0.1807	-0.0003	0.0000	0.0000	-0.0005
	307	-0.0008	-0.2179	0.0002	0.0000	0.0000	0.0006
	308	0.0012	0.0887	-0.0002	0.0000	0.0000	-0.0002
	309	0.0273	-0.2115	0.0019	0.0000	0.0000	0.0006
	310	0.0273	-0.2116	0.0009	0.0000	0.0000	0.0006
	311	-0.0287	-0.2132	0.0000	0.0000	0.0000	0.0006
	312	-0.0287	-0.2133	-0.0010	0.0000	0.0000	0.0006
	313	0.0077	-0.2120	0.0023	0.0000	0.0000	0.0006
	314	-0.0090	-0.2126	0.0018	0.0000	0.0000	0.0006
	315	0.0076	-0.2123	-0.0009	0.0000	0.0000	0.0006
	316	-0.0091	-0.2128	-0.0015	0.0000	0.0000	0.0006
	63	301	-0.0004	-0.4047	0.0025	0.0000	-0.0013
	302	0.0000	-0.0243	0.0021	0.0000	0.0000	-0.0009
63	303	0.0002	0.0094	-0.0004	0.0000	0.0000	0.0000
	304	0.0001	0.0244	-0.0019	0.0000	0.0000	0.0007
	305	0.0000	-0.0399	0.0036	0.0000	0.0000	-0.0014
	306	-0.0002	0.0126	-0.0009	0.0000	0.0000	0.0006
	307	0.0000	-0.0469	0.0035	0.0000	-0.0001	-0.0014
	308	-0.0001	-0.0104	0.0007	0.0000	0.0000	-0.0001
	309	0.0191	-0.0195	0.0021	0.0000	0.0000	-0.0007
	310	0.0191	-0.0193	0.0013	0.0000	0.0000	-0.0007
	311	-0.0191	-0.0196	0.0021	0.0000	-0.0001	-0.0007
	312	-0.0191	-0.0193	0.0013	0.0000	-0.0001	-0.0007
	313	0.0057	-0.0199	0.0030	0.0000	0.0000	-0.0007
	314	-0.0057	-0.0199	0.0030	0.0000	0.0000	-0.0007
	315	0.0057	-0.0189	0.0004	0.0000	0.0000	-0.0007
	316	-0.0057	-0.0190	0.0004	0.0000	0.0000	-0.0007

□

JOINT DISPLACEMENT (CM RADIANS) STRUCTURE TYPE = SPACE

JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
64	301	-0.0001	-0.0506	0.0025	0.0000	-0.0001	-0.0007
	302	0.0000	-0.0309	0.0024	0.0000	0.0000	-0.0001
	303	0.0001	0.0078	-0.0008	0.0000	0.0000	0.0000
	304	0.0000	0.0287	-0.0024	0.0000	0.0000	0.0001
	305	0.0000	-0.0510	0.0040	0.0000	0.0000	-0.0002
	306	-0.0001	0.0162	-0.0010	0.0000	0.0000	0.0000
	307	0.0000	-0.0555	0.0042	0.0000	0.0000	-0.0002
	308	-0.0001	-0.0106	0.0010	0.0000	0.0000	0.0000
	309	0.0191	-0.0251	0.0027	0.0000	0.0000	-0.0005
	310	0.0191	-0.0248	0.0018	0.0000	0.0000	-0.0005
	311	-0.0191	-0.0247	0.0019	0.0000	0.0000	0.0003
	312	-0.0191	-0.0244	0.0011	0.0000	0.0000	0.0003
	313	0.0057	-0.0254	0.0034	0.0000	0.0000	-0.0002
	314	-0.0057	-0.0253	0.0032	0.0000	0.0000	0.0000
	315	0.0057	-0.0242	0.0006	0.0000	0.0000	-0.0002
	316	-0.0057	-0.0241	0.0004	0.0000	0.0000	0.0000
	65	301	0.0001	-0.0506	0.0024	0.0000	0.0001
65	302	0.0000	-0.0309	0.0023	0.0000	0.0000	0.0001
	303	0.0000	0.0078	-0.0008	0.0000	0.0000	0.0000
	304	0.0000	0.0287	-0.0024	0.0000	0.0000	-0.0001
	305	0.0000	-0.0510	0.0040	0.0000	0.0000	0.0002
	306	0.0000	0.0162	-0.0010	0.0000	0.0000	0.0000
	307	0.0000	-0.0554	0.0042	0.0000	0.0000	0.0002
	308	0.0000	-0.0162	0.0009	0.0000	0.0000	0.0000
	309	0.0191	-0.0247	0.0019	0.0000	0.0000	-0.0003
	310	0.0191	-0.0244	0.0011	0.0000	0.0000	-0.0003
	311	-0.0191	-0.0251	0.0027	0.0000	0.0000	0.0005
	312	-0.0191	-0.0248	0.0018	0.0000	0.0000	0.0005
	313	0.0057	-0.0253	0.0032	0.0000	0.0000	0.0000
	314	-0.0057	-0.0254	0.0034	0.0000	0.0000	0.0002
	315	0.0057	-0.0241	0.0003	0.0000	0.0000	0.0000
	316	-0.0057	-0.0242	0.0006	0.0000	0.0000	0.0002
	66	301	0.0004	-0.0407	0.0025	0.0000	0.0013
	302	0.0000	-0.0243	0.0021	0.0000	0.0000	0.0009
66	303	-0.0002	0.0094	-0.0004	0.0000	0.0000	0.0000
	304	-0.0001	0.0244	-0.0019	0.0000	0.0000	-0.0007
	305	0.0001	-0.0399	0.0036	0.0000	0.0000	0.0014
	306	0.0002	0.0126	-0.0009	0.0000	0.0000	-0.0006
	307	0.0000	-0.0468	0.0035	0.0000	0.0001	0.0014
	308	0.0001	-0.0160	0.0006	0.0000	0.0000	0.0001
	309	0.0191	-0.0196	0.0021	0.0000	0.0001	0.0007
	310	0.0191	-0.0193	0.0013	0.0000	0.0001	0.0007
	311	-0.0191	-0.0195	0.0021	0.0000	0.0000	0.0007
	312	-0.0191	-0.0193	0.0013	0.0000	0.0000	0.0007
	313	0.0057	-0.0199	0.0030	0.0000	0.0000	0.0007
	314	-0.0057	-0.0199	0.0030	0.0000	0.0000	0.0007
	315	0.0057	-0.0190	0.0004	0.0000	0.0000	0.0007
	316	-0.0057	-0.0189	0.0004	0.0000	0.0000	0.0007

□

JOINT DISPLACEMENT (CM RADIANS) STRUCTURE TYPE = SPACE

JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
67	301	-0.0006	-0.0440	-0.0024	0.0001	0.0000	-0.0013
	302	-0.0001	-0.0258	-0.0020	0.0000	0.0000	-0.0009
	303	-0.0002	-0.0511	-0.0033	0.0001	0.0000	-0.0014
	304	-0.0001	-0.0117	-0.0007	0.0000	0.0000	0.0000
	305	-0.0003	-0.0424	-0.0034	0.0001	0.0000	-0.0014
	306	-0.0001	0.0135	0.0009	0.0000	0.0000	0.0006
	307	0.0002	0.0111	0.0004	0.0000	0.0000	0.0000
	308	0.0001	0.0265	0.0019	0.0000	0.0000	0.0007
	309	0.0212	-0.0206	-0.0012	0.0000	0.0000	-0.0007
	310	0.0212	-0.0207	-0.0020	0.0000	0.0000	-0.0007
	311	-0.0214	-0.0206	-0.0012	0.0000	0.0001	0.0007
	312	-0.0214	-0.0208	-0.0020	0.0000	0.0001	-0.0007
	313	0.0063	-0.0204	-0.0002	0.0000	0.0000	-0.0007
	314	-0.0065	-0.0204	-0.0002	0.0000	0.0000	-0.0007
	315	0.0063	-0.0209	-0.0030	0.0000	0.0000	-0.0007
	316	-0.0064	-0.0209	-0.0030	0.0000	0.0000	-0.0007
	317	-0.0003	-0.0556	-0.0022	0.0001	0.0001	-0.0006
	318	-0.0001	-0.0336	-0.0021	0.0000	0.0000	-0.0001
	319	-0.0002	-0.0610	-0.0039	0.0001	0.0000	-0.0002
68	301	-0.0001	-0.0118	-0.0010	0.0000	0.0000	0.0000
	302	-0.0002	-0.0552	-0.0037	0.0001	0.0000	-0.0002
	303	0.0000	0.0179	0.0008	0.0000	0.0000	0.0000
	304	0.0001	0.0089	0.0009	0.0000	0.0000	0.0000
	305	0.0001	0.0314	0.0022	0.0000	0.0000	0.0001
	306	0.0001	-0.0270	-0.0016	0.0000	0.0000	-0.0006
	307	0.0212	-0.0272	-0.0024	0.0000	0.0000	-0.0006
	308	-0.0214	-0.0266	-0.0009	0.0000	0.0000	0.0004
	309	-0.0214	-0.0268	-0.0018	0.0000	0.0000	0.0004
	310	0.0062	-0.0266	-0.0003	0.0000	0.0000	-0.0002
	311	-0.0065	-0.0265	-0.0001	0.0000	0.0000	0.0000
	312	0.0063	-0.0273	-0.0033	0.0000	0.0000	-0.0002
	313	-0.0064	-0.0272	-0.0031	0.0000	0.0000	0.0001
	314	-0.0002	-0.0557	-0.0022	0.0001	-0.0001	0.0006
	315	-0.0001	-0.0336	-0.0021	0.0000	0.0000	0.0001
	316	-0.0002	-0.0609	-0.0039	0.0001	0.0000	-0.0002
	317	0.0000	0.0179	0.0008	0.0000	0.0000	0.0000
	318	0.0001	0.0089	0.0009	0.0000	0.0000	0.0000
	319	0.0001	0.0314	0.0022	0.0000	0.0000	0.0001
69	301	-0.0002	-0.0272	-0.0033	0.0000	0.0000	-0.0002
	302	-0.0001	-0.0336	-0.0021	0.0000	0.0000	0.0001
	303	-0.0002	-0.0609	-0.0039	0.0001	0.0000	0.0002
	304	0.0000	-0.0118	-0.0010	0.0000	0.0000	0.0000
	305	-0.0002	-0.0551	-0.0037	0.0001	0.0000	0.0002
	306	0.0001	0.0179	0.0008	0.0000	0.0000	0.0000
	307	0.0000	0.0090	0.0009	0.0000	0.0000	0.0000
	308	0.0000	0.0246	0.0025	0.0000	0.0000	-0.0001
	309	0.0212	-0.0266	-0.0010	0.0000	0.0000	-0.0004
	310	0.0212	-0.0268	-0.0018	0.0000	0.0000	-0.0004
	311	-0.0214	-0.0269	-0.0016	0.0000	0.0000	0.0006
	312	-0.0214	-0.0271	-0.0025	0.0000	0.0000	0.0006
	313	0.0062	-0.0264	-0.0001	0.0000	0.0000	0.0000
	314	-0.0065	-0.0265	-0.0003	0.0000	0.0000	0.0002
	315	0.0063	-0.0272	-0.0031	0.0000	0.0000	-0.0001
	316	-0.0065	-0.0273	-0.0033	0.0000	0.0000	0.0002
	317	0.0000	0.0179	0.0008	0.0000	0.0000	0.0000
	318	0.0001	0.0089	0.0009	0.0000	0.0000	0.0000
	319	0.0001	0.0314	0.0022	0.0000	0.0000	0.0001

□

JOINT DISPLACEMENT (CM RADIANS) STRUCTURE TYPE = SPACE

JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
70	301	0.0001	-0.0440	-0.0024	0.0001	0.0000	0.0013
	302	-0.0001	-0.0258	-0.0020	0.0000	0.0000	0.0009
	303	-0.0002	-0.0511	-0.0033	0.0001	0.0000	0.0014
	304	-0.0001	-0.0117	-0.0007	0.0000	0.0000	0.0000
	305	-0.0002	-0.0423	-0.0034	0.0001	0.0000	0.0014
	306	0.0002	0.0135	0.0009	0.0000	0.0000	-0.0006
	307	-0.0001	0.0111	0.0004	0.0000	0.0000	0.0000
	308	0.0000	0.0198	0.0021	0.0000	0.0000	-0.0007
	309	0.0212	-0.0206	-0.0012	0.0000	-0.0001	0.0007
	310	0.0212	-0.0208	-0.0020	0.0000	-0.0001	0.0007
	311	-0.0215	-0.0206	-0.0012	0.0000	0.0000	0.0007
	312	-0.0214	-0.0207	-0.0020	0.0000	0.0000	0.0007
	313	0.0062	-0.0204	-0.0002	0.0000	0.0000	0.0007
	314	-0.0065	-0.0204	-0.0002	0.0000	0.0000	0.0007
	315	0.0063	-0.0209	-0.0030	0.0000	0.0000	0.0007
	316	-0.0065	-0.0209	-0.0030	0.0000	0.0000	0.0007
	317	0.0004	0.1697	-0.0229	0.0000	0.0002	0.0011
	318	0.0000	0.1155	-0.0147	0.0000	0.0001	0.0008
	319	-0.0002	0.0147	-0.0017	0.0000	0.0000	0.0000
71	301	-0.0001	-0.0831	0.0106	0.0000	-0.0001	-0.0006
	302	0.0000	0.1838	0.0232	0.0000	0.0002	0.0012
	303	0.0002	-0.0769	0.0099	0.0000	-0.0001	-0.0005
	304	0.0000	0.1763	-0.0227	0.0000	0.0002	0.0012
	305	0.0001	0.0060	-0.0012	0.0000	0.0000	0.0001
	306	0.0000	0.0921	-0.0196	0.0000	0.0002	0.0006
	307	0.0191	0.0923	-0.0201	0.0000	0.0001	0.0006
	308	-0.0191	0.0925	-0.0034	0.0000	0.0000	0.0006
	309	-0.0191	0.0928	-0.0039	0.0000	0.0000	0.0006
	310	0.0057	0.0919	-0.0133	0.0000	0.0001	0.0006
	311	-0.0057	0.0921	-0.0085	0.0000	0.0001	0.0006
	312	0.0057	0.0928	-0.0150	0.0000	0.0001	0.0006
	313	-0.0057	0.0929	-0.0101	0.0000	0.0001	0.0006
	314	-0.0004	0.1697	-0.0229	0.0000	-0.0002	-0.0011
	315	0.0000	0.1155	-0.0147	0.0000	-0.0001	-0.0008
	316	0.0002	-0.0769	0.0099	0.0000	0.0001	0.0005
	317	0.0000	0.1763	-0.0227	0.0000	-0.0002	-0.0012
	318	-0.0001	0.0116	-0.0016	0.0000	0.0000	-0.0001
	319	0.0191	0.0925	-0.0034	0.0000	0.0000	-0.0006
72	301	-0.0004	0.1697	-0.0229	0.0000	-0.0002	-0.0011
	302	0.0000	0.1155	-0.0147	0.0000	-0.0001	-0.0008
	303	0.0002	0.0147	-0.0017	0.0000	0.0000	0.0000
	304	0.0001	-0.0831	0.0106	0.0000	0.0001	0.0006
	305	0.0000	0.1838	0.0232	0.0000	-0.0002	-0.0012
	306	-0.0002	-0.0769	0.0099	0.0000	0.0001	0.0005
	307	0.0000	0.1763	-0.0227	0.0000	-0.0002	-0.0012
	308	-0.0001	0.0116	-0.0016	0.0000	0.0000	-0.0001
	309	0.0191	0.0925	-0.0034	0.0000	0.0000	-0.0006
	310	0.0191	0.0928	-0.0039	0.0000	0.0000	-0.0006
	311	-0.0191	0.0921	-0.0196	0.0000	-0.0002	-0.0006
	312	-0.0191	0.0923	-0.0201	0.0000	-0.0001	-0.0006
	313	0.0057	0.0921	-0.0085	0.0000	-0.0001	-0.0006
	314	-0.0057	0.0919	-0.0133	0.0000	-0.0001	-0.0006
	315	0.0057	0.0930	-0.0101	0.0000	-0.0001	-0.0006
	316	-0.0057	0.0928	-0.0150	0.0000	-0.0001	-0.0006
	317	0.0000	0.1763	-0.0227	0.0000	-0.0002	-0.0012
	318	-0.0001	0.0116	-0.0016	0.0000	0.0000	-0.0001
	319	0.0191	0.0925	-0.0034	0.0000	0.0000	-0.0006

□

JOINT DISPLACEMENT (CM RADIANS) STRUCTURE TYPE = SPACE

JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
73	301	0.0001	0.1664	0.0201	0.0001	-0.0002	0.0011
	302	-0.0001	0.1144	0.0129	0.0000	-0.0001	0.0008
	303	-0.0002	0.1725	0.0198	0.0001	-0.0002	0.0012
	304	0.0001	0.0103	0.0012	0.0000	0.0000	0.0000
	305	-0.0002	0.1820	0.0204	0.0001	-0.0002	0.0012
	306	0.0002	-0.0761	-0.0088	0.0000	0.0001	-0.0005
	307	-0.0001	0.0165	0.0017	0.0000	0.0000	0.0000
	308	0.0000	-0.0879	-0.0096	0.0000	0.0001	-0.0006
	309	0.0212	0.0913	0.0190	0.0000	-0.0001	0.0006
	310	0.0212	0.0912	0.0185	0.0000	-0.0001	0.0006
	311	-0.0215	0.0918	0.0021	0.0000	0.0000	0.0006
	312	-0.0215	0.0916	0.0016	0.0000	0.0000	0.0006
	313	0.0062	0.0916	0.0136	0.0000	-0.0001	0.0006
	314	-0.0065	0.0918	0.0086	0.0000	-0.0001	0.0006
	315	0.0063	0.0912	0.0120	0.0000	-0.0001	0.0006
	316	-0.0065	0.0913	0.0070	0.0000	-0.0001	0.0006
	317	-0.0005	0.1664	0.0203	0.0001	0.0002	-0.0011
	318	-0.0001	0.1144	0.0130	0.0000	0.0001	-0.0008
	319	-0.0002	0.1725	0.0200	0.0001	0.0002	-0.0012
	320	-0.0001	0.0103	0.0013	0.0000	0.0000	-0.0001
	321	-0.0003	0.1820	0.0206	0.0001	0.0002	-0.0012
	322	-0.0001	-0.0761	-0.0089	0.0000	-0.0001	0.0005
	323	0.0002	0.0165	0.0017	0.0000	0.0000	0.0000
	324	-0.0001	-0.0812	-0.0093	0.0000	-0.0001	0.0006
	325	0.0001	0.0918	0.0022	0.0000	0.0000	-0.0006
	326	0.0212	0.0918	0.0018	0.0000	0.0000	-0.0006
	327	0.0213	0.0916	0.0018	0.0000	0.0001	-0.0006
	328	-0.0214	0.0913	0.0190	0.0000	0.0001	-0.0006
	329	-0.0214	0.0912	0.0186	0.0000	0.0001	-0.0006
	330	0.0063	0.0918	0.0087	0.0000	0.0001	-0.0006
	331	-0.0065	0.0917	0.0137	0.0000	0.0001	-0.0006
	332	0.0063	0.0913	0.0071	0.0000	0.0001	-0.0006
	333	-0.0064	0.0912	0.0121	0.0000	0.0001	-0.0006
	334	-0.0011	-0.0051	0.0106	0.0000	-0.0001	-0.0008
	335	0.0001	0.0003	0.0007	0.0000	0.0000	0.0000
	336	0.0003	-0.0029	0.0421	0.0000	-0.0004	-0.0001
	337	0.0002	-0.0119	0.1436	0.0000	-0.0015	-0.0001
	338	0.0003	-0.0081	0.1034	0.0000	-0.0011	-0.0001
	339	0.0002	-0.0173	0.2044	0.0000	-0.0021	-0.0002
	340	-0.0003	0.0183	-0.2190	0.0000	0.0023	0.0002
	341	-0.0002	0.0095	-0.1173	0.0000	0.0012	0.0001
	342	-0.0127	0.0003	0.0006	0.0000	0.0000	0.0000
	343	0.0129	0.0003	0.0006	0.0000	0.0000	0.0000
	344	0.0129	0.0002	0.0006	0.0000	0.0000	0.0000
	345	-0.0037	0.0000	0.0005	0.0000	0.0000	0.0000
	346	-0.0037	0.0004	0.0007	0.0000	0.0000	0.0000
	347	0.0039	0.0004	0.0007	0.0000	0.0000	0.0000

□

JOINT DISPLACEMENT (CM RADIANS) STRUCTURE TYPE = SPACE

JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
76	301	-0.0002	-0.0075	0.0172	0.0000	0.0044	0.0005
	302	0.0001	0.0003	0.0008	0.0000	0.0000	0.0000
	303	0.0001	-0.0040	0.0548	0.0000	0.0001	0.0000
	304	0.0001	-0.0156	0.1876	0.0000	0.0003	0.0000
	305	0.0002	-0.0107	0.1349	0.0000	0.0002	0.0000
	306	0.0000	-0.0226	0.2671	0.0000	0.0004	0.0001
	307	-0.0001	0.0239	-0.2861	0.0000	-0.0005	-0.0001
	308	-0.0001	0.0125	-0.1531	0.0000	-0.0003	0.0000
	309	-0.0127	0.0002	0.0007	0.0000	-0.0003	0.0000
	310	-0.0127	0.0004	0.0007	0.0000	-0.0003	0.0000
	311	0.0129	0.0001	0.0006	0.0000	0.0003	0.0000
	312	0.0129	0.0002	0.0007	0.0000	0.0003	0.0000
	313	-0.0038	0.0000	0.0006	0.0000	-0.0001	0.0000
	314	0.0039	-0.0001	0.0006	0.0000	0.0001	0.0000
	315	-0.0038	0.0005	0.0008	0.0000	-0.0001	0.0000
	316	0.0039	0.0005	0.0008	0.0000	0.0001	0.0000
	317	0.0004	-0.0075	0.0172	0.0000	-0.0044	-0.0005
	318	0.0000	-0.0003	0.0008	0.0000	0.0000	0.0000
	319	0.0000	-0.0040	0.0548	0.0000	-0.0001	0.0000
	320	0.0000	-0.0156	0.1876	0.0000	-0.0003	0.0000
	321	-0.0001	0.0239	-0.2861	0.0000	-0.0004	-0.0001
	322	0.0001	0.0125	0.0006	0.0000	0.0002	0.0000
	323	0.0000	0.0125	-0.1531	0.0000	-0.0003	0.0000
	324	-0.0128	0.0001	0.0006	0.0000	-0.0003	0.0000
	325	-0.0128	0.0002	0.0007	0.0000	-0.0003	0.0000
	326	0.0128	0.0004	0.0007	0.0000	0.0003	0.0000
	327	-0.0038	-0.0001	0.0006	0.0000	-0.0001	0.0000
	328	0.0038	0.0000	0.0006	0.0000	0.0001	0.0000
	329	-0.0038	0.0005	0.0008	0.0000	-0.0001	0.0000
	330	0.0038	0.0005	0.0008	0.0000	0.0001	0.0000
	331	0.0013	-0.0051	0.0106	0.0000	0.0001	0.0008
	332	0.0000	0.0003	0.0007	0.0000	0.0000	0.0000
	333	-0.0001	-0.0029	0.0421	0.0000	0.0004	0.0001
	334	-0.0002	-0.0119	0.1436	0.0000	0.0015	0.0001
	335	-0.0002	-0.0081	0.1034	0.0000	0.0011	0.0001
	336	-0.0002	-0.0173	0.2044	0.0000	0.0021	0.0002
	337	0.0003	0.0183	-0.2190	0.0000	-0.0023	-0.0002
	338	0.0002	0.0095	-0.1172	0.0000	-0.0012	-0.0001
	339	-0.0128	0.0002	0.0006	0.0000	0.0000	0.0000
	340	-0.0128	0.0003	0.0006	0.0000	0.0000	0.0000
	341	0.0128	0.0002	0.0005	0.0000	0.0000	0.0000
	342	0.0128	0.0003	0.0006	0.0000	0.0000	0.0000
	343	-0.0038	0.0000	0.0005	0.0000	0.0000	0.0000
	344	0.0038	0.0000	0.0005	0.0000	0.0000	0.0000
	345	-0.0038	0.0004	0.0007	0.0000	0.0000	0.0000
	346	0.0038	0.0004	0.0007	0.0000	0.0000	0.0000

75

78

□

JOINT DISPLACEMENT (CM RADIANS) STRUCTURE TYPE = SPACE

JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
85	301	0.0012	0.0831	0.0032	0.0000	-0.0001	0.0006
	302	-0.0001	0.0021	-0.0008	0.0000	0.0000	0.0000
	303	0.0003	-0.0108	0.0000	0.0000	0.0022	-0.0002
	304	0.0002	-0.0074	-0.0347	0.0000	0.0012	-0.0010
	305	-0.0003	0.0084	0.0297	0.0000	-0.0010	0.0001
	306	-0.0002	0.0089	0.0628	0.0000	-0.0021	0.0002
	307	-0.0002	0.0053	0.0109	0.0000	-0.0004	0.0001
	308	-0.0002	0.0075	0.0433	0.0000	-0.0014	0.0001
	309	-0.0130	0.0049	-0.0009	0.0000	0.0000	0.0000
	310	-0.0130	0.0048	-0.0008	0.0000	0.0000	0.0000
	311	0.0128	-0.0015	-0.0005	0.0000	0.0000	0.0000
	312	0.0128	-0.0016	-0.0004	0.0000	0.0000	0.0000
	313	-0.0039	0.0028	-0.0008	0.0000	0.0000	0.0000
	314	0.0038	0.0009	-0.0007	0.0000	0.0000	0.0000
	315	-0.0039	0.0024	-0.0006	0.0000	0.0000	0.0000
	316	0.0038	0.0005	-0.0005	0.0000	0.0000	0.0000
86	301	-0.0012	0.0831	0.0032	0.0000	0.0001	-0.0006
	302	0.0001	0.0021	-0.0008	0.0000	0.0000	0.0000
	303	-0.0003	-0.0108	-0.0664	0.0000	-0.0022	0.0002
	304	-0.0002	-0.0074	-0.0347	0.0000	-0.0012	0.0001
	305	0.0003	0.0084	0.0297	0.0000	0.0010	-0.0001
	306	0.0002	0.0089	0.0628	0.0000	0.0021	-0.0002
	307	0.0002	0.0053	0.0109	0.0000	0.0004	-0.0001
	308	0.0002	0.0075	0.0434	0.0000	0.0014	-0.0001
	309	-0.0128	-0.0015	-0.0005	0.0000	0.0000	0.0000
	310	-0.0128	-0.0016	-0.0004	0.0000	0.0000	0.0000
	311	0.0130	0.0049	-0.0009	0.0000	0.0000	0.0000
	312	0.0130	0.0048	-0.0008	0.0000	0.0000	0.0000
	313	-0.0038	0.0009	-0.0007	0.0000	0.0000	0.0000
	314	0.0039	0.0028	-0.0008	0.0000	0.0000	0.0000
	315	-0.0038	0.0005	-0.0005	0.0000	0.0000	0.0000
	316	0.0039	0.0024	-0.0006	0.0000	0.0000	0.0000
87	301	-0.0001	0.0413	-0.0014	0.0000	0.0000	0.0003
	302	0.0006	-0.0096	0.0024	0.0000	0.0000	-0.0001
	303	0.0010	-0.0134	-0.0156	-0.0001	0.0002	-0.0001
	304	0.0005	0.0052	-0.0680	-0.0005	0.0009	0.0000
	305	0.0012	-0.0107	-0.0451	0.0003	0.0006	-0.0001
	306	0.0003	0.0157	-0.0993	-0.0007	0.0012	0.0001
	307	-0.0007	-0.0106	0.1048	0.0007	-0.0013	0.0000
	308	-0.0008	0.0020	0.0541	0.0004	0.0007	-0.0001
	309	-0.0008	0.0020	0.0541	0.0004	0.0007	-0.0001
	310	-0.0008	0.0020	0.0541	0.0004	0.0007	-0.0001
	311	-0.0008	0.0020	0.0541	0.0004	0.0007	-0.0001
	312	-0.0008	0.0020	0.0541	0.0004	0.0007	-0.0001
	313	-0.0008	0.0020	0.0541	0.0004	0.0007	-0.0001
	314	-0.0008	0.0020	0.0541	0.0004	0.0007	-0.0001
	315	-0.0008	0.0020	0.0541	0.0004	0.0007	-0.0001
	316	-0.0008	0.0020	0.0541	0.0004	0.0007	-0.0001
88	301	-0.0002	0.0410	0.0013	0.0000	0.0000	0.0003
	302	0.0005	-0.0095	-0.0024	0.0000	0.0000	-0.0001
	303	-0.0007	-0.0104	-0.1048	-0.0007	0.0013	0.0000
	304	-0.0007	-0.0019	-0.0540	-0.0007	0.0006	0.0001
	305	0.0011	-0.0106	0.0451	0.0003	-0.0006	-0.0001
	306	0.0003	-0.0155	0.0993	0.0007	-0.0012	0.0001
	307	0.0009	-0.0133	0.1048	0.0004	-0.0007	-0.0001
	308	0.0005	0.0052	0.0679	0.0005	-0.0009	0.0000
	309	-0.0167	-0.0092	-0.0025	0.0000	0.0000	-0.0001
	310	-0.0167	-0.0094	-0.0025	0.0000	0.0000	-0.0001
	311	0.0175	-0.0058	-0.0014	0.0000	0.0000	0.0000
	312	0.0175	-0.0060	-0.0013	0.0000	0.0000	0.0000
	313	-0.0047	-0.0077	-0.0022	0.0000	0.0000	-0.0001
	314	0.0055	-0.0067	-0.0018	0.0000	0.0000	-0.0001
	315	-0.0047	-0.0085	-0.0020	0.0000	0.0000	-0.0001
89	301	0.0003	0.0413	-0.0014	0.0000	0.0000	-0.0003
	302	-0.0004	-0.0097	0.0024	0.0000	0.0000	0.0001
	303	-0.0008	-0.0134	-0.0156	-0.0001	-0.0002	0.0001
	304	-0.0005	0.0052	-0.0680	-0.0005	-0.0009	0.0000
	305	-0.0010	-0.0107	-0.0451	-0.0003	-0.0006	0.0001
	306	-0.0004	0.0157	-0.0993	-0.0007	-0.0012	-0.0001
	307	0.0007	-0.0106	0.1048	0.0007	0.0013	0.0000
	308	0.0007	0.0019	0.0540	0.0004	0.0007	-0.0001
	309	-0.0174	-0.0062	0.0013	0.0000	0.0000	0.0001
	310	-0.0174	-0.0060	0.0014	0.0000	0.0000	0.0001
	311	0.0167	-0.0095	0.0025	0.0000	0.0000	0.0001
	312	0.0167	-0.0092	0.0025	0.0000	0.0000	0.0001
	313	-0.0054	-0.0076	0.0017	0.0000	0.0000	0.0001
	314	0.0048	-0.0086	0.0020	0.0000	0.0000	0.0001
	315	-0.0054	-0.0069	0.0018	0.0000	0.0000	0.0001
90	301	0.0002	0.0410	0.0013	0.0000	0.0000	-0.0003
	302	-0.0005	-0.0095	-0.0024	0.0000	0.0000	0.0001
	303	0.0007	-0.0104	-0.1048	-0.0007	0.0013	0.0000
	304	0.0007	0.0019	-0.0540	-0.0004	-0.0007	-0.0001
	305	-0.0011	-0.0106	0.0451	0.0003	0.0006	0.0001
	306	-0.0003	0.0155	0.0993	0.0007	0.0012	-0.0001
	307	-0.0009	-0.0133	0.1048	0.0004	-0.0007	-0.0001
	308	-0.0005	0.0051	0.0680	0.0005	0.0009	0.0000
	309	-0.0175	-0.0058	-0.0014	0.0000	0.0000	0.0000
	310	-0.0175	-0.0060	-0.0013	0.0000	0.0000	0.0000
	311	0.0167	-0.0092	-0.0025	0.0000	0.0000	0.0001
	312	0.0167	-0.0094	-0.0025	0.0000	0.0000	0.0001
	313	-0.0055	-0.0067	-0.0018	0.0000	0.0000	0.0001
	314	0.0047	-0.0077	-0.0022	0.0000	0.0000	0.0001
	315	-0.0055	-0.0075	-0.0017	0.0000	0.0000	0.0001
	316	0.0047	-0.0085	-0.0020	0.0000	0.0000	0.0001

□

JOINT DISPLACEMENT (CM RADIANS) STRUCTURE TYPE = SPACE

JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
91	301	-0.0002	-0.3556	-0.0181	0.0001	0.0000	0.0002
	302	-0.0001	-0.2160	-0.0118	0.0000	0.0000	0.0001
	303	-0.0002	-0.3527	-0.0194	0.0001	0.0000	0.0002
	304	0.0000	-0.0408	-0.0024	0.0000	0.0000	0.0000
	305	-0.0002	-0.3471	-0.0191	0.0001	0.0000	0.0002
	306	0.0001	0.1347	0.0072	0.0000	0.0000	-0.0001
	307	0.0000	0.0025	0.0004	0.0000	0.0000	0.0000
	308	0.0001	0.1685	0.0097	0.0000	0.0000	-0.0001
	309	0.0212	-0.1727	-0.0094	0.0000	0.0000	0.0001
	310	0.0212	-0.1731	-0.0102	0.0000	0.0000	0.0001
	311	-0.0214	-0.1726	-0.0087	0.0000	0.0000	0.0001
	312	-0.0214	-0.1730	-0.0095	0.0000	0.0000	0.0001
	313	0.0062	-0.1722	-0.0082	0.0000	0.0000	0.0001
	314	-0.0065	-0.1722	-0.0080	0.0000	0.0000	0.0001
	315	0.0063	-0.1735	-0.0109	0.0000	0.0000	0.0001
	316	-0.0064	-0.1734	-0.0107	0.0000	0.0000	0.0001
93	301	0.0001	-0.4674	0.0008	0.0000	0.0000	0.0000
	302	0.0001	-0.2871	0.0005	0.0000	0.0000	0.0000
	303	0.0001	-0.2335	-0.0005	0.0000	0.0000	0.0000
	304	0.0000	0.0965	-0.0009	0.0000	0.0000	0.0000
	305	0.0001	-0.4649	0.0008	0.0000	0.0000	0.0000
	306	0.0000	0.1956	-0.0003	0.0000	0.0000	0.0000
	307	0.0000	-0.2361	0.0014	0.0000	0.0000	0.0000
	308	0.0013	0.1203	0.0005	0.0000	0.0000	0.0001
	309	0.0283	-0.2296	0.0010	0.0000	0.0000	0.0000
	310	0.0283	-0.2297	-0.0001	0.0000	0.0000	0.0000
	311	-0.0282	-0.2296	0.0009	0.0000	0.0000	0.0000
	312	-0.0282	-0.2297	-0.0001	0.0000	0.0000	0.0000
	313	0.0085	-0.2295	0.0022	0.0000	0.0000	0.0000
	314	-0.0084	-0.2295	0.0022	0.0000	0.0000	0.0000
	315	0.0085	-0.2298	-0.0013	0.0000	0.0000	0.0000
	316	-0.0084	-0.2298	-0.0013	0.0000	0.0000	0.0000
95	301	0.0000	-0.3496	0.0187	0.0000	0.0000	0.0000
	302	0.0000	-0.2130	0.0122	0.0000	0.0000	0.0000
	303	0.0000	0.0014	-0.0003	0.0000	0.0000	0.0000
	304	0.0000	0.1689	-0.0098	0.0000	0.0000	0.0000
	305	0.0000	-0.3422	0.0197	0.0000	0.0000	0.0000
	306	0.0000	0.1327	-0.0075	0.0000	0.0000	0.0000
	307	0.0000	-0.3465	0.0199	0.0000	0.0000	0.0000
	308	0.0000	-0.0422	0.0024	0.0000	0.0000	0.0000
	309	0.0191	-0.1706	0.0102	0.0000	0.0000	0.0000
	310	0.0191	-0.1701	0.0094	0.0000	0.0000	0.0000
	311	-0.0191	-0.1706	0.0102	0.0000	0.0000	0.0000
	312	-0.0191	-0.1701	0.0094	0.0000	0.0000	0.0000
	313	0.0057	-0.1712	0.0111	0.0000	0.0000	0.0000
	314	-0.0057	-0.1712	0.0111	0.0000	0.0000	0.0000
	315	0.0057	-0.1695	0.0084	0.0000	0.0000	0.0000
	316	-0.0057	-0.1695	0.0084	0.0000	0.0000	0.0000

□

JOINT DISPLACEMENT (CM RADIANS) STRUCTURE TYPE = SPACE

JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
96	301	0.0000	0.0000	0.0000	-0.0001	0.0000	0.0000
	302	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	303	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	304	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	305	0.0000	0.0000	0.0000	-0.0001	0.0000	0.0000
	306	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	307	0.0000	0.0000	0.0000	-0.0001	0.0000	0.0000
	308	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	309	0.0000	0.0000	0.0000	0.0000	0.0000	-0.0006
	310	0.0000	0.0000	0.0000	0.0000	0.0000	-0.0006
	311	0.0000	0.0000	0.0000	0.0000	0.0000	0.0006
	312	0.0000	0.0000	0.0000	0.0000	0.0000	0.0006
	313	0.0000	0.0000	0.0000	0.0000	0.0000	-0.0002
	314	0.0000	0.0000	0.0000	0.0000	0.0000	0.0002
	315	0.0000	0.0000	0.0000	-0.0001	0.0000	-0.0002
	316	0.0000	0.0000	0.0000	-0.0001	0.0000	0.0002
97	301	0.0000	0.0000	0.0000	0.0001	0.0000	0.0000
	302	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	303	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	304	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	305	0.0000	0.0000	0.0000	0.0001	0.0000	0.0000
	306	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	307	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	308	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	309	0.0000	0.0000	0.0000	0.0000	0.0000	-0.0006
	310	0.0000	0.0000	0.0000	0.0000	0.0000	-0.0006
	311	0.0000	0.0000	0.0000	0.0000	0.0000	0.0006
	312	0.0000	0.0000	0.0000	0.0000	0.0000	0.0006
	313	0.0000	0.0000	0.0000	0.0000	0.0000	-0.0002
	314	0.0000	0.0000	0.0000	0.0000	0.0000	0.0002
	315	0.0000	0.0000	0.0000	-0.0001	0.0000	-0.0002
	316	0.0000	0.0000	0.0000	-0.0001	0.0000	0.0002
98	301	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	302	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	303	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	304	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	305	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	306	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	307	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	308	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	309	0.0000	0.0000	0.0000	0.0000	0.0000	-0.0006
	310	0.0000	0.0000	0.0000	0.0000	0.0000	-0.0006
	311	0.0000	0.0000	0.0000	0.0000	0.0000	0.0006
	312	0.0000	0.0000	0.0000	0.0000	0.0000	0.0006
	313	0.0000	0.0000	0.0000	0.0001	0.0000	-0.0002
	314	0.0000	0.0000	0.0000	0.0000	0.0000	0.0002
	315	0.0000	0.0000	0.0000	0.0000	0.0000	-0.0002
	316	0.0000	0.0000	0.0000	0.0000	0.0000	0.0002
	301	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	302	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	303	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	304	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	305	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	306	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	307	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	308	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	309	0.0000	0.0000	0.0000	0.0000	0.0000	-0.0006
	310	0.0000	0.0000	0.0000	0.0000	0.0000	-0.0006
	311	0.0000	0.0000	0.0000	0.0000	0.0000	0.0006
	312	0.0000	0.0000	0.0000	0.0000	0.0000	0.0006
	313	0.0000	0.0000	0.0000	0.0000	0.0000	-0.0002
	314	0.0000	0.0000	0.0000	0.0000	0.0000	0.0002
	315	0.0000	0.0000	0.0000	0.0000	0.0000	-0.0002
	316	0.0000	0.0000	0.0000	0.0000	0.0000	0.0002

□

□

JOINT DISPLACEMENT (CM RADIANS) STRUCTURE TYPE = SPACE

JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
□	105	301	0.0000	0.0000	0.0000	-0.0005	-0.0008
		302	0.0000	0.0000	0.0001	-0.0002	-0.0005
		303	0.0000	0.0000	0.0000	0.0001	0.0000
		304	0.0000	0.0000	-0.0001	0.0002	0.0004
		305	0.0000	0.0000	0.0001	-0.0003	-0.0008
		306	0.0000	0.0000	0.0000	0.0000	0.0004
		307	0.0000	0.0000	0.0001	-0.0003	-0.0008
		308	0.0000	0.0000	0.0000	-0.0001	-0.0001
		309	0.0000	0.0000	0.0000	-0.0001	-0.0007
		310	0.0000	0.0000	0.0000	-0.0001	-0.0007
		311	0.0000	0.0000	0.0000	-0.0002	-0.0001
		312	0.0000	0.0000	0.0000	-0.0002	-0.0001
		313	0.0000	0.0000	0.0001	-0.0001	-0.0005
		314	0.0000	0.0000	0.0001	-0.0002	-0.0003
		315	0.0000	0.0000	0.0000	-0.0001	-0.0005
		316	0.0000	0.0000	0.0000	-0.0002	-0.0003
□	106	301	0.0000	0.0000	0.0000	-0.0002	-0.0002
		302	0.0000	0.0000	-0.0001	0.0000	-0.0001
		303	0.0000	0.0000	-0.0001	0.0000	-0.0002
		304	0.0000	0.0000	0.0000	0.0000	0.0000
		305	0.0000	0.0000	-0.0001	0.0000	-0.0002
		306	0.0000	0.0000	0.0000	0.0000	0.0001
		307	0.0000	0.0000	0.0001	0.0000	0.0000
		308	0.0000	0.0000	0.0000	0.0000	0.0001
		309	0.0000	0.0000	0.0000	0.0000	0.0001
		310	0.0000	0.0000	0.0000	0.0000	0.0000
		311	0.0000	0.0000	0.0000	0.0000	0.0000
		312	0.0000	0.0000	0.0000	0.0000	0.0000
		313	0.0000	0.0000	0.0001	0.0000	0.0000
		314	0.0000	0.0000	0.0000	0.0000	0.0000
		315	0.0000	0.0000	0.0000	0.0000	0.0000
		316	0.0000	0.0000	-0.0001	0.0000	0.0000
□	107	301	0.0000	0.0000	0.0000	0.0001	-0.0002
		302	0.0000	0.0000	0.0000	0.0001	-0.0001
		303	0.0000	0.0000	0.0000	0.0000	0.0000
		304	0.0000	0.0000	-0.0001	0.0000	0.0001
		305	0.0000	0.0000	0.0000	0.0000	0.0000
		306	0.0000	0.0000	0.0000	0.0000	0.0000
		307	0.0000	0.0000	0.0000	0.0000	0.0000
		308	0.0000	0.0000	0.0000	0.0000	0.0000
		309	0.0000	0.0000	0.0000	0.0000	0.0000
		310	0.0000	0.0000	0.0000	0.0000	0.0000
		311	0.0000	0.0000	0.0000	0.0000	0.0000
		312	0.0000	0.0000	0.0000	0.0000	0.0000
		313	0.0000	0.0000	0.0000	0.0000	0.0000
		314	0.0000	0.0000	0.0000	0.0000	0.0000
		315	0.0000	0.0000	-0.0001	0.0000	-0.0003
		316	0.0000	0.0000	-0.0001	0.0000	0.0000

□

JOINT DISPLACEMENT (CM RADIANS) STRUCTURE TYPE = SPACE

JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
□	111	301	0.0000	0.0000	0.0000	0.0005	0.0008
	302	0.0000	0.0000	0.0000	0.0001	0.0002	0.0005
	303	0.0000	0.0000	0.0000	0.0000	-0.0001	0.0000
	304	0.0000	0.0000	0.0000	-0.0001	-0.0002	-0.0004
	305	0.0000	0.0000	0.0000	0.0001	0.0003	0.0008
	306	0.0000	0.0000	0.0000	0.0000	0.0000	-0.0004
	307	0.0000	0.0000	0.0000	0.0001	0.0003	0.0008
	308	0.0000	0.0000	0.0000	0.0000	0.0001	0.0001
	309	0.0000	0.0000	0.0000	0.0000	0.0002	0.0001
	310	0.0000	0.0000	0.0000	0.0000	0.0002	0.0001
	311	0.0000	0.0000	0.0000	0.0000	0.0001	0.0007
	312	0.0000	0.0000	0.0000	0.0000	0.0001	0.0007
	313	0.0000	0.0000	0.0000	0.0001	0.0002	0.0003
	314	0.0000	0.0000	0.0000	0.0001	0.0001	0.0005
	315	0.0000	0.0000	0.0000	0.0000	0.0002	0.0003
	316	0.0000	0.0000	0.0000	0.0000	0.0001	0.0005
□	112	301	0.0000	0.0000	0.0000	0.0002	-0.0001
	302	0.0000	0.0000	0.0000	-0.0002	-0.0002	-0.0001
	303	0.0000	0.0000	0.0000	-0.0003	-0.0002	-0.0002
	304	0.0000	0.0000	0.0000	0.0000	0.0001	0.0000
	305	0.0000	0.0000	0.0000	-0.0001	-0.0002	-0.0002
	306	0.0000	0.0000	0.0000	0.0000	0.0003	0.0001
	307	0.0000	0.0000	0.0000	0.0001	-0.0002	0.0001
	308	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	309	0.0000	0.0000	0.0000	0.0000	0.0002	-0.0001
	310	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	311	0.0000	0.0000	0.0000	0.0000	0.0003	-0.0002
	312	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	313	0.0000	0.0000	0.0000	0.0000	0.0000	-0.0002
	314	0.0000	0.0000	0.0000	0.0000	0.0001	-0.0001
	315	0.0000	0.0000	0.0000	0.0000	0.0002	-0.0002
	316	0.0000	0.0000	0.0000	0.0000	0.0001	-0.0001
□	113	301	0.0000	0.0000	0.0000	-0.0002	-0.0001
	302	0.0000	0.0000	0.0000	0.0000	0.0002	-0.0001
	303	0.0000	0.0000	0.0000	-0.0001	0.0002	0.0000
	304	0.0000	0.0000	0.0000	0.0000	-0.0001	0.0001
	305	0.0000	0.0000	0.0000	0.0000	0.0002	-0.0002
	306	0.0000	0.0000	0.0000	0.0000	-0.0003	0.0001
	307	0.0000	0.0000	0.0000	0.0000	0.0003	-0.0002
	308	0.0000	0.0000	0.0000	0.0000	-0.0001	0.0000
	309	0.0000	0.0000	0.0000	0.0000	0.0003	-0.0002
	310	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	311	0.0000	0.0000	0.0000	0.0000	-0.0002	-0.0001
	312	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	313	0.0000	0.0000	0.0000	0.0000	-0.0002	-0.0001
	314	0.0000	0.0000	0.0000	0.0000	-0.0001	-0.0001
	315	0.0000	0.0000	0.0000	0.0000	-0.0002	-0.0001
	316	0.0000	0.0000	0.0000	0.0000	-0.0001	-0.0001

□

JOINT DISPLACEMENT (CM RADIANS) STRUCTURE TYPE = SPACE

JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
□	114	301	0.0000	0.0000	0.0000	-0.0004	-0.0001
	302	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	303	0.0000	0.0000	0.0000	0.0000	-0.0001	-0.0001
	304	0.0000	0.0000	0.0000	-0.0001	0.0000	0.0000
	305	0.0000	0.0000	0.0000	-0.0001	-0.0001	-0.0001
	306	0.0000	0.0000	0.0000	-0.0001	0.0000	0.0000
	307	0.0000	0.0000	0.0000	0.0001	0.0000	0.0000
	308	0.0000	0.0000	0.0000	0.0001	0.0000	0.0000
	309	0.0000	0.0000	0.0000	0.0000	-0.0003	-0.0002
	310	0.0000	0.0000	0.0000	0.0000	-0.0003	-0.0002
	311	0.0000	0.0000	0.0000	0.0000	0.0002	0.0001
	312	0.0000	0.0000	0.0000	0.0000	0.0002	0.0001
	313	0.0000	0.0000	0.0000	0.0000	-0.0001	-0.0001
	315	0.0000	0.0000	0.0000	0.0000	-0.0001	-0.0001
	316	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
□	115	301	0.0000	0.0000	0.0000	0.0003	-0.0001
	302	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	303	0.0000	0.0000	0.0000	-0.0001	0.0000	0.0000
	304	0.0000	0.0000	0.0000	-0.0001	0.0000	0.0000
	305	0.0000	0.0000	0.0000	0.0000	0.0001	-0.0001
	306	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	307	0.0000	0.0000	0.0000	0.0000	0.0000	-0.0001
	308	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	309	0.0000	0.0000	0.0000	0.0000	0.0003	-0.0002
	310	0.0000	0.0000	0.0000	0.0000	0.0003	-0.0002
	311	0.0000	0.0000	0.0000	0.0000	-0.0002	0.0002
	312	0.0000	0.0000	0.0000	0.0000	-0.0002	0.0002
	313	0.0000	0.0000	0.0000	0.0000	0.0001	-0.0001
	314	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	315	0.0000	0.0000	0.0000	0.0000	0.0001	-0.0001
	316	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
□	116	301	0.0000	0.0000	0.0000	0.0004	0.0001
	302	0.0000	0.0000	0.0000	0.0000	0.0001	0.0000
	303	0.0000	0.0000	0.0000	0.0000	0.0001	0.0001
	304	0.0000	0.0000	0.0000	-0.0001	0.0000	0.0000
	305	0.0000	0.0000	0.0000	0.0000	-0.0001	0.0001
	306	0.0000	0.0000	0.0000	-0.0001	0.0000	0.0000
	307	0.0000	0.0000	0.0000	0.0001	0.0000	0.0000
	308	0.0000	0.0000	0.0000	0.0001	0.0000	0.0000
	309	0.0000	0.0000	0.0000	0.0000	-0.0002	-0.0001
	310	0.0000	0.0000	0.0000	0.0000	-0.0002	-0.0001
	311	0.0000	0.0000	0.0000	0.0000	0.0003	0.0002
	312	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	313	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	314	0.0000	0.0000	0.0000	0.0000	0.0001	0.0001
	315	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	316	0.0000	0.0000	0.0000	0.0000	0.0001	0.0001

□

JOINT DISPLACEMENT (CM RADIANS) STRUCTURE TYPE = SPACE

	JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
□	117	301	0.0000	0.0000	0.0000	0.0000	-0.0003	0.0001
		302	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
		303	0.0000	0.0000	0.0000	-0.0001	0.0000	0.0000
		304	0.0000	0.0000	0.0000	-0.0001	0.0000	0.0000
		305	0.0000	0.0000	0.0000	0.0001	-0.0001	0.0001
		306	0.0000	0.0000	0.0000	0.0001	0.0000	0.0000
		307	0.0000	0.0000	0.0000	0.0000	-0.0001	0.0001
	118	308	0.0000	0.0000	0.0000	0.0001	0.0000	0.0000
		309	0.0000	0.0000	0.0000	0.0000	0.0002	-0.0002
		310	0.0000	0.0000	0.0000	0.0000	0.0002	-0.0002
		311	0.0000	0.0000	0.0000	0.0000	-0.0003	0.0002
		312	0.0000	0.0000	0.0000	0.0000	-0.0003	0.0002
		313	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
		314	0.0000	0.0000	0.0000	0.0000	-0.0001	0.0001
		315	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
		316	0.0000	0.0000	0.0000	0.0000	-0.0001	0.0001
		317	0.0000	0.0000	0.0000	0.0000	-0.0002	0.0001
119	302	0.0000	0.0000	0.0000	0.0000	0.0002	0.0001	
	303	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	
	304	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	
	305	0.0000	0.0000	0.0000	0.0000	0.0002	0.0002	
	306	0.0000	0.0000	0.0000	0.0000	0.0003	0.0002	
	307	0.0000	0.0000	0.0000	0.0000	0.0001	0.0001	
	308	0.0000	0.0000	0.0000	0.0000	0.0002	0.0002	
	309	0.0000	0.0000	0.0000	0.0000	0.0001	0.0001	
	310	0.0000	0.0000	0.0000	0.0000	0.0002	0.0002	
	311	0.0000	0.0000	0.0000	0.0000	-0.0002	0.0002	

□

JOINT DISPLACEMENT (CM RADIANS) STRUCTURE TYPE = SPACE

JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
□		128	301	0.0092	-0.0014	0.0001	-0.0002
		302	-0.0088	0.0006	-0.0001	0.0000	-0.0002
		303	-0.0083	0.0008	0.0008	-0.0002	0.0002
		304	0.0025	-0.0001	0.0005	-0.0001	-0.0001
		305	-0.0103	0.0006	-0.0005	0.0001	0.0002
		306	0.0131	-0.0011	-0.0006	0.0001	-0.0003
		307	-0.0125	0.0009	-0.0003	0.0001	0.0002
		308	0.0038	-0.0004	-0.0005	0.0001	-0.0001
		309	-0.0143	0.0006	-0.0001	0.0000	-0.0002
		310	-0.0142	0.0003	-0.0001	0.0000	-0.0002
		311	0.0002	0.0006	-0.0001	0.0000	0.0000
		312	0.0002	0.0003	-0.0001	0.0000	0.0000
		313	-0.0092	0.0009	0.0000	0.0000	-0.0002
		314	-0.0049	0.0010	0.0000	0.0000	-0.0001
		315	-0.0091	0.0000	-0.0001	0.0000	-0.0002
		316	-0.0048	0.0000	-0.0001	0.0000	-0.0001
		129	301	-0.0145	-0.0023	0.0001	0.0003
□		302	-0.0021	0.0006	-0.0001	0.0000	0.0000
		303	0.0005	0.0010	0.0010	-0.0002	0.0000
		304	0.0019	0.0000	0.0006	-0.0001	0.0000
		305	-0.0036	0.0005	-0.0007	0.0001	-0.0001
		306	0.0008	-0.0014	-0.0008	0.0002	0.0000
		307	-0.0034	0.0009	-0.0004	0.0001	-0.0001
		308	-0.0007	-0.0005	-0.0007	0.0001	0.0000
		309	-0.0132	0.0008	-0.0001	0.0000	-0.0002
		310	-0.0132	0.0005	-0.0001	0.0000	-0.0002
		311	0.0099	0.0005	-0.0001	0.0000	0.0002
		312	0.0099	0.0001	-0.0002	0.0000	0.0002
		313	-0.0051	0.0011	0.0000	0.0001	-0.0001
		314	0.0018	0.0010	0.0000	0.0000	0.0000
		315	-0.0051	0.0000	-0.0002	0.0000	-0.0001
		316	0.0018	-0.0001	-0.0002	0.0000	0.0000
		130	301	0.0145	-0.0024	0.0001	-0.0003
		302	0.0021	0.0006	-0.0001	0.0000	0.0000
		303	-0.0005	0.0010	-0.0002	0.0000	0.0000
□		304	-0.0019	0.0000	0.0006	-0.0001	0.0000
		305	0.0036	0.0005	-0.0007	0.0001	-0.0001
		306	-0.0008	-0.0014	0.0008	0.0002	0.0000
		307	0.0034	0.0009	-0.0004	0.0001	-0.0001
		308	-0.0007	-0.0005	-0.0007	0.0001	0.0000
		309	-0.0099	0.0005	-0.0001	0.0000	-0.0002
		310	-0.0099	0.0001	-0.0002	0.0000	0.0002
		311	0.0132	0.0008	-0.0001	0.0000	0.0002
		312	0.0132	0.0005	-0.0001	0.0000	-0.0003
		313	-0.0018	0.0010	0.0000	0.0000	0.0000
		314	0.0051	0.0011	0.0000	-0.0001	0.0001
		315	-0.0018	-0.0001	-0.0002	0.0000	0.0000
		316	0.0051	0.0000	-0.0002	0.0000	-0.0001
		131	301	0.0145	-0.0024	0.0001	-0.0003
		302	0.0021	0.0006	-0.0001	0.0000	0.0000
		303	-0.0005	0.0010	-0.0002	0.0000	0.0000
		304	-0.0019	0.0000	0.0006	-0.0001	0.0000
		305	0.0036	0.0005	-0.0007	0.0001	-0.0001
		306	-0.0008	-0.0014	0.0008	0.0002	0.0000
		307	0.0034	0.0009	-0.0004	0.0001	-0.0001
		308	-0.0007	-0.0005	-0.0007	0.0001	0.0000
		309	-0.0099	0.0005	-0.0001	0.0000	-0.0002
		310	-0.0099	0.0001	-0.0002	0.0000	0.0002
		311	0.0132	0.0008	-0.0001	0.0000	0.0002
		312	0.0132	0.0005	-0.0001	0.0000	-0.0003
		313	-0.0018	0.0010	0.0000	0.0000	0.0000
		314	0.0051	0.0011	0.0000	-0.0001	0.0001
		315	-0.0018	-0.0001	-0.0002	0.0000	0.0000
		316	0.0051	0.0000	-0.0002	0.0000	-0.0001

□

JOINT DISPLACEMENT (CM RADIANS) STRUCTURE TYPE = SPACE

JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
131	301	-0.0092	-0.0014	0.0001	0.0000	0.0002	0.0001
	302	0.0088	0.0006	-0.0001	0.0000	-0.0002	0.0001
	303	0.0083	0.0008	0.0008	-0.0001	-0.0002	0.0000
	304	-0.0025	-0.0001	0.0005	-0.0001	0.0001	-0.0001
	305	0.0103	0.0006	-0.0005	0.0001	-0.0002	0.0002
	306	-0.0131	-0.0011	-0.0006	0.0001	0.0003	-0.0001
	307	0.0125	-0.0009	-0.0003	0.0001	-0.0003	0.0002
	308	-0.0039	-0.0004	-0.0006	0.0001	0.0001	0.0000
	309	-0.0002	0.0006	-0.0001	0.0000	0.0000	0.0000
	310	-0.0002	0.0003	-0.0001	0.0000	0.0000	0.0000
	311	0.0143	0.0006	-0.0001	0.0000	-0.0003	0.0002
	312	0.0142	0.0003	-0.0001	0.0000	-0.0003	0.0002
	313	0.0049	0.0009	0.0000	0.0000	-0.0001	0.0001
	314	0.0092	0.0009	0.0000	0.0000	-0.0002	0.0002
	315	0.0048	0.0000	-0.0001	0.0000	-0.0001	0.0001
	316	0.0091	0.0000	-0.0001	0.0000	-0.0002	0.0002
132	301	0.0096	-0.0014	-0.0001	0.0000	0.0002	-0.0001
	302	-0.0088	0.0006	0.0001	0.0000	-0.0002	-0.0001
	303	-0.0126	0.0008	0.0003	-0.0001	-0.0003	-0.0002
	304	0.0039	-0.0004	0.0005	-0.0001	0.0001	0.0000
	305	-0.0104	0.0006	0.0005	-0.0001	-0.0002	0.0002
	306	0.0133	-0.0011	0.0007	-0.0001	0.0003	0.0001
	307	-0.0085	0.0007	-0.0008	0.0002	-0.0002	0.0000
	308	0.0025	-0.0001	-0.0005	0.0001	0.0001	0.0001
	309	-0.0144	0.0003	0.0001	0.0000	-0.0003	-0.0002
	310	-0.0144	0.0006	0.0000	0.0000	-0.0003	-0.0002
	311	0.0002	0.0003	0.0001	0.0000	0.0000	0.0000
	312	0.0002	0.0006	0.0000	0.0000	0.0000	0.0000
	313	-0.0092	0.0000	0.0001	0.0000	-0.0002	-0.0001
	314	-0.0048	0.0000	0.0001	0.0000	-0.0001	-0.0001
	315	-0.0093	0.0009	0.0000	0.0000	-0.0002	-0.0001
	316	-0.0050	0.0009	0.0000	0.0000	-0.0001	-0.0001
133	301	-0.0153	-0.0024	-0.0001	0.0000	-0.0004	-0.0001
	302	-0.0022	0.0006	0.0001	0.0000	0.0000	0.0000
	303	-0.0036	0.0009	0.0004	-0.0001	-0.0001	-0.0001
	304	-0.0008	-0.0005	0.0007	-0.0001	0.0000	0.0000
	305	-0.0038	0.0004	0.0007	-0.0001	-0.0001	-0.0001
	306	0.0008	-0.0014	0.0008	-0.0002	0.0000	0.0000
	307	0.0006	0.0009	-0.0010	0.0002	0.0000	0.0000
	308	0.0020	0.0000	-0.0006	0.0001	0.0000	0.0000
	309	-0.0132	0.0005	0.0001	0.0000	-0.0003	-0.0002
	310	-0.0132	0.0008	0.0001	0.0000	-0.0003	-0.0002
	311	0.0097	0.0001	0.0002	0.0000	0.0002	0.0001
	312	0.0097	0.0004	0.0001	0.0000	0.0002	0.0001
	313	-0.0051	0.0000	0.0002	0.0000	-0.0001	-0.0001
	314	0.0017	-0.0001	0.0002	0.0000	0.0000	0.0000
	315	-0.0051	0.0011	0.0000	0.0000	-0.0001	-0.0001
	316	0.0017	0.0010	0.0000	0.0000	0.0000	0.0000

□

JOINT DISPLACEMENT (CM RADIANS) STRUCTURE TYPE = SPACE

JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
134	301	0.0155	-0.0024	-0.0001	0.0000	0.0004	0.0001
	302	0.0023	0.0006	0.0001	0.0000	0.0001	0.0000
	303	0.0037	0.0008	0.0004	-0.0001	0.0001	0.0001
	304	0.0008	-0.0005	0.0007	-0.0001	0.0000	0.0000
	305	0.0039	0.0004	0.0007	-0.0001	0.0001	0.0001
	306	-0.0008	-0.0013	0.0008	-0.0002	0.0000	0.0000
	307	-0.0006	0.0009	-0.0010	0.0002	0.0000	0.0000
	308	-0.0021	0.0000	-0.0006	0.0001	0.0000	0.0000
	309	-0.0096	0.0001	0.0002	0.0000	-0.0002	-0.0001
	310	-0.0096	0.0004	0.0001	0.0000	-0.0002	-0.0001
	311	0.0132	0.0005	0.0001	0.0000	0.0003	0.0002
	312	0.0132	0.0008	0.0001	0.0000	0.0003	0.0002
	313	-0.0016	-0.0001	0.0002	0.0000	0.0000	0.0000
	314	0.0052	0.0000	0.0002	0.0000	0.0000	0.0001
	315	-0.0016	0.0010	0.0000	0.0000	0.0000	0.0000
	316	0.0052	0.0011	0.0000	0.0000	0.0001	0.0001
135	301	-0.0095	-0.0014	-0.0001	0.0000	-0.0002	0.0001
	302	0.0089	0.0006	0.0001	0.0000	0.0002	0.0001
	303	0.0127	0.0008	0.0003	-0.0001	0.0003	0.0002
	304	-0.0039	-0.0004	0.0005	-0.0001	-0.0001	0.0000
	305	0.0105	0.0006	0.0005	-0.0001	0.0002	0.0002
	306	-0.0133	-0.0011	0.0007	-0.0001	-0.0003	-0.0001
	307	0.0085	0.0007	-0.0008	0.0002	0.0002	0.0000
	308	-0.0026	-0.0001	-0.0004	0.0001	-0.0001	-0.0001
	309	-0.0002	0.0003	0.0001	0.0000	0.0000	0.0000
	310	-0.0001	0.0006	0.0000	0.0000	0.0000	0.0000
	311	0.0144	0.0003	0.0001	0.0000	0.0003	0.0002
	312	0.0144	0.0006	0.0000	0.0000	0.0003	0.0002
	313	0.0049	0.0000	0.0001	0.0000	0.0001	0.0001
	314	0.0093	0.0000	0.0001	0.0000	0.0002	0.0002
	315	0.0050	0.0009	0.0000	0.0000	0.0001	0.0001
	316	0.0094	0.0009	0.0000	0.0000	0.0002	0.0002

***** END OF LATEST ANALYSIS RESULT *****

591. LOAD LIST 201 TO 236

592. PARAMETER 1

593. CODE BS950

594. LZ 9.3 MEMB 1 TO 3 10 TO 15 22 TO 27 34 TO 39 46 TO 48 95 TO 102 562 564 566 -

595. 567 572 TO 575

596. LZ 6.65 MEMB 6 7 18 19 30 31 42 43

597. LZ 5.6 MEMB 4 5 8 9 16 17 20 21 28 29 32 33 40 41 44 45 52 TO 59

598. LZ 6 MEMB 208 218 228 236 238 240

□

599. UNL 1.5 MEMB 201 TO 218 220 TO 236 238 240 241 301 TO 320

600. KY 0.65 MEMB 501 TO 516 522 TO 525 530 TO 533 538 TO 541

601. KZ 0.65 MEMB 501 TO 516 522 TO 525 530 TO 533 538 TO 541

602. MAIN 3 MEMB 501 TO 516 522 TO 525 530 TO 533 538 TO 541

603. PY 345000 ALL

604. SBLT 1 ALL

605. SBLT 0 MEMB 501 TO 516 522 TO 525 530 TO 533 538 TO 541

606. TRACK 2 ALL

607. CHECK CODE ALL

□STEEL DESIGN □

STAAD.Pro CODE CHECKING - (BSI)

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

□

CALCULATED CAPACITIES FOR MEMB 5 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1642.4 PT= 2166.6 MB= 315.5					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

6	TAPERED	PASS	BS-4.7 (C)	0.196	207
32.01 C -0.10 56.14 3.19					

CALCULATED CAPACITIES FOR MEMB 6 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1301.0 PT= 2166.6 MB= 244.8					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

7	TAPERED	PASS	BS-4.7 (C)	0.197	207
32.05 C 0.10 -56.14 0.00					

CALCULATED CAPACITIES FOR MEMB 7 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1207.8 PT= 2166.6 MB= 228.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

8	TAPERED	PASS	BS-4.7 (C)	0.127	207
13.00 C -0.14 37.91 0.00					

CALCULATED CAPACITIES FOR MEMB 8 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1488.2 PT= 2166.6 MB= 280.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

9	TAPERED	PASS	BS-4.7 (C)	0.077	213
20.27 C -0.85 16.67 0.00					

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

□

CALCULATED CAPACITIES FOR MEMB 9 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1902.8 PT= 2166.6 MB= 324.8					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

10	TAPERED	PASS	BS-4.8.2.2	0.153	211
79.43 T 0.24 -36.54 0.00					

CALCULATED CAPACITIES FOR MEMB 10 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1663.1 PT= 2166.6 MB= 324.8					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

11	TAPERED	PASS	BS-4.8.2.2	0.154	211
80.34 T -0.24 36.54 1.02					

CALCULATED CAPACITIES FOR MEMB 11 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1663.1 PT= 2166.6 MB= 324.8					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

12	TAPERED	PASS	BS-4.7 (C)	0.262	202
93.71 C -3.69 -37.46 2.70					

CALCULATED CAPACITIES FOR MEMB 12 UNIT - kN,m SECTION CLASS 3					
MCZ= 275.6 MCY= 56.6 PC= 1421.2 PT= 2063.1 MB= 210.2					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 347 kN : qw = 207 N/mm2					
d = 280 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

13	TAPERED	PASS	BS-4.7 (C)	0.259	214
124.52 C 0.14 -48.35 2.70					

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
--------	-------	---------------	----------------------	--------------	----------------------

□

CALCULATED CAPACITIES FOR MEMB 13 UNIT - kN,m SECTION CLASS 3					
MCZ= 275.6 MCY= 56.7 PC= 1421.2 PT= 2063.1 MB= 202.9					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 347 kN : qw = 207 N/mm2					
d = 280 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

14	TAPERED	PASS	BS-4.8.2.2	0.199	211
107.05 T -0.07 48.26 1.02					

CALCULATED CAPACITIES FOR MEMB 14 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1663.1 PT= 2166.6 MB= 324.8					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

15	TAPERED	PASS	BS-4.8.2.2	0.198	211
105.62 T 0.06 -48.26 0.00					

CALCULATED CAPACITIES FOR MEMB 15 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1663.1 PT= 2166.6 MB= 324.8					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

16	TAPERED	PASS	BS-4.7 (C)	0.078	201
20.96 C -0.29 20.21 0.00					

CALCULATED CAPACITIES FOR MEMB 16 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1902.8 PT= 2166.6 MB= 324.8					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

17	TAPERED	PASS	BS-4.7 (C)	0.110	201
17.87 C -0.29 30.95 2.18					

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
--------	-------	---------------	----------------------	--------------	----------------------

□

CALCULATED CAPACITIES FOR MEMB 17 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1642.4 PT= 2166.6 MB= 315.5					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

18	TAPERED	PASS	BS-4.7 (C)	0.144	207
23.92 C -0.08 41.01 0.00					

CALCULATED CAPACITIES FOR MEMB 18 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1301.0 PT= 2166.6 MB= 244.8					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

19	TAPERED	PASS	BS-4.7 (C)	0.143	207
23.92 C 0.03 -40.65 0.00					

CALCULATED CAPACITIES FOR MEMB 19 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1207.8 PT= 2166.6 MB= 228.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

20	TAPERED	PASS	BS-4.7 (C)	0.122	207
16.57 C -0.09 35.84 0.00					

CALCULATED CAPACITIES FOR MEMB 20 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1488.2 PT= 2166.6 MB= 280.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

21	TAPERED	PASS	BS-4.7 (C)	0.081	213
20.97 C 0.34 20.75 0.00					

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
--------	-------	---------------	----------------------	--------------	----------------------

□

CALCULATED CAPACITIES FOR MEMB 21 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1902.8 PT= 2166.6 MB= 324.8					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

22	TAPERED	PASS	BS-4.8.2.2	0.198	211
		105.49 T	-0.06	-48.31	0.00

CALCULATED CAPACITIES FOR MEMB 22 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1663.1 PT= 2166.6 MB= 324.8					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

23	TAPERED	PASS	BS-4.8.2.2	0.199	211
		106.90 T	0.06	48.31	1.02

CALCULATED CAPACITIES FOR MEMB 23 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1663.1 PT= 2166.6 MB= 324.8					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

24	TAPERED	PASS	BS-4.7 (C)	0.259	202
		124.29 C	-0.14	-48.34	2.70

CALCULATED CAPACITIES FOR MEMB 24 UNIT - kN,m SECTION CLASS 3					
MCZ= 275.6 MCY= 56.6 PC= 1421.2 PT= 2063.1 MB= 210.2					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 347 kN : qw = 207 N/mm2					
d = 280 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

25	TAPERED	PASS	BS-4.7 (C)	0.259	214
		124.51 C	-0.14	-48.35	2.70

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
--------	-------	---------------	----------------------	--------------	----------------------

□

CALCULATED CAPACITIES FOR MEMB 25 UNIT - kN,m SECTION CLASS 3					
MCZ= 275.6 MCY= 56.6 PC= 1421.2 PT= 2063.1 MB= 202.9					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 347 kN : qw = 207 N/mm2					
d = 280 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

26	TAPERED	PASS	BS-4.8.2.2	0.199	211
		107.06 T	0.07	48.26	1.02

CALCULATED CAPACITIES FOR MEMB 26 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1663.1 PT= 2166.6 MB= 324.8					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

27	TAPERED	PASS	BS-4.8.2.2	0.198	211
		105.63 T	-0.06	-48.26	0.00

CALCULATED CAPACITIES FOR MEMB 27 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1663.1 PT= 2166.6 MB= 324.8					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

28	TAPERED	PASS	BS-4.7 (C)	0.078	201
		20.43 C	0.28	20.25	0.00

CALCULATED CAPACITIES FOR MEMB 28 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1902.8 PT= 2166.6 MB= 324.8					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

29	TAPERED	PASS	BS-4.7 (C)	0.109	201
		17.33 C	0.26	30.94	2.18

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
--------	-------	---------------	----------------------	--------------	----------------------

□

CALCULATED CAPACITIES FOR MEMB 29 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1642.4 PT= 2166.6 MB= 315.5					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

30	TAPERED	PASS	BS-4.7 (C)	0.143	207
		24.16 C	0.06	40.96	0.00

CALCULATED CAPACITIES FOR MEMB 30 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1301.0 PT= 2166.6 MB= 244.8					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

31	TAPERED	PASS	BS-4.7 (C)	0.143	207
		24.16 C	-0.03	-40.66	0.00

CALCULATED CAPACITIES FOR MEMB 31 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1207.8 PT= 2166.6 MB= 228.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

32	TAPERED	PASS	BS-4.7 (C)	0.122	207
		16.73 C	0.09	35.81	0.00

CALCULATED CAPACITIES FOR MEMB 32 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1488.2 PT= 2166.6 MB= 280.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

33	TAPERED	PASS	BS-4.7 (C)	0.081	213
		21.00 C	-0.34	20.74	0.00

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
--------	-------	---------------	----------------------	--------------	----------------------

□

CALCULATED CAPACITIES FOR MEMB 33 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1902.8 PT= 2166.6 MB= 324.8					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

34	TAPERED	PASS	BS-4.8.2.2	0.198	211
		105.49 T	0.06	-48.31	0.00

CALCULATED CAPACITIES FOR MEMB 34 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1663.1 PT= 2166.6 MB= 324.8					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

35	TAPERED	PASS	BS-4.8.2.2	0.199	211
		106.90 T	-0.06	48.31	1.02

CALCULATED CAPACITIES FOR MEMB 35 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1663.1 PT= 2166.6 MB= 324.8					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

36	TAPERED	PASS	BS-4.7 (C)	0.259	202
		124.32 C	0.14	-48.34	2.70

CALCULATED CAPACITIES FOR MEMB 36 UNIT - kN,m SECTION CLASS 3					
MCZ= 275.6 MCY= 56.6 PC= 1421.2 PT= 2063.1 MB= 210.2					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 347 kN : qw = 207 N/mm2					
d = 280 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

37	TAPERED	PASS	BS-4.7 (C)	0.262	214
		93.79 C	-3.69	-37.46	2.70

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
--------	-------	---------------	----------------------	--------------	----------------------

□

CALCULATED CAPACITIES FOR MEMB 37 UNIT - kN,m SECTION CLASS 3					
MCZ= 275.6 MCY= 56.7 PC= 1421.2 PT= 2063.1 MB= 202.9					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 347 kN : qw = 207 N/mm2					
d = 280 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

38 TAPERED PASS BS-4.8.2.2 0.154 211					
80.47 T -0.25 36.49 1.02					

CALCULATED CAPACITIES FOR MEMB 38 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1663.1 PT= 2166.6 MB= 324.8					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

39 TAPERED PASS BS-4.8.2.2 0.153 211					
79.54 T 0.24 -36.49 0.00					

CALCULATED CAPACITIES FOR MEMB 39 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1663.1 PT= 2166.6 MB= 324.8					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

40 TAPERED PASS BS-4.7 (C) 0.073 201					
19.00 C -0.75 16.15 0.00					

CALCULATED CAPACITIES FOR MEMB 40 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1902.8 PT= 2166.6 MB= 324.8					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

41 TAPERED PASS BS-4.7 (C) 0.095 201					
16.41 C -0.28 26.30 2.18					

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
--------	-------	---------------	----------------------	--------------	----------------------

□

CALCULATED CAPACITIES FOR MEMB 41 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1642.4 PT= 2166.6 MB= 315.5					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

42 TAPERED PASS BS-4.7 (C) 0.196 207					
32.02 C 0.10 56.14 3.19					

CALCULATED CAPACITIES FOR MEMB 42 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1301.0 PT= 2166.6 MB= 244.8					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

43 TAPERED PASS BS-4.7 (C) 0.197 207					
32.05 C -0.10 -56.14 0.00					

CALCULATED CAPACITIES FOR MEMB 43 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1207.8 PT= 2166.6 MB= 228.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

44 TAPERED PASS BS-4.7 (C) 0.127 207					
13.00 C 0.14 37.91 0.00					

CALCULATED CAPACITIES FOR MEMB 44 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1488.2 PT= 2166.6 MB= 280.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

45 TAPERED PASS BS-4.7 (C) 0.077 213					
20.23 C 0.85 16.66 0.00					

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

□

CALCULATED CAPACITIES FOR MEMB 45 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1902.8 PT= 2166.6 MB= 324.8					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

46 TAPERED PASS BS-4.8.2.2 0.153 211					
79.43 T -0.24 -36.54 0.00					

CALCULATED CAPACITIES FOR MEMB 46 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1663.1 PT= 2166.6 MB= 324.8					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

47	TAPERED	PASS	BS-4.8.2.2	0.154	211
80.34 T	0.24	36.54	1.02		

CALCULATED CAPACITIES FOR MEMB 47 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1663.1 PT= 2166.6 MB= 324.8					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

48	TAPERED	PASS	BS-4.7 (C)	0.262	202
93.71 C	3.69	-37.46	2.70		

CALCULATED CAPACITIES FOR MEMB 48 UNIT - kN,m SECTION CLASS 3					
MCZ= 275.6 MCY= 56.6 PC= 1421.2 PT= 2063.1 MB= 210.2					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 347 kN : qw = 207 N/mm2					
d = 280 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

52	TAPERED	PASS	BS-4.7 (C)	0.095	213
17.27 C	-0.29	-26.11	0.00		

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

□

CALCULATED CAPACITIES FOR MEMB 52 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1763.3 PT= 2166.6 MB= 324.8					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

53 TAPERED PASS BS-4.7 (C) 0.108 213					
17.41 C 0.32 -30.33 0.00					

CALCULATED CAPACITIES FOR MEMB 53 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1763.1 PT= 2166.6 MB= 324.8					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

54	TAPERED	PASS	BS-4.7 (C)	0.108	213
17.44 C	-0.32	-30.31	0.00		

CALCULATED CAPACITIES FOR MEMB 54 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1763.1 PT= 2166.6 MB= 324.8					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

55	TAPERED	PASS	BS-4.7 (C)	0.095	213
17.23 C	0.29	-26.10	0.00		

CALCULATED CAPACITIES FOR MEMB 55 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1763.1 PT= 2166.6 MB= 324.8					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

56	TAPERED	PASS	BS-4.7 (C)	0.136	207
11.83 C	0.15	-41.04	2.52		

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

□

CALCULATED CAPACITIES FOR MEMB 56 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1532.6 PT= 2166.6 MB= 290.0					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required: Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

57 TAPERED PASS BS-4.7 (C) 0.132 207					
16.99 C 0.10 -38.96 2.52					

CALCULATED CAPACITIES FOR MEMB 57 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1532.6 PT= 2166.6 MB= 290.0					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required: Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

58 TAPERED PASS BS-4.7 (C) 0.131 207					
16.48 C -0.08 -39.02 2.52					

CALCULATED CAPACITIES FOR MEMB 58 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1532.6 PT= 2166.6 MB= 290.0					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required: Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

59 TAPERED PASS BS-4.7 (C) 0.135 207					
11.83 C -0.13 -41.04 2.52					

CALCULATED CAPACITIES FOR MEMB 59 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1532.6 PT= 2166.6 MB= 290.0					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required: Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

95 TAPERED PASS BS-4.7 (C) 0.302 214					
68.91 C 6.87 37.46 0.00					

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

□

CALCULATED CAPACITIES FOR MEMB 95 UNIT - kN,m SECTION CLASS 3					
MCZ= 275.6 MCY= 56.6 PC= 1426.5 PT= 2063.1 MB= 243.9					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required: Vb = 409 kN : qw = 207 N/mm2					
d = 330 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

96 TAPERED PASS BS-4.7 (C) 0.241 215					
89.45 C -0.23 49.36 0.00					

CALCULATED CAPACITIES FOR MEMB 96 UNIT - kN,m SECTION CLASS 3					
MCZ= 275.6 MCY= 56.6 PC= 1426.5 PT= 2063.1 MB= 243.9					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required: Vb = 409 kN : qw = 207 N/mm2					
d = 330 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

97 TAPERED PASS BS-4.7 (C) 0.241 215					
89.44 C 0.23 49.36 0.00					

CALCULATED CAPACITIES FOR MEMB 97 UNIT - kN,m SECTION CLASS 3					
MCZ= 275.6 MCY= 56.6 PC= 1426.5 PT= 2063.1 MB= 243.9					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required: Vb = 409 kN : qw = 207 N/mm2					
d = 330 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

98 TAPERED PASS BS-4.7 (C) 0.302 214					
68.91 C -6.87 37.46 0.00					

CALCULATED CAPACITIES FOR MEMB 98 UNIT - kN,m SECTION CLASS 3					
MCZ= 275.6 MCY= 56.6 PC= 1426.5 PT= 2063.1 MB= 243.9					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required: Vb = 409 kN : qw = 207 N/mm2					
d = 330 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

99 TAPERED PASS BS-4.7 (C) 0.302 202					
68.82 C -6.87 37.46 0.00					

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

□

CALCULATED CAPACITIES FOR MEMB 99 UNIT - kN,m SECTION CLASS 3					
MCZ= 275.6 MCY= 56.6 PC= 1426.5 PT= 2063.1 MB= 243.9					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 409 kN : qw = 207 N/mm2					
d = 330 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

100	TAPERED	PASS	BS-4.7 (C)	0.241	203
89.27 C 0.23 49.36 0.00					

CALCULATED CAPACITIES FOR MEMB 100 UNIT - kN,m SECTION CLASS 3					
MCZ= 275.6 MCY= 56.6 PC= 1426.5 PT= 2063.1 MB= 243.9					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 409 kN : qw = 207 N/mm2					
d = 330 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

101	TAPERED	PASS	BS-4.7 (C)	0.241	203
89.30 C -0.23 49.36 0.00					

CALCULATED CAPACITIES FOR MEMB 101 UNIT - kN,m SECTION CLASS 3					
MCZ= 275.6 MCY= 56.6 PC= 1426.5 PT= 2063.1 MB= 243.9					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 409 kN : qw = 207 N/mm2					
d = 330 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

102	TAPERED	PASS	BS-4.7 (C)	0.302	202
68.82 C 6.87 37.46 0.00					

CALCULATED CAPACITIES FOR MEMB 102 UNIT - kN,m SECTION CLASS 3					
MCZ= 275.6 MCY= 56.6 PC= 1426.5 PT= 2063.1 MB= 243.9					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 409 kN : qw = 207 N/mm2					
d = 330 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

201	TAPERED	PASS	BS-4.7 (C)	0.092	207
0.55 C -1.75 -7.99 1.50					

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

□

CALCULATED CAPACITIES FOR MEMB 201 UNIT - kN,m SECTION CLASS 2					
MCZ= 170.4 MCY= 38.8 PC= 1266.8 PT= 0.0 MB= 190.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 347 kN : qw = 207 N/mm2					
d = 280 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

202	TAPERED	PASS	BS-4.7 (C)	0.307	201
43.82 C -0.13 -28.13 3.79					

CALCULATED CAPACITIES FOR MEMB 202 UNIT - kN,m SECTION CLASS 2					
MCZ= 170.4 MCY= 38.8 PC= 248.4 PT= 1614.6 MB= 190.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 347 kN : qw = 207 N/mm2					
d = 280 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

203	TAPERED	PASS	BS-4.7 (C)	0.293	201
37.62 C 0.05 -31.67 3.00					

CALCULATED CAPACITIES FOR MEMB 203 UNIT - kN,m SECTION CLASS 2					
MCZ= 170.4 MCY= 38.8 PC= 282.3 PT= 1614.6 MB= 190.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 347 kN : qw = 207 N/mm2					
d = 280 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

204	TAPERED	PASS	BS-4.7 (C)	0.307	201
43.96 C -0.13 -28.12 2.71					

CALCULATED CAPACITIES FOR MEMB 204 UNIT - kN,m SECTION CLASS 2					
MCZ= 170.4 MCY= 38.8 PC= 248.4 PT= 1614.6 MB= 190.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 347 kN : qw = 207 N/mm2					
d = 280 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

205	TAPERED	PASS	BS-4.7 (C)	0.092	207
0.55 C 1.75 7.99 0.00					

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
--------	-------	---------------	----------------------	--------------	----------------------

□

-----CALCULATED CAPACITIES FOR MEMB 205 UNIT - kN,m SECTION CLASS 2					
MCZ= 170.4 MCY= 38.8 PC= 1267.4 PT= 0.0 MB= 190.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 347 kN : qw = 207 N/mm2					
d = 280 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

206 TAPERED PASS BS-4.7 (C) 0.083 207					
0.17 C 0.55 -11.69 1.80					

-----CALCULATED CAPACITIES FOR MEMB 206 UNIT - kN,m SECTION CLASS 2					
MCZ= 170.4 MCY= 38.8 PC= 1174.4 PT= 1614.6 MB= 190.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 347 kN : qw = 207 N/mm2					
d = 280 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

207 TAPERED PASS BS-4.3.6 0.206 218					
0.28 T 0.01 8.91 3.25					

-----CALCULATED CAPACITIES FOR MEMB 207 UNIT - kN,m SECTION CLASS 2					
MCZ= 170.4 MCY= 38.8 PC= 5224.1 PT= 1614.6 MB= 190.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 347 kN : qw = 207 N/mm2					
d = 280 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

208 TAPERED PASS BS-4.3.6 0.191 218					
0.13 T -0.09 7.74 2.80					

-----CALCULATED CAPACITIES FOR MEMB 208 UNIT - kN,m SECTION CLASS 2					
MCZ= 170.4 MCY= 38.8 PC= 839.5 PT= 1614.6 MB= 190.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 347 kN : qw = 207 N/mm2					
d = 280 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

209 TAPERED PASS BS-4.3.6 0.206 218					
0.28 T 0.01 8.91 3.25					

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
--------	-------	---------------	----------------------	--------------	----------------------

□

-----CALCULATED CAPACITIES FOR MEMB 209 UNIT - kN,m SECTION CLASS 2					
MCZ= 170.4 MCY= 38.8 PC= 3734.2 PT= 1614.6 MB= 190.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 347 kN : qw = 207 N/mm2					
d = 280 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

210 TAPERED PASS BS-4.7 (C) 0.083 207					
0.18 C -0.56 11.69 0.00					

-----CALCULATED CAPACITIES FOR MEMB 210 UNIT - kN,m SECTION CLASS 2					
MCZ= 170.4 MCY= 38.8 PC= 1174.4 PT= 1614.6 MB= 190.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 347 kN : qw = 207 N/mm2					
d = 280 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

211 TAPERED PASS BS-4.3.6 0.215 201					
0.01 T 0.02 35.20 3.00					

-----CALCULATED CAPACITIES FOR MEMB 211 UNIT - kN,m SECTION CLASS 2					
MCZ= 170.4 MCY= 38.8 PC= 777.3 PT= 1614.6 MB= 190.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 347 kN : qw = 207 N/mm2					
d = 280 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

212 TAPERED PASS BS-4.3.6 0.254 218					
1.66 T -0.01 11.36 0.00					

-----CALCULATED CAPACITIES FOR MEMB 212 UNIT - kN,m SECTION CLASS 2					
MCZ= 170.4 MCY= 38.8 PC= 248.4 PT= 1614.6 MB= 190.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 347 kN : qw = 207 N/mm2					
d = 280 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

213 TAPERED PASS BS-4.3.6 0.228 218					
0.54 C 0.00 10.55 3.00					

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

□

CALCULATED CAPACITIES FOR MEMB 213 UNIT - kN,m SECTION CLASS 2					
MCZ= 170.4 MCY= 38.8 PC= 282.3 PT= 1614.6 MB= 190.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required: Vb = 347 kN : qw = 207 N/mm2					
d = 280 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

214	TAPERED	PASS	BS-4.3.6	0.253	218
		2.17 T	0.00	11.38	6.50

CALCULATED CAPACITIES FOR MEMB 214 UNIT - kN,m SECTION CLASS 2					
MCZ= 170.4 MCY= 38.8 PC= 248.4 PT= 1614.6 MB= 190.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required: Vb = 347 kN : qw = 207 N/mm2					
d = 280 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

215	TAPERED	PASS	BS-4.3.6	0.215	201
		0.01 T	-0.03	35.20	0.00

CALCULATED CAPACITIES FOR MEMB 215 UNIT - kN,m SECTION CLASS 2					
MCZ= 170.4 MCY= 38.8 PC= 777.3 PT= 1614.6 MB= 190.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required: Vb = 347 kN : qw = 207 N/mm2					
d = 280 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

216	TAPERED	PASS	BS-4.3.6	0.275	207
		3.38 T	0.00	44.73	3.20

CALCULATED CAPACITIES FOR MEMB 216 UNIT - kN,m SECTION CLASS 2					
MCZ= 170.4 MCY= 38.8 PC= 719.1 PT= 1614.6 MB= 190.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required: Vb = 347 kN : qw = 207 N/mm2					
d = 280 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

217	TAPERED	PASS	BS-4.3.6	0.303	218
		1.37 T	0.00	23.80	0.00

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

□

CALCULATED CAPACITIES FOR MEMB 217 UNIT - kN,m SECTION CLASS 2					
MCZ= 170.4 MCY= 38.8 PC= 248.4 PT= 1614.6 MB= 190.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required: Vb = 347 kN : qw = 207 N/mm2					
d = 280 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

218	TAPERED	PASS	BS-4.3.6	0.240	212
		0.44 C	0.00	8.55	3.00

CALCULATED CAPACITIES FOR MEMB 218 UNIT - kN,m SECTION CLASS 2					
MCZ= 170.4 MCY= 38.8 PC= 777.3 PT= 1614.6 MB= 190.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required: Vb = 347 kN : qw = 207 N/mm2					
d = 280 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

220	TAPERED	PASS	BS-4.3.6	0.275	207
		3.39 T	0.00	44.73	0.00

CALCULATED CAPACITIES FOR MEMB 220 UNIT - kN,m SECTION CLASS 2					
MCZ= 170.4 MCY= 38.8 PC= 719.1 PT= 1614.6 MB= 190.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required: Vb = 347 kN : qw = 207 N/mm2					
d = 280 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

221	TAPERED	PASS	BS-4.3.6	0.215	207
		0.01 T	-0.03	35.22	3.00

CALCULATED CAPACITIES FOR MEMB 221 UNIT - kN,m SECTION CLASS 2					
MCZ= 170.4 MCY= 38.8 PC= 777.3 PT= 1614.6 MB= 190.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required: Vb = 347 kN : qw = 207 N/mm2					
d = 280 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

222	TAPERED	PASS	BS-4.3.6	0.253	206
		2.35 T	0.01	11.33	0.00

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

□

CALCULATED CAPACITIES FOR MEMB 222 UNIT - kN,m SECTION CLASS 2					
MCZ=	170.4	MCY=	38.8	PC=	248.4 PT= 1614.6 MB= 190.6
BUCKLING CO-EFFICIENTS	mLT = 1.00,	mx = 0.00,	my = 0.00,	myx = 0.00	
Shear Buckling check is required :	Vb = 347 kN :	qw			= 207 N/mm2
d = 280 mm :	t = 6 mm	: a =	0 mm :	pyf = 344 N/mm2	
BS-4.4.3.2	status = PASS		: BS-4.4.3.3	status = PASS	

223	TAPERED	PASS	BS-4.3.6	0.228	206
		0.15 C	0.00	10.55	3.00

CALCULATED CAPACITIES FOR MEMB 223 UNIT - kN,m SECTION CLASS 2					
MCZ=	170.4	MCY=	38.8	PC=	282.3 PT= 1614.6 MB= 190.6
BUCKLING CO-EFFICIENTS	mLT = 1.00,	mx = 0.00,	my = 0.00,	myx = 0.00	
Shear Buckling check is required :	Vb = 347 kN :	qw			= 207 N/mm2
d = 280 mm :	t = 6 mm	: a =	0 mm :	pyf = 344 N/mm2	
BS-4.4.3.2	status = PASS		: BS-4.4.3.3	status = PASS	

224	TAPERED	PASS	BS-4.3.6	0.253	206
		2.35 T	-0.01	11.33	6.50

CALCULATED CAPACITIES FOR MEMB 224 UNIT - kN,m SECTION CLASS 2					
MCZ=	170.4	MCY=	38.8	PC=	248.4 PT= 1614.6 MB= 190.6
BUCKLING CO-EFFICIENTS	mLT = 1.00,	mx = 0.00,	my = 0.00,	myx = 0.00	
Shear Buckling check is required :	Vb = 347 kN :	qw			= 207 N/mm2
d = 280 mm :	t = 6 mm	: a =	0 mm :	pyf = 344 N/mm2	
BS-4.4.3.2	status = PASS		: BS-4.4.3.3	status = PASS	

225	TAPERED	PASS	BS-4.3.6	0.215	207
		0.01 T	0.03	35.22	0.00

CALCULATED CAPACITIES FOR MEMB 225 UNIT - kN,m SECTION CLASS 2					
MCZ=	170.4	MCY=	38.8	PC=	777.3 PT= 1614.6 MB= 190.6
BUCKLING CO-EFFICIENTS	mLT = 1.00,	mx = 0.00,	my = 0.00,	myx = 0.00	
Shear Buckling check is required :	Vb = 347 kN :	qw			= 207 N/mm2
d = 280 mm :	t = 6 mm	: a =	0 mm :	pyf = 344 N/mm2	
BS-4.4.3.2	status = PASS		: BS-4.4.3.3	status = PASS	

226	TAPERED	PASS	BS-4.7 (C)	0.085	207
		0.23 C	-0.62	-11.68	1.80

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

□

CALCULATED CAPACITIES FOR MEMB 226 UNIT - kN,m SECTION CLASS 2					
MCZ=	170.4	MCY=	38.8	PC=	1174.4 PT= 1614.6 MB= 190.6
BUCKLING CO-EFFICIENTS	mLT = 1.00,	mx = 0.00,	my = 0.00,	myx = 0.00	
Shear Buckling check is required :	Vb = 347 kN :	qw			= 207 N/mm2
d = 280 mm :	t = 6 mm	: a =	0 mm :	pyf = 344 N/mm2	
BS-4.4.3.2	status = PASS		: BS-4.4.3.3	status = PASS	

227	TAPERED	PASS	BS-4.3.6	0.207	206
		0.34 T	-0.02	8.90	3.25

CALCULATED CAPACITIES FOR MEMB 227 UNIT - kN,m SECTION CLASS 2					
MCZ=	170.4	MCY=	38.8	PC=	5224.1 PT= 1614.6 MB= 190.6
BUCKLING CO-EFFICIENTS	mLT = 1.00,	mx = 0.00,	my = 0.00,	myx = 0.00	
Shear Buckling check is required :	Vb = 347 kN :	qw			= 207 N/mm2
d = 280 mm :	t = 6 mm	: a =	0 mm :	pyf = 344 N/mm2	
BS-4.4.3.2	status = PASS		: BS-4.4.3.3	status = PASS	

228	TAPERED	PASS	BS-4.3.6	0.191	206
		0.17 T	0.10	7.73	3.00

CALCULATED CAPACITIES FOR MEMB 228 UNIT - kN,m SECTION CLASS 2					
MCZ=	170.4	MCY=	38.8	PC=	777.3 PT= 1614.6 MB= 190.6
BUCKLING CO-EFFICIENTS	mLT = 1.00,	mx = 0.00,	my = 0.00,	myx = 0.00	
Shear Buckling check is required :	Vb = 347 kN :	qw			= 207 N/mm2
d = 280 mm :	t = 6 mm	: a =	0 mm :	pyf = 344 N/mm2	
BS-4.4.3.2	status = PASS		: BS-4.4.3.3	status = PASS	

229	TAPERED	PASS	BS-4.3.6	0.206	206
		0.34 T	-0.02	8.90	3.25

CALCULATED CAPACITIES FOR MEMB 229 UNIT - kN,m SECTION CLASS 2					
MCZ=	170.4	MCY=	38.8	PC=	3457.6 PT= 1614.6 MB= 190.6
BUCKLING CO-EFFICIENTS	mLT = 1.00,	mx = 0.00,	my = 0.00,	myx = 0.00	
Shear Buckling check is required :	Vb = 347 kN :	qw			= 207 N/mm2
d = 280 mm :	t = 6 mm	: a =	0 mm :	pyf = 344 N/mm2	
BS-4.4.3.2	status = PASS		: BS-4.4.3.3	status = PASS	

230	TAPERED	PASS	BS-4.7 (C)	0.085	207
		0.23 C	0.62	11.68	0.00

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
--------	-------	---------------	----------------------	--------------	----------------------

□

-----CALCULATED CAPACITIES FOR MEMB 230 UNIT - kN-m SECTION CLASS 2					
	MCZ=	170.4	MCY= 38.8	PC= 1174.4	PT= 1614.6 MB= 190.6
	BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00				
	Shear Buckling check is required : Vb = 347 kN : qw = 207 N/mm2				
	d = 280 mm	:	t = 6 mm	:	a = 0 mm : pyf = 344 N/mm2
	BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS				

231	TAPERED	PASS	BS-4.7 (C)	0.090	207
		0.60 C	1.64	-7.97	1.50

-----CALCULATED CAPACITIES FOR MEMB 231 UNIT - kN,m SECTION CLASS 2										
	MCZ=	170.4	MCY=	38.8	PC=	1267.4	PT=	0.0	MB=	190.6
	BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00									
	Shear Buckling check is required : Vb = 347 kN : qw = 207 N/mm2									
	d =	280 mm	:	t =	6 mm	:	a =	0 mm	:	pyf = 344 N/mm2
	BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS									

232	TAPERED	PASS	BS-4.7 (C)	0.308	213
		44.28 C	0.12	-28.12	3.79

-----CALCULATED CAPACITIES FOR MEMB 232 UNIT - kN,m SECTION CLASS 2												
	MCZ=	170.4	MCY=	38.8	PC=	248.4	PT=	1614.6	MB=	190.6		
	BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00											
	Shear Buckling check is required : Vb = 347 kN : qw = 207 N/mm2											
	d =	280 mm	:	t =	6 mm	:	a =	0 mm	:	pyf =	344 N/mm2	
	BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS											

233	TAPERED	PASS	BS-4.7 (C)	0.290	213
		36.44 C	-0.04	-31.67	3.00

-----CALCULATED CAPACITIES FOR MEMB 233 UNIT - kN,m SECTION CLASS 2										
	MCZ=	170.4	MCY=	38.8	PC=	282.3	PT=	1614.6	MB=	190.6
	BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00									
	Shear Buckling check is required : Vb = 347 kN : qw = 207 N/mm2									
	d =	280 mm	:	t =	6 mm	:	a =	0 mm	:	pyf = 344 N/mm2
	BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS									

234	TAPERED	PASS	BS-4.7 (C)	0.308	213
		44.27 C	0.12	-28.12	2.71

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
--------	-------	---------------	----------------------	--------------	----------------------

□

-----CALCULATED CAPACITIES FOR MEMB 234 UNIT - kN,m SECTION CLASS 2					
	MCZ=	170.4	MCY= 38.8	PC= 248.4	PT= 1614.6 MB= 190.6
	BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00				
	Shear Buckling check is required : Vb = 347 kN : qw = 207 N/mm2				
	d = 280 mm	:	t = 6 mm	:	a = 0 mm : pyf = 344 N/mm2
	BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS				

235	TAPERED	PASS	BS-4.7 (C)	0.090	207
		0.60 C	-1.64	7.97	0.00

-----CALCULATED CAPACITIES FOR MEMB 235 UNIT - kN,m SECTION CLASS 2										
	MCZ=	170.4	MCY=	38.8	PC=	1267.4	PT=	0.0	MB=	190.6
	BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00									
	Shear Buckling check is required : Vb = 347 kN : qw = 207 N/mm2									
	d =	280 mm	:	t =	6 mm	:	a =	0 mm	:	pyf = 344 N/mm2
	BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS									

236	TAPERED	PASS	BS-4.3.6	0.193	218
		0.15 T	0.08	7.86	0.27

-----CALCULATED CAPACITIES FOR MEMB 236 UNIT - kN,m SECTION CLASS 2												
	MCZ=	170.4	MCY=	38.8	PC=	719.1	PT=	1614.6	MB=	190.6		
	BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00											
	Shear Buckling check is required : Vb = 347 kN : qw = 207 N/mm2											
	d =	280 mm	:	t =	6 mm	:	a =	0 mm	:	pyf =	344 N/mm2	
	BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS											

238	TAPERED	PASS	BS-4.3.6	0.240	212
		0.44 C	0.00	8.55	0.00

-----CALCULATED CAPACITIES FOR MEMB 238 UNIT - kN,m SECTION CLASS 2										
	MCZ=	170.4	MCY=	38.8	PC=	777.3	PT=	1614.6	MB=	190.6
	BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00									
	Shear Buckling check is required : Vb = 347 kN : qw = 207 N/mm2									
	d =	280 mm	:	t =	6 mm	:	a =	0 mm	:	pyf = 344 N/mm2
	BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS									

240	TAPERED	PASS	BS-4.3.6	0.191	206
		0.17 T	-0.10	7.73	0.00

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
--------	-------	---------------	----------------------	--------------	----------------------

□

CALCULATED CAPACITIES FOR MEMB 240 UNIT - kN,m SECTION CLASS 2					
MCZ=	170.4	MCY=	38.8	PC=	777.3 PT= 1614.6 MB= 190.6
BUCKLING CO-EFFICIENTS	mLT = 1.00,	mx = 0.00,	my = 0.00,	myx = 0.00	
Shear Buckling check is required :	Vb = 347 kN :	qw			= 207 N/mm2
d = 280 mm :	t = 6 mm	:	a = 0 mm :	pyf = 344 N/mm2	
BS-4.4.3.2	status = PASS	:	BS-4.4.3.3	status = PASS	

241	TAPERED	PASS	BS-4.3.6	0.295	212
		0.42 C	0.00	9.80	6.50

CALCULATED CAPACITIES FOR MEMB 241 UNIT - kN,m SECTION CLASS 2					
MCZ=	170.4	MCY=	38.8	PC=	248.4 PT= 1614.6 MB= 190.6
BUCKLING CO-EFFICIENTS	mLT = 1.00,	mx = 0.00,	my = 0.00,	myx = 0.00	
Shear Buckling check is required :	Vb = 347 kN :	qw			= 207 N/mm2
d = 280 mm :	t = 6 mm	:	a = 0 mm :	pyf = 344 N/mm2	
BS-4.4.3.2	status = PASS	:	BS-4.4.3.3	status = PASS	

301	TAPERED	PASS	BS-4.7 (C)	0.063	214
		0.00	-3.87	6.28	1.30

CALCULATED CAPACITIES FOR MEMB 301 UNIT - kN,m SECTION CLASS 3					
MCZ=	257.7	MCY=	100.2	PC=	2334.0 PT= 2537.8 MB= 257.7
BUCKLING CO-EFFICIENTS	mLT = 1.00,	mx = 0.00,	my = 0.00,	myx = 0.00	
Shear Buckling check is required :	Vb = 280 kN :	qw			= 207 N/mm2
d = 226 mm :	t = 6 mm	:	a = 0 mm :	pyf = 344 N/mm2	
BS-4.4.3.2	status = PASS	:	BS-4.4.3.3	status = PASS	

302	TAPERED	PASS	BS-4.8.2.2	0.237	211
		2.46 T	-10.34	-34.31	3.25

CALCULATED CAPACITIES FOR MEMB 302 UNIT - kN,m SECTION CLASS 3					
MCZ=	257.7	MCY=	100.2	PC=	10382.0 PT= 2537.8 MB= 257.7
BUCKLING CO-EFFICIENTS	mLT = 1.00,	mx = 0.00,	my = 0.00,	myx = 0.00	
Shear Buckling check is required :	Vb = 280 kN :	qw			= 207 N/mm2
d = 226 mm :	t = 6 mm	:	a = 0 mm :	pyf = 344 N/mm2	
BS-4.4.3.2	status = PASS	:	BS-4.4.3.3	status = PASS	

303	TAPERED	PASS	BS-4.8.2.2	0.187	214
		3.17 T	-5.56	33.45	3.00

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
--------	-------	---------------	----------------------	--------------	----------------------

□

CALCULATED CAPACITIES FOR MEMB 303 UNIT - kN,m SECTION CLASS 3					
MCZ=	257.7	MCY=	100.2	PC=	46181.7 PT= 2537.8 MB= 257.7
BUCKLING CO-EFFICIENTS	mLT = 1.00,	mx = 0.00,	my = 0.00,	myx = 0.00	
Shear Buckling check is required :	Vb = 280 kN :	qw			= 207 N/mm2
d = 226 mm :	t = 6 mm	:	a = 0 mm :	pyf = 344 N/mm2	
BS-4.4.3.2	status = PASS	:	BS-4.4.3.3	status = PASS	

304	TAPERED	PASS	BS-4.8.2.2	0.237	211
		2.46 T	-10.34	-34.31	3.25

CALCULATED CAPACITIES FOR MEMB 304 UNIT - kN,m SECTION CLASS 3					
MCZ=	257.7	MCY=	100.2	PC=	205426.3 PT= 2537.8 MB= 257.7
BUCKLING CO-EFFICIENTS	mLT = 1.00,	mx = 0.00,	my = 0.00,	myx = 0.00	
Shear Buckling check is required :	Vb = 280 kN :	qw			= 207 N/mm2
d = 226 mm :	t = 6 mm	:	a = 0 mm :	pyf = 344 N/mm2	
BS-4.4.3.2	status = PASS	:	BS-4.4.3.3	status = PASS	

305	TAPERED	PASS	BS-4.7 (C)	0.063	214
		0.00	3.87	-6.28	0.00

CALCULATED CAPACITIES FOR MEMB 305 UNIT - kN,m SECTION CLASS 3					
MCZ=	257.7	MCY=	100.2	PC=	2334.1 PT= 2537.8 MB= 257.7
BUCKLING CO-EFFICIENTS	mLT = 1.00,	mx = 0.00,	my = 0.00,	myx = 0.00	
Shear Buckling check is required :	Vb = 280 kN :	qw			= 207 N/mm2
d = 226 mm :	t = 6 mm	:	a = 0 mm :	pyf = 344 N/mm2	
BS-4.4.3.2	status = PASS	:	BS-4.4.3.3	status = PASS	

306	TAPERED	PASS	BS-4.7 (C)	0.063	202
		0.00	-3.87	-6.28	1.30

CALCULATED CAPACITIES FOR MEMB 306 UNIT - kN,m SECTION CLASS 3					
MCZ=	257.7	MCY=	100.2	PC=	2334.1 PT= 2537.8 MB= 257.7
BUCKLING CO-EFFICIENTS	mLT = 1.00,	mx = 0.00,	my = 0.00,	myx = 0.00	
Shear Buckling check is required :	Vb = 280 kN :	qw			= 207 N/mm2
d = 226 mm :	t = 6 mm	:	a = 0 mm :	pyf = 344 N/mm2	
BS-4.4.3.2	status = PASS	:	BS-4.4.3.3	status = PASS	

307	TAPERED	PASS	BS-4.8.2.2	0.237	211
		2.45 T	-10.34	34.31	3.25

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

□

CALCULATED CAPACITIES FOR MEMB 307 UNIT - kN,m SECTION CLASS 3					
MCZ= 257.7 MCY= 100.2 PC= 10382.5 PT= 2537.8 MB= 257.7					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required: Vb = 280 kN : qw = 207 N/mm2					
d = 226 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

308	TAPERED	PASS	BS-4.8.2.2	0.187	202
		3.16 T	-5.56	-33.45	3.00

CALCULATED CAPACITIES FOR MEMB 308 UNIT - kN,m SECTION CLASS 3					
MCZ= 257.7 MCY= 100.2 PC= 46183.5 PT= 2537.8 MB= 257.7					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required: Vb = 280 kN : qw = 207 N/mm2					
d = 226 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

309	TAPERED	PASS	BS-4.8.2.2	0.237	211
		2.45 T	-10.34	34.31	3.25

CALCULATED CAPACITIES FOR MEMB 309 UNIT - kN,m SECTION CLASS 3					
MCZ= 257.7 MCY= 100.2 PC=205434.5 PT= 2537.8 MB= 257.7					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required: Vb = 280 kN : qw = 207 N/mm2					
d = 226 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

310	TAPERED	PASS	BS-4.7 (C)	0.063	202
		0.00	3.87	6.28	0.00

CALCULATED CAPACITIES FOR MEMB 310 UNIT - kN,m SECTION CLASS 3					
MCZ= 257.7 MCY= 100.2 PC= 2334.1 PT= 2537.8 MB= 257.7					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required: Vb = 280 kN : qw = 207 N/mm2					
d = 226 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

311	TAPERED	PASS	BS-4.7 (C)	0.048	214
		0.00	-3.28	3.93	1.30

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

□

CALCULATED CAPACITIES FOR MEMB 311 UNIT - kN,m SECTION CLASS 3					
MCZ= 257.7 MCY= 100.2 PC= 2334.1 PT= 2537.8 MB= 257.7					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required: Vb = 280 kN : qw = 207 N/mm2					
d = 226 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

312	TAPERED	PASS	BS-4.7 (C)	0.168	214
		3.35 C	-7.86	22.30	3.25

CALCULATED CAPACITIES FOR MEMB 312 UNIT - kN,m SECTION CLASS 3					
MCZ= 257.7 MCY= 100.2 PC= 1045.9 PT= 2537.8 MB= 257.7					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required: Vb = 280 kN : qw = 207 N/mm2					
d = 226 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

313	TAPERED	PASS	BS-4.7 (C)	0.135	214
		3.53 C	-5.18	20.92	3.00

CALCULATED CAPACITIES FOR MEMB 313 UNIT - kN,m SECTION CLASS 3					
MCZ= 257.7 MCY= 100.2 PC= 1154.2 PT= 2537.8 MB= 257.7					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required: Vb = 280 kN : qw = 207 N/mm2					
d = 226 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

314	TAPERED	PASS	BS-4.7 (C)	0.168	214
		3.35 C	-7.86	22.31	3.25

CALCULATED CAPACITIES FOR MEMB 314 UNIT - kN,m SECTION CLASS 3					
MCZ= 257.7 MCY= 100.2 PC= 1045.9 PT= 2537.8 MB= 257.7					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required: Vb = 280 kN : qw = 207 N/mm2					
d = 226 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

315	TAPERED	PASS	BS-4.7 (C)	0.048	214
		0.00	3.28	-3.93	0.00

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
--------	-------	---------------	----------------------	--------------	----------------------

□

CALCULATED CAPACITIES FOR MEMB 315 UNIT - kN,m SECTION CLASS 3					
MCZ=	257.7	MCY= 100.2	PC= 2334.1	PT= 2537.8	MB= 257.7
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 280 kN : qw = 207 N/mm2					
d = 226 mm :	t = 6 mm	: a = 0 mm : pyf = 344 N/mm2			
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

316	TAPERED	PASS	BS-4.7 (C)	0.048	202
		0.00	-3.28	-3.93	1.30

CALCULATED CAPACITIES FOR MEMB 316 UNIT - kN,m SECTION CLASS 3					
MCZ=	257.7	MCY= 100.2	PC= 2334.1	PT= 2537.8	MB= 257.7
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 280 kN : qw = 207 N/mm2					
d = 226 mm :	t = 6 mm	: a = 0 mm : pyf = 344 N/mm2			
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

317	TAPERED	PASS	BS-4.7 (C)	0.168	202
		3.33 C	-7.86	-22.31	3.25

CALCULATED CAPACITIES FOR MEMB 317 UNIT - kN,m SECTION CLASS 3					
MCZ=	257.7	MCY= 100.2	PC= 1045.9	PT= 2537.8	MB= 257.7
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 280 kN : qw = 207 N/mm2					
d = 226 mm :	t = 6 mm	: a = 0 mm : pyf = 344 N/mm2			
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

318	TAPERED	PASS	BS-4.7 (C)	0.135	202
		3.52 C	-5.19	-20.92	3.00

CALCULATED CAPACITIES FOR MEMB 318 UNIT - kN,m SECTION CLASS 3					
MCZ=	257.7	MCY= 100.2	PC= 1154.2	PT= 2537.8	MB= 257.7
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 280 kN : qw = 207 N/mm2					
d = 226 mm :	t = 6 mm	: a = 0 mm : pyf = 344 N/mm2			
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

319	TAPERED	PASS	BS-4.7 (C)	0.168	202
		3.33 C	-7.86	-22.31	3.25

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
--------	-------	---------------	----------------------	--------------	----------------------

CALCULATED CAPACITIES FOR MEMB 319 UNIT - kN,m SECTION CLASS 3					
MCZ=	257.7	MCY= 100.2	PC= 1045.9	PT= 2537.8	MB= 257.7
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 280 kN : qw = 207 N/mm2					
d = 226 mm :	t = 6 mm	: a = 0 mm : pyf = 344 N/mm2			
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

320	TAPERED	PASS	BS-4.7 (C)	0.048	202
		0.00	3.28	3.93	0.00

CALCULATED CAPACITIES FOR MEMB 320 UNIT - kN,m SECTION CLASS 3					
MCZ=	257.7	MCY= 100.2	PC= 2334.1	PT= 2537.8	MB= 257.7
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 280 kN : qw = 207 N/mm2					
d = 226 mm :	t = 6 mm	: a = 0 mm : pyf = 344 N/mm2			
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

501 ST UA70X70X6	PASS	BS-4.6 (T)	0.005	0.00	207
	1.30 T	0.00	0.00		3.50

MATERIAL DATA

Grade of steel = S 275
Modulus of elasticity = 205 kN/mm2
Design Strength (py) = 344 N/mm2

SECTION PROPERTIES (units - cm)

Member Length =	349.70				
Gross Area =	8.20	Net Area =	8.20	Eff. Area =	8.20
=====					
Moment of inertia		z-z axis		y-y axis	
Plastic modulus		: 15.391		60.246	
Elastic modulus		: 10.133		21.909	
Effective modulus		: 5.629		12.171	
Shear Area		: 2.520		2.520	

DESIGN DATA (units - kN,m)

Section Class	: SLENDER				
=====					
Tension Capacity		z-z axis		y-y axis	
Shear Capacity		: 282.9		282.9	
		: 52.2		52.2	

BUCKLING CALCULATIONS (units - kN,m)

(axis nomenclature as per design code)

LTB Moment Capacity (kNm) and LTB Length (m):	2.69,	3.497			
LTB Coefficients & Associated Moments (kNm):					
mLT = 1.00 : mx = 0.00 : my = 0.00	: myx =	0.00			
Mlt = 0.00 : Mx = 0.00 : My = 0.00	: My =	0.00			

CRITICAL LOADS FOR EACH CLAUSE CHECK (units- kN,m):

CLAUSe	RATIO	LOAD	FX	VY	VZ	MZ	MY
BS-4.6 (T)	0.005	207	1.3	-	-	-	-
Torsion and deflections have not been considered in the design.							

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

502 ST UA70X70X6	PASS	BS-4.6 (T)	0.001	0.00	207
	0.36 T	0.00	0.00		3.64

MATERIAL DATA

Grade of steel = S 275
Modulus of elasticity = 205 kN/mm2
Design Strength (py) = 344 N/mm2

SECTION PROPERTIES (units - cm)

Member Length =	363.58				
Gross Area =	8.20	Net Area =	8.20	Eff. Area =	8.20
=====					
Moment of inertia		z-z axis		y-y axis	
Plastic modulus		: 15.391		60.246	
Elastic modulus		: 10.133		21.909	
Effective modulus		: 5.629		12.171	
Shear Area		: 2.520		2.520	

DESIGN DATA (units - kN,m)

Section Class	: SLENDER				
Squash Load	: 282.90				
Axial force/Squash load	: 0.001				

Compression Capacity	: 46.3			y-y axis	
Tension Capacity	: 282.9			97.2	
Shear Capacity	: 52.2			52.2	

BUCKLING CALCULATIONS (units - kN,m)

(axis nomenclature as per design code)

		v-v axis		a-a axis		b-b axis
Slenderness	: 172.501			111.179		111.179
Radius of gyration (cm)	: 1.370			2.126		2.126
Effective Length	: 2.363			2.363		2.363

LTB Moment Capacity (kNm) and LTB Length (m):	2.63,	3.636				
LTB Coefficients & Associated Moments (kNm):						
mLT = 1.00 : mx = 0.00 : my = 0.00	: myx =	0.00				
Mlt = 0.00 : Mx = 0.00 : My = 0.00	: My =	0.00				

CRITICAL LOADS FOR EACH CLAUSE CHECK (units- kN,m):

CLAUSe	RATIO	LOAD	FX	VY	VZ	MZ	MY
BS-4.6 (T)	0.001	207	0.4	-	-	-	-
BS-4.7 (C)	0.001	218	0.0	-	-	-	-

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

□	503 ST UA70X70X6	PASS	BS-4.7 (C)	0.001	220
		0.02 C	0.00	0.00	0.00
=====					

MATERIAL DATA

Grade of steel = S 275
Modulus of elasticity = 205 kN/mm2
Design Strength (py) = 344 N/mm2

SECTION PROPERTIES (units - cm)

Member Length = 437.92
Gross Area = 8.20 Net Area = 8.20 Eff. Area = 8.20

	z-z axis	y-y axis
Moment of inertia	: 15.391	60.246
Plastic modulus	: 10.133	21.909
Elastic modulus	: 5.629	12.171
Effective modulus	: 5.629	12.171
Shear Area	: 2.520	2.520

DESIGN DATA (units - kN,m)

Section Class : SLENDER
Squash Load : 282.90
Axial force/Squash load : 0.000

	z-z axis	y-y axis
Compression Capacity	: 33.1	71.9
Tension Capacity	: 282.9	282.9
Shear Capacity	: 52.2	52.2

BUCKLING CALCULATIONS (units - kN,m)

(axis nomenclature as per design code)

	v-v axis	a-a axis	b-b axis
Slenderness	: 207.770	133.911	133.911
Radius of gyration (cm)	: 1.370	2.126	2.126
Effective Length	: 2.846	2.846	2.846

LTB Moment Capacity (kNm) and LTB Length (m): 2.37, 4.379
LTB Coefficients & Associated Moments (kNm):
mLT = 1.00 : mx = 0.00 : my = 0.00 : myx = 0.00
MLt = 0.00 : Mx = 0.00 : My = 0.00 : My = 0.00

CRITICAL LOADS FOR EACH CLAUSE CHECK (units- kN,m):

CLAUSE	RATIO	LOAD	FX	VY	VZ	MZ	MY
Torsion and deflections have not been considered in the design.							

Torsion and deflections have not been considered in the design.

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

504 ST UA70X70X6	PASS	BS-4.7 (C)	0.080	207	
	2.49 C	0.00	0.00	0.00	
=====					

MATERIAL DATA

Grade of steel = S 275
Modulus of elasticity = 205 kN/mm2
Design Strength (py) = 344 N/mm2

SECTION PROPERTIES (units - cm)

Member Length = 451.85
Gross Area = 8.20 Net Area = 8.20 Eff. Area = 8.20

	z-z axis	y-y axis
Moment of inertia	: 15.391	60.246
Plastic modulus	: 10.133	21.909
Elastic modulus	: 5.629	12.171
Effective modulus	: 5.629	12.171
Shear Area	: 2.520	2.520

DESIGN DATA (units - kN,m) BS5950-1/2000
Section Class : SLENDER
Squash Load : 282.90
Axial force/Squash Load : 0.009

	z-z axis	y-y axis
Compression Capacity	: 31.2	68.2
Tension Capacity	: 282.9	282.9
Shear Capacity	: 52.2	52.2

BUCKLING CALCULATIONS (units - kN,m)
(axis nomenclature as per design code)

	v-v axis	a-a axis	b-b axis
Slenderness	: 214.382	138.172	138.172
Radius of gyration (cm)	: 1.370	2.126	2.126
Effective Length	: 2.937	2.937	2.937

LTB Moment Capacity (kNm) and LTB Length (m): 2.33, 4.519
LTB Coefficients & Associated Moments (kNm):
mLT = 1.00 : mx = 0.00 : my = 0.00 : myx = 0.00
MLt = 0.00 : Mx = 0.00 : My = 0.00 : My = 0.00

CRITICAL LOADS FOR EACH CLAUSE CHECK (units- kN,m):

CLAUSE	RATIO	LOAD	FX	VY	VZ	MZ	MY
BS-4.6 (T)	0.001	212	0.4	-	-	-	-
BS-4.7 (C)	0.080	207	2.5	-	-	-	-

Torsion and deflections have not been considered in the design.

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

505 ST UA70X70X6	PASS	BS-4.7 (C)	0.083	207	
	2.40 C	0.00	0.00	4.71	
=====					

MATERIAL DATA

Grade of steel = S 275
Modulus of elasticity = 205 kN/mm2
Design Strength (py) = 344 N/mm2

SECTION PROPERTIES (units - cm)

Member Length = 471.31
Gross Area = 8.20 Net Area = 8.20 Eff. Area = 8.20

	z-z axis	y-y axis
Moment of inertia	: 15.391	60.246
Plastic modulus	: 10.133	21.909
Elastic modulus	: 5.629	12.171
Effective modulus	: 5.629	12.171
Shear Area	: 2.520	2.520

DESIGN DATA (units - kN,m) BS5950-1/2000
Section Class : SLENDER
Squash Load : 282.90
Axial force/Squash Load : 0.008

	z-z axis	y-y axis
Compression Capacity	: 28.9	63.5
Tension Capacity	: 282.9	282.9
Shear Capacity	: 52.2	52.2

BUCKLING CALCULATIONS (units - kN,m)

(axis nomenclature as per design code)

	v-v axis	a-a axis	b-b axis
Slenderness	: 223.614	144.122	144.122
Radius of gyration (cm)	: 1.370	2.126	2.126
Effective Length	: 3.064	3.064	3.064

LTB Moment Capacity (kNm) and LTB Length (m): 2.27, 4.713
LTB Coefficients & Associated Moments (kNm):
mLT = 1.00 : mx = 0.00 : my = 0.00 : myx = 0.00
MLt = 0.00 : Mx = 0.00 : My = 0.00 : My = 0.00

CRITICAL LOADS FOR EACH CLAUSE CHECK (units- kN,m):

CLAUSE	RATIO	LOAD	FX	VY	VZ	MZ	MY
BS-4.6 (T)	0.001	212	0.4	-	-	-	-
BS-4.7 (C)	0.083	207	2.4	-	-	-	-

Torsion and deflections have not been considered in the design.

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

506 ST UA70X70X6	PASS	BS-4.7 (C)	0.001	0.00	207
	0.02 C	0.00	0.00	0.00	4.58

MATERIAL DATA

Grade of steel = S 275
Modulus of elasticity = 205 kN/mm²
Design Strength (py) = 344 N/mm²

SECTION PROPERTIES (units - cm)

Member Length = 457.97
Gross Area = 8.20 Net Area = 8.20 Eff. Area = 8.20

	z-z axis	y-y axis
Moment of inertia	: 15.391	60.246
Plastic modulus	: 10.133	21.909
Elastic modulus	: 5.629	12.171
Effective modulus	: 5.629	12.171
Shear Area	: 2.520	2.520

DESIGN DATA (units - kN,m)

BS5950-1/2000
Section Class : SLENDER
Squash Load : 282.90
Axial force/Squash load : 0.000

	z-z axis	y-y axis
Compression Capacity	: 30.4	66.7
Tension Capacity	: 282.9	282.9
Shear Capacity	: 52.2	52.2

BUCKLING CALCULATIONS (units - kN,m)

(axis nomenclature as per design code)

	v-v axis	a-a axis	b-b axis
Slenderness	: 217.283	140.042	140.042
Radius of gyration (cm)	: 1.370	2.126	2.126
Effective Length	: 2.977	2.977	2.977

LTB Moment Capacity (kNm) and LTB Length (m): 2.31, 4.580
LTB Coefficients & Associated Moments (kNm):
mLT = 1.00 : mx = 0.00 : my = 0.00 : myx = 0.00
Mlt = 0.00 : Mx = 0.00 : My = 0.00 : My = 0.00

CRITICAL LOADS FOR EACH CLAUSE CHECK (units- kN,m):

CLAUSe RAtIo LoAD FX VY VZ MZ MY
BS-4.6 (T) 0.001 207 0.4 - - -
Torsion and deflections have not been considered in the design.

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

507 ST UA70X70X6	PASS	BS-4.6 (T)	0.001	0.00	207
	0.42 T	0.00	0.00	0.00	0.00

MATERIAL DATA

Grade of steel = S 275
Modulus of elasticity = 205 kN/mm²
Design Strength (py) = 344 N/mm²

SECTION PROPERTIES (units - cm)

Member Length = 329.16
Gross Area = 8.20 Net Area = 8.20 Eff. Area = 8.20

	z-z axis	y-y axis
Moment of inertia	: 15.391	60.246
Plastic modulus	: 10.133	21.909
Elastic modulus	: 5.629	12.171
Effective modulus	: 5.629	12.171
Shear Area	: 2.520	2.520

DESIGN DATA (units - kN,m)

BS5950-1/2000
Section Class : SLENDER
Squash Load : 282.90
Axial force/Squash load : 0.001

	z-z axis	y-y axis
Compression Capacity	: 55.2	112.8
Tension Capacity	: 282.9	282.9
Shear Capacity	: 52.2	52.2

BUCKLING CALCULATIONS (units - kN,m)

(axis nomenclature as per design code)

	v-v axis	a-a axis	b-b axis
Slenderness	: 156.172	100.655	100.655
Radius of gyration (cm)	: 1.370	2.126	2.126
Effective Length	: 2.140	2.140	2.140

LTB Moment Capacity (kNm) and LTB Length (m): 2.77, 3.292
LTB Coefficients & Associated Moments (kNm):
mLT = 1.00 : mx = 0.00 : my = 0.00 : myx = 0.00
Mlt = 0.00 : Mx = 0.00 : My = 0.00 : My = 0.00

CRITICAL LOADS FOR EACH CLAUSE CHECK (units- kN,m):

CLAUSe RAtIo LoAD FX VY VZ MZ MY
BS-4.6 (T) 0.001 207 0.4 - - -
Torsion and deflections have not been considered in the design.

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

508 ST UA70X70X6	PASS	BS-4.6 (T)	0.004	0.00	207
	1.26 T	0.00	0.00	0.00	0.00

MATERIAL DATA

Grade of steel = S 275
Modulus of elasticity = 205 kN/mm2
Design Strength (py) = 344 N/mm2

SECTION PROPERTIES (units - cm)

Member Length = 313.76
Gross Area = 8.20 Net Area = 8.20 Eff. Area = 8.20

	z-z axis	y-y axis
Moment of inertia	: 15.391	60.246
Plastic modulus	: 10.133	21.909
Elastic modulus	: 5.629	12.171
Effective modulus	: 5.629	12.171
Shear Area	: 2.520	2.520

DESIGN DATA (units - kN,m)

BS5950-1/2000

Section Class

: SLENDER

	z-z axis	y-y axis
Tension Capacity	: 282.9	282.9
Shear Capacity	: 52.2	52.2

BUCKLING CALCULATIONS (units - kN,m)

(axis nomenclature as per design code)

LTB Moment Capacity (kNm) and LTB Length (m):	2.83,	3.138
LTB Coefficients & Associated Moments (kNm):		
mLT = 1.00 : mx = 0.00 : my = 0.00 : myx = 0.00		
Mlt = 0.00 : Mx = 0.00 : My = 0.00 : My = 0.00		

CRITICAL LOADS FOR EACH CLAUSE CHECK (units- kN,m):

CLAUSe	RATIO	LOAD	FX	VY	VZ	MZ	MY
BS-4.6 (T)	0.004	207	1.3	-	-	-	-
Torsion and deflections have not been considered in the design.							

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

509 ST UA70X70X6	PASS	BS-4.6 (T)	0.001	0.00	207
	0.36 T	0.00	0.00	0.00	3.64

MATERIAL DATA

Grade of steel = S 275
Modulus of elasticity = 205 kN/mm2
Design Strength (py) = 344 N/mm2

SECTION PROPERTIES (units - cm)

Member Length = 363.58
Gross Area = 8.20 Net Area = 8.20 Eff. Area = 8.20

	z-z axis	y-y axis
Moment of inertia	: 15.391	60.246
Plastic modulus	: 10.133	21.909
Elastic modulus	: 5.629	12.171
Effective modulus	: 5.629	12.171
Shear Area	: 2.520	2.520

DESIGN DATA (units - kN,m)

BS5950-1/2000

Section Class

: SLENDER

Squash Load

: 282.90

Axial force/Squash load : 0.001

	z-z axis	y-y axis
Compression Capacity	: 46.3	97.2
Tension Capacity	: 282.9	282.9
Shear Capacity	: 52.2	52.2

BUCKLING CALCULATIONS (units - kN,m)

(axis nomenclature as per design code)

	v-v axis	a-a axis	b-b axis
Slenderness	: 172.501	111.179	111.179
Radius of gyration (cm)	: 1.370	2.126	2.126
Effective Length	: 2.363	2.363	2.363

LTB Moment Capacity (kNm) and LTB Length (m):	2.63,	3.636
LTB Coefficients & Associated Moments (kNm):		
mLT = 1.00 : mx = 0.00 : my = 0.00 : myx = 0.00		
Mlt = 0.00 : Mx = 0.00 : My = 0.00 : My = 0.00		

CRITICAL LOADS FOR EACH CLAUSE CHECK (units- kN,m):

CLAUSe	RATIO	LOAD	FX	VY	VZ	MZ	MY
BS-4.6 (T)	0.001	207	0.4	-	-	-	-
BS-4.7 (C)	0.001	218	0.1	-	-	-	-

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

□

510 ST UA70X70X6	PASS	BS-4.6	(T)	0.005	207
	1.30 T	0.00		0.00	3.50

MATERIAL DATA

Grade of steel = S 275
Modulus of elasticity = 205 kN/mm2
Design Strength (py) = 344 N/mm2

SECTION PROPERTIES (units - cm)

Member Length = 349.70
Gross Area = 8.20 Net Area = 8.20 Eff. Area = 8.20

	z-z axis	y-y axis
Moment of inertia	: 15.391	60.246
Plastic modulus	: 10.133	21.909
Elastic modulus	: 5.629	12.171
Effective modulus	: 5.629	12.171
Shear Area	: 2.520	2.520

DESIGN DATA (units - kN,m) BS5950-1/2000
Section Class : SLENDER

	z-z axis	y-y axis
Tension Capacity	: 282.9	282.9
Shear Capacity	: 52.2	52.2

BUCKLING CALCULATIONS (units - kN,m)
(axis nomenclature as per design code)

LTB Moment Capacity (kNm) and LTB Length (m): 2.69, 3.497
LTB Coefficients & Associated Moments (kNm):
mLT = 1.00 : mx = 0.00 : my = 0.00 : myx = 0.00
MLt = 0.00 : Mx = 0.00 : My = 0.00 : My = 0.00

CRITICAL LOADS FOR EACH CLAUSE CHECK (units- kN,m) :

CLAUSE	RATIO	LOAD	FX	VY	VZ	MZ	MY
BS-4.6	(T)	0.005	207	1.3	-	-	-

Torsion and deflections have not been considered in the design.

Torsion and deflections have not been considered in the design.

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

511 ST UA70X70X6	PASS	BS-4.7 (C)	0.080	207
2.49 C	0.00	0.00	0.00	0.00
=====				

MATERIAL DATA

Grade of steel = S 275
Modulus of elasticity = 205 kN/mm2
Design Strength (py) = 344 N/mm2

SECTION PROPERTIES (units - cm)

Member Length = 451.85
Gross Area = 8.20 Net Area = 8.20 Eff. Area = 8.20

	z-z axis	y-y axis
Moment of inertia	: 15.391	60.246
Plastic modulus	: 10.133	21.909
Elastic modulus	: 5.629	12.171
Effective modulus	: 5.629	12.171
Shear Area	: 2.520	2.520

DESIGN DATA (units - kN,m) BS5950-1/2000
Section Class : SLENDER
Squash Load : 282.90
Axial force/Squash Load : 0.009

	z-z axis	y-y axis
Compression Capacity	: 31.2	68.2
Tension Capacity	: 282.9	282.9
Shear Capacity	: 52.2	52.2

BUCKLING CALCULATIONS (units - kN,m)
(axis nomenclature as per design code)

	v-v axis	a-a axis	b-b axis
Slenderness	: 214.382	138.172	138.172
Radius of gyration (cm)	: 1.370	2.126	2.126
Effective Length	: 2.937	2.937	2.937

LTB Moment Capacity (kNm) and LTB Length (m): 2.33, 4.519
LTB Coefficients & Associated Moments (kNm):
mLT = 1.00 : mx = 0.00 : my = 0.00 : myx = 0.00
MLt = 0.00 : Mx = 0.00 : My = 0.00 : My = 0.00

CRITICAL LOADS FOR EACH CLAUSE CHECK (units- kN,m):

CLAUSE	RATIO	LOAD	FX	VY	VZ	MZ	MY
BS-4.6 (T)	0.001	212	0.4	-	-	-	-
BS-4.7 (C)	0.080	207	2.5	-	-	-	-

Torsion and deflections have not been considered in the design.

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
--------	-------	---------------	----------------------	--------------	----------------------

512 ST UA70X70X6	PASS	BS-4.7 (C)	0.001	222	
	0.02 C	0.00	0.00	0.00	

MATERIAL DATA

Grade of steel = S 275
Modulus of elasticity = 205 kN/mm²
Design Strength (py) = 344 N/mm²

SECTION PROPERTIES (units - cm)

Member Length = 437.92
Gross Area = 8.20 Net Area = 8.20 Eff. Area = 8.20

Moment of inertia	: 15.391	z-z axis	y-y axis
Plastic modulus	: 10.133		60.246
Elastic modulus	: 5.629		21.909
Effective modulus	: 5.629		12.171
Shear Area	: 2.520		12.171

DESIGN DATA (units - kN,m) BS5950-1/2000
Section Class : SLENDER
Squash Load : 282.90
Axial force/Squash load : 0.000

Compression Capacity	: 33.1	z-z axis	y-y axis
Tension Capacity	: 282.9		71.9
Shear Capacity	: 52.2		282.9

BUCKLING CALCULATIONS (units - kN,m)

(axis nomenclature as per design code)

		v-v axis	a-a axis	b-b axis
Slenderness	: 207.770		133.911	133.911
Radius of gyration (cm)	: 1.370		2.126	2.126
Effective Length	: 2.846		2.846	2.846

LTB Moment Capacity (kNm) and LTB Length (m): 2.37, 4.379
LTB Coefficients & Associated Moments (kNm):
mLT = 1.00 : mx = 0.00 : my = 0.00 : myx = 0.00
Mlt = 0.00 : Mx = 0.00 : My = 0.00 : My = 0.00

CRITICAL LOADS FOR EACH CLAUSE CHECK (units- kN,m):

CLAUSe	RATIO	LOAD	FX	VY	VZ	MZ	MY
--------	-------	------	----	----	----	----	----

Torsion and deflections have not been considered in the design.

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
--------	-------	---------------	----------------------	--------------	----------------------

513 ST UA70X70X6	PASS	BS-4.7 (C)	0.001	207	
	0.02 C	0.00	0.00	0.00	4.58

MATERIAL DATA

Grade of steel = S 275
Modulus of elasticity = 205 kN/mm²
Design Strength (py) = 344 N/mm²

SECTION PROPERTIES (units - cm)

Member Length = 457.97
Gross Area = 8.20 Net Area = 8.20 Eff. Area = 8.20

Moment of inertia	: 15.391	z-z axis	y-y axis
Plastic modulus	: 10.133		60.246
Elastic modulus	: 5.629		21.909
Effective modulus	: 5.629		12.171
Shear Area	: 2.520		12.171

DESIGN DATA (units - kN,m) BS5950-1/2000
Section Class : SLENDER
Squash Load : 282.90
Axial force/Squash load : 0.000

Compression Capacity	: 30.4	z-z axis	y-y axis
Tension Capacity	: 282.9		66.7
Shear Capacity	: 52.2		282.9

BUCKLING CALCULATIONS (units - kN,m)

(axis nomenclature as per design code)

		v-v axis	a-a axis	b-b axis
Slenderness	: 217.283		140.042	140.042
Radius of gyration (cm)	: 1.370		2.126	2.126
Effective Length	: 2.977		2.977	2.977

LTB Moment Capacity (kNm) and LTB Length (m): 2.31, 4.580
LTB Coefficients & Associated Moments (kNm):
mLT = 1.00 : mx = 0.00 : my = 0.00 : myx = 0.00
Mlt = 0.00 : Mx = 0.00 : My = 0.00 : My = 0.00

CRITICAL LOADS FOR EACH CLAUSE CHECK (units- kN,m):

CLAUSe	RATIO	LOAD	FX	VY	VZ	MZ	MY
--------	-------	------	----	----	----	----	----

Torsion and deflections have not been considered in the design.

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

□	514 ST UA70X70X6	PASS	BS-4.7 (C)	0.083	207
		2.39 C	0.00	0.00	4.71

MATERIAL DATA

Grade of steel = S 275
Modulus of elasticity = 205 kN/mm2
Design Strength (py) = 344 N/mm2

SECTION PROPERTIES (units - cm)

Member Length = 471.31
Gross Area = 8.20 Net Area = 8.20 Eff. Area = 8.20

	z-z axis	y-y axis
Moment of inertia	: 15.391	60.246
Plastic modulus	: 10.133	21.909
Elastic modulus	: 5.629	12.171
Effective modulus	: 5.629	12.171
Shear Area	: 2.520	2.520

DESIGN DATA (units - kN,m) BS5950-1/2000
Section Class : SLENDER
Squash Load : 282.90
Axial force/Squash Load : 0.008

	z-z axis	y-y axis
Compression Capacity	: 28.9	63.5
Tension Capacity	: 282.9	282.9
Shear Capacity	: 52.2	52.2

BUCKLING CALCULATIONS (units - kN,m)

(axis nomenclature as per design code)

	v-v axis	a-a axis	b-b axis
Slenderness	: 223.614	144.122	144.122
Radius of gyration (cm)	: 1.370	2.126	2.126
Effective Length	: 3.064	3.064	3.064

LTB Moment Capacity (kNm) and LTB Length (m): 2.27, 4.713
LTB Coefficients & Associated Moments (kNm):
mLT = 1.00 : mx = 0.00 : my = 0.00 : myx = 0.00
MLt = 0.00 : Mx = 0.00 : My = 0.00 : My = 0.00

CRITICAL LOADS FOR EACH CLAUSE CHECK (units- kN,m):

CLAUSE	RATIO	LOAD	FX	VY	VZ	MZ	MY
BS-4.6 (T)	0.001	212	0.4	-	-	-	-
BS-4.7 (C)	0.083	207	2.4	-	-	-	-

Torsion and deflections have not been considered in the design.

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
--------	-------	---------------	----------------------	--------------	----------------------

□

515 ST UA70X70X6	PASS	BS-4.6 (T)	0.001	0.00	207
	0.42 T	0.00	0.00	0.00	0.00

MATERIAL DATA

Grade of steel = S 275
Modulus of elasticity = 205 kN/mm²
Design Strength (py) = 344 N/mm²

SECTION PROPERTIES (units - cm)

Member Length = 329.16
Gross Area = 8.20 Net Area = 8.20 Eff. Area = 8.20

Moment of inertia	: 15.391	Y-Y axis	60.246
Plastic modulus	: 10.133		21.909
Elastic modulus	: 5.629		12.171
Effective modulus	: 5.629		12.171
Shear Area	: 2.520		2.520

DESIGN DATA (units - kN,m)

Section Class : SLENDER
Squash Load : 282.90
Axial force/Squash load : 0.001

Compression Capacity	: 55.2	Y-Y axis	112.8
Tension Capacity	: 282.9		282.9
Shear Capacity	: 52.2		52.2

BUCKLING CALCULATIONS (units - kN,m)

(axis nomenclature as per design code)

	v-v axis	a-a axis	b-b axis
Slenderness	: 156.172	100.655	100.655
Radius of gyration (cm)	: 1.370	2.126	2.126
Effective Length	: 2.140	2.140	2.140

LTB Moment Capacity (kNm) and LTB Length (m): 2.77, 3.292

LTB Coefficients & Associated Moments (kNm):

mLT = 1.00 : mx = 0.00 : my = 0.00 : myx = 0.00
Mlt = 0.00 : Mx = 0.00 : My = 0.00 : My = 0.00

CRITICAL LOADS FOR EACH CLAUSE CHECK (units- kN,m):

CLAUSe	RATIO	LOAD	FX	VY	VZ	MZ	MY
BS-4.6 (T)	0.001	207	0.4	-	-	-	-

Torsion and deflections have not been considered in the design.

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
--------	-------	---------------	----------------------	--------------	----------------------

□

516 ST UA70X70X6	PASS	BS-4.6 (T)	0.004	0.00	207
	1.26 T	0.00	0.00	0.00	3.14

MATERIAL DATA

Grade of steel = S 275
Modulus of elasticity = 205 kN/mm²
Design Strength (py) = 344 N/mm²

SECTION PROPERTIES (units - cm)

Member Length = 313.76
Gross Area = 8.20 Net Area = 8.20 Eff. Area = 8.20

Moment of inertia	: 15.391	z-z axis	Y-Y axis
Plastic modulus	: 10.133		60.246
Elastic modulus	: 5.629		21.909
Effective modulus	: 5.629		12.171
Shear Area	: 2.520		12.171
			2.520

DESIGN DATA (units - kN,m)

BS5950-1/2000

Section Class : SLENDER

Tension Capacity	: 282.9	Y-Y axis	282.9
Shear Capacity	: 52.2		52.2

BUCKLING CALCULATIONS (units - kN,m)

(axis nomenclature as per design code)

LTB Moment Capacity (kNm) and LTB Length (m): 2.83, 3.138

LTB Coefficients & Associated Moments (kNm):

mLT = 1.00 : mx = 0.00 : my = 0.00 : myx = 0.00
Mlt = 0.00 : Mx = 0.00 : My = 0.00 : My = 0.00

CRITICAL LOADS FOR EACH CLAUSE CHECK (units- kN,m):

CLAUSe	RATIO	LOAD	FX	VY	VZ	MZ	MY
BS-4.6 (T)	0.004	207	1.3	-	-	-	-

Torsion and deflections have not been considered in the design.

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

522 ST UA70X70X6	PASS	BS-4.7 (C)	0.313	221
9.86 C	0.00	0.00	0.00	0.00
=====				

MATERIAL DATA

Grade of steel = S 275
Modulus of elasticity = 205 kN/mm2
Design Strength (py) = 344 N/mm2

SECTION PROPERTIES (units - cm)

Member Length = 449.65
Gross Area = 8.20 Net Area = 8.20 Eff. Area = 8.20

	z-z axis	y-y axis
Moment of inertia	: 15.391	60.246
Plastic modulus	: 10.133	21.909
Elastic modulus	: 5.629	12.171
Effective modulus	: 5.629	12.171
Shear Area	: 2.520	2.520

DESIGN DATA (units - kN,m)

BS5950-1/2000
Section Class : SLENDER
Squash Load : 282.90
Axial force/Squash Load : 0.035

	z-z axis	y-y axis
Compression Capacity	: 31.5	68.8
Tension Capacity	: 282.9	282.9
Shear Capacity	: 52.2	52.2

BUCKLING CALCULATIONS (units - kN,m)

(axis nomenclature as per design code)

	v-v axis	a-a axis	b-b axis
Slenderness	: 213.340	137.500	137.500
Radius of gyration (cm)	: 1.370	2.126	2.126
Effective Length	: 2.923	2.923	2.923

LTB Moment Capacity (kNm) and LTB Length (m): 2.33, 4.497

LTB Coefficients & Associated Moments (kNm):

mLT = 1.00 : mx = 0.00 : my = 0.00 : myx = 0.00
MLt = 0.00 : Mx = 0.00 : My = 0.00 : My = 0.00

CRITICAL LOADS FOR EACH CLAUSE CHECK (units- kN,m):

CLAUSE	RATIO	LOAD	FX	VY	VZ	MZ	MY
BS-4.6 (T)	0.009	228	2.7	-	-	-	-
BS-4.7 (C)	0.313	221	9.9	-	-	-	-

Torsion and deflections have not been considered in the design.

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

523 ST UA70X70X6	PASS	BS-4.7 (C)	0.224	201
9.73 C	0.00	0.00	0.00	0.00
=====				

MATERIAL DATA

Grade of steel = S 275
Modulus of elasticity = 205 kN/mm2
Design Strength (py) = 344 N/mm2

SECTION PROPERTIES (units - cm)

Member Length = 376.60
Gross Area = 8.20 Net Area = 8.20 Eff. Area = 8.20

	z-z axis	y-y axis
Moment of inertia	: 15.391	60.246
Plastic modulus	: 10.133	21.909
Elastic modulus	: 5.629	12.171
Effective modulus	: 5.629	12.171
Shear Area	: 2.520	2.520

DESIGN DATA (units - kN,m)

BS5950-1/2000
Section Class : SLENDER
Squash Load : 282.90
Axial force/Squash load : 0.034

	z-z axis	y-y axis
Compression Capacity	: 43.5	92.0
Tension Capacity	: 282.9	282.9
Shear Capacity	: 52.2	52.2

BUCKLING CALCULATIONS (units - kN,m)

(axis nomenclature as per design code)

	v-v axis	a-a axis	b-b axis
Slenderness	: 178.677	115.160	115.160
Radius of gyration (cm)	: 1.370	2.126	2.126
Effective Length	: 2.448	2.448	2.448

LTB Moment Capacity (kNm) and LTB Length (m): 2.58, 3.766

LTB Coefficients & Associated Moments (kNm):

mLT = 1.00 : mx = 0.00 : my = 0.00 : myx = 0.00
MLt = 0.00 : Mx = 0.00 : My = 0.00 : My = 0.00

CRITICAL LOADS FOR EACH CLAUSE CHECK (units- kN,m):

CLAUSE	RATIO	LOAD	FX	VY	VZ	MZ	MY
BS-4.6 (T)	0.009	218	2.6	-	-	-	-
BS-4.7 (C)	0.224	201	9.7	-	-	-	-

Torsion and deflections have not been considered in the design.

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

□	524 ST UA70X70X6	PASS	BS-4.7 (C)	0.274	219
		9.69 C	0.00	0.00	0.00
=====					

MATERIAL DATA

Grade of steel = S 275
Modulus of elasticity = 205 kN/mm2
Design Strength (py) = 344 N/mm2

SECTION PROPERTIES (units - cm)

Member Length = 422.12
Gross Area = 8.20 Net Area = 8.20 Eff. Area = 8.20

	z-z axis	y-y axis
Moment of inertia	: 15.391	60.246
Plastic modulus	: 10.133	21.909
Elastic modulus	: 5.629	12.171
Effective modulus	: 5.629	12.171
Shear Area	: 2.520	2.520

DESIGN DATA (units - kN,m) BS5950-1/2000
Section Class : SLENDER
Squash Load : 282.90
Axial force/Squash Load : 0.034

	z-z axis	y-y axis
Compression Capacity	: 35.4	76.5
Tension Capacity	: 282.9	282.9
Shear Capacity	: 52.2	52.2

BUCKLING CALCULATIONS (units - kN,m)
(axis nomenclature as per design code)

	v-v axis	a-a axis	b-b axis
Slenderness	: 200.278	129.082	129.082
Radius of gyration (cm)	: 1.370	2.126	2.126
Effective Length	: 2.744	2.744	2.744

LTB Moment Capacity (kNm) and LTB Length (m): 2.42, 4.221
LTB Coefficients & Associated Moments (kNm):
mLT = 1.00 : mx = 0.00 : my = 0.00 : myx = 0.00
MLt = 0.00 : Mx = 0.00 : My = 0.00 : My = 0.00

CRITICAL LOADS FOR EACH CLAUSE CHECK (units- kN,m):

CLAUSE	RATIO	LOAD	FX	VY	VZ	MZ	MY
BS-4.6 (T)	0.009	218	2.5	-	-	-	-
BS-4.7 (C)	0.274	219	9.7	-	-	-	-

Torsion and deflections have not been considered in the design.

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

□	525 ST UA70X70X6	PASS	BS-4.7 (C)	0.251	219
		9.48 C	0.00	0.00	0.00
=====					

MATERIAL DATA

Grade of steel = S 275
Modulus of elasticity = 205 kN/mm2
Design Strength (py) = 344 N/mm2

SECTION PROPERTIES (units - cm)

Member Length = 407.22
Gross Area = 8.20 Net Area = 8.20 Eff. Area = 8.20

	z-z axis	y-y axis
Moment of inertia	: 15.391	60.246
Plastic modulus	: 10.133	21.909
Elastic modulus	: 5.629	12.171
Effective modulus	: 5.629	12.171
Shear Area	: 2.520	2.520

DESIGN DATA (units - kN,m) BS5950-1/2000
Section Class : SLENDER
Squash Load : 282.90
Axial force/Squash Load : 0.034

	z-z axis	y-y axis
Compression Capacity	: 37.7	81.1
Tension Capacity	: 282.9	282.9
Shear Capacity	: 52.2	52.2

BUCKLING CALCULATIONS (units - kN,m)
(axis nomenclature as per design code)

	v-v axis	a-a axis	b-b axis
Slenderness	: 193.205	124.523	124.523
Radius of gyration (cm)	: 1.370	2.126	2.126
Effective Length	: 2.647	2.647	2.647

LTB Moment Capacity (kNm) and LTB Length (m): 2.47, 4.072
LTB Coefficients & Associated Moments (kNm):
mLT = 1.00 : mx = 0.00 : my = 0.00 : myx = 0.00
MLt = 0.00 : Mx = 0.00 : My = 0.00 : My = 0.00

CRITICAL LOADS FOR EACH CLAUSE CHECK (units- kN,m):

CLAUSE	RATIO	LOAD	FX	VY	VZ	MZ	MY
BS-4.6 (T)	0.009	218	2.5	-	-	-	-
BS-4.7 (C)	0.251	219	9.5	-	-	-	-

Torsion and deflections have not been considered in the design.

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

530 ST UA70X70X6	PASS	BS-4.7 (C)	0.137	207	
	4.51 C	0.00	0.00	0.00	
=====					

MATERIAL DATA

Grade of steel = S 275
Modulus of elasticity = 205 kN/mm2
Design Strength (py) = 344 N/mm2

SECTION PROPERTIES (units - cm)

Member Length = 437.92
Gross Area = 8.20 Net Area = 8.20 Eff. Area = 8.20

	z-z axis	y-y axis
Moment of inertia	: 15.391	60.246
Plastic modulus	: 10.133	21.909
Elastic modulus	: 5.629	12.171
Effective modulus	: 5.629	12.171
Shear Area	: 2.520	2.520

DESIGN DATA (units - kN,m) BS5950-1/2000
Section Class : SLENDER
Squash Load : 282.90
Axial force/Squash Load : 0.016

	z-z axis	y-y axis
Compression Capacity	: 33.1	71.9
Tension Capacity	: 282.9	282.9
Shear Capacity	: 52.2	52.2

BUCKLING CALCULATIONS (units - kN,m)
(axis nomenclature as per design code)

	v-v axis	a-a axis	b-b axis
Slenderness	: 207.770	133.911	133.911
Radius of gyration (cm)	: 1.370	2.126	2.126
Effective Length	: 2.846	2.846	2.846

LTB Moment Capacity (kNm) and LTB Length (m): 2.37, 4.379
LTB Coefficients & Associated Moments (kNm):
mLT = 1.00 : mx = 0.00 : my = 0.00 : myx = 0.00
MLt = 0.00 : Mx = 0.00 : My = 0.00 : My = 0.00

CRITICAL LOADS FOR EACH CLAUSE CHECK (units- kN,m):

CLAUSE	RATIO	LOAD	FX	VY	VZ	MZ	MY
BS-4.6 (T)	0.004	212	1.1	-	-	-	-
BS-4.7 (C)	0.137	207	4.5	-	-	-	-

Torsion and deflections have not been considered in the design.

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

531 ST UA70X70X6	PASS	BS-4.7 (C)	0.144	207	
	4.37 C	0.00	0.00	4.58	
=====					

MATERIAL DATA

Grade of steel = S 275
Modulus of elasticity = 205 kN/mm2
Design Strength (py) = 344 N/mm2

SECTION PROPERTIES (units - cm)

Member Length = 457.97
Gross Area = 8.20 Net Area = 8.20 Eff. Area = 8.20

	z-z axis	y-y axis
Moment of inertia	: 15.391	60.246
Plastic modulus	: 10.133	21.909
Elastic modulus	: 5.629	12.171
Effective modulus	: 5.629	12.171
Shear Area	: 2.520	2.520

DESIGN DATA (units - kN,m) BS5950-1/2000
Section Class : SLENDER
Squash Load : 282.90
Axial force/Squash Load : 0.015

	z-z axis	y-y axis
Compression Capacity	: 30.4	66.7
Tension Capacity	: 282.9	282.9
Shear Capacity	: 52.2	52.2

BUCKLING CALCULATIONS (units - kN,m)
(axis nomenclature as per design code)

	v-v axis	a-a axis	b-b axis
Slenderness	: 217.283	140.042	140.042
Radius of gyration (cm)	: 1.370	2.126	2.126
Effective Length	: 2.977	2.977	2.977

LTB Moment Capacity (kNm) and LTB Length (m): 2.31, 4.580
LTB Coefficients & Associated Moments (kNm):
mLT = 1.00 : mx = 0.00 : my = 0.00 : myx = 0.00
MLt = 0.00 : Mx = 0.00 : My = 0.00 : My = 0.00

CRITICAL LOADS FOR EACH CLAUSE CHECK (units- kN,m):

CLAUSE	RATIO	LOAD	FX	VY	VZ	MZ	MY
BS-4.6 (T)	0.004	212	1.1	-	-	-	-
BS-4.7 (C)	0.144	207	4.4	-	-	-	-

Torsion and deflections have not been considered in the design.

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

532 ST UA70X70X6	PASS	BS-4.7 (C)	0.136	207	
	4.48 C	0.00	0.00	0.00	
=====					

MATERIAL DATA

Grade of steel = S 275
Modulus of elasticity = 205 kN/mm2
Design Strength (py) = 344 N/mm2

SECTION PROPERTIES (units - cm)

Member Length = 437.92
Gross Area = 8.20 Net Area = 8.20 Eff. Area = 8.20

	z-z axis	y-y axis
Moment of inertia	: 15.391	60.246
Plastic modulus	: 10.133	21.909
Elastic modulus	: 5.629	12.171
Effective modulus	: 5.629	12.171
Shear Area	: 2.520	2.520

DESIGN DATA (units - kN,m) BS5950-1/2000
Section Class : SLENDER
Squash Load : 282.90
Axial force/Squash Load : 0.016

	z-z axis	y-y axis
Compression Capacity	: 33.1	71.9
Tension Capacity	: 282.9	282.9
Shear Capacity	: 52.2	52.2

BUCKLING CALCULATIONS (units - kN,m)
(axis nomenclature as per design code)

	v-v axis	a-a axis	b-b axis
Slenderness	: 207.770	133.911	133.911
Radius of gyration (cm)	: 1.370	2.126	2.126
Effective Length	: 2.846	2.846	2.846

LTB Moment Capacity (kNm) and LTB Length (m): 2.37, 4.379
LTB Coefficients & Associated Moments (kNm):
mLT = 1.00 : mx = 0.00 : my = 0.00 : myx = 0.00
MLt = 0.00 : Mx = 0.00 : My = 0.00 : My = 0.00

CRITICAL LOADS FOR EACH CLAUSE CHECK (units- kN,m):

CLAUSE	RATIO	LOAD	FX	VY	VZ	MZ	MY
BS-4.6 (T)	0.004	212	1.1	-	-	-	-
BS-4.7 (C)	0.136	207	4.5	-	-	-	-

Torsion and deflections have not been considered in the design.

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

533 ST UA70X70X6	PASS	BS-4.7 (C)	0.142	207	
	4.32 C	0.00	0.00	4.58	
=====					

MATERIAL DATA

Grade of steel = S 275
Modulus of elasticity = 205 kN/mm2
Design Strength (py) = 344 N/mm2

SECTION PROPERTIES (units - cm)

Member Length = 457.97
Gross Area = 8.20 Net Area = 8.20 Eff. Area = 8.20

	z-z axis	y-y axis
Moment of inertia	: 15.391	60.246
Plastic modulus	: 10.133	21.909
Elastic modulus	: 5.629	12.171
Effective modulus	: 5.629	12.171
Shear Area	: 2.520	2.520

DESIGN DATA (units - kN,m) BS5950-1/2000
Section Class : SLENDER
Squash Load : 282.90
Axial force/Squash Load : 0.015

	z-z axis	y-y axis
Compression Capacity	: 30.4	66.7
Tension Capacity	: 282.9	282.9
Shear Capacity	: 52.2	52.2

BUCKLING CALCULATIONS (units - kN,m)
(axis nomenclature as per design code)

	v-v axis	a-a axis	b-b axis
Slenderness	: 217.283	140.042	140.042
Radius of gyration (cm)	: 1.370	2.126	2.126
Effective Length	: 2.977	2.977	2.977

LTB Moment Capacity (kNm) and LTB Length (m): 2.31, 4.580
LTB Coefficients & Associated Moments (kNm):
mLT = 1.00 : mx = 0.00 : my = 0.00 : myx = 0.00
MLt = 0.00 : Mx = 0.00 : My = 0.00 : My = 0.00

CRITICAL LOADS FOR EACH CLAUSE CHECK (units- kN,m):

CLAUSE	RATIO	LOAD	FX	VY	VZ	MZ	MY
BS-4.6 (T)	0.004	218	1.1	-	-	-	-
BS-4.7 (C)	0.142	207	4.3	-	-	-	-

Torsion and deflections have not been considered in the design.

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

□	538 ST UA70X70X6	PASS	BS-4.7 (C)	0.258	213
		10.04 C	0.00	0.00	4.00

MATERIAL DATA

Grade of steel = S 275
Modulus of elasticity = 205 kN/mm2
Design Strength (py) = 344 N/mm2

SECTION PROPERTIES (units - cm)

Member Length = 400.28
Gross Area = 8.20 Net Area = 8.20 Eff. Area = 8.20

	z-z axis	y-y axis
Moment of inertia	: 15.391	60.246
Plastic modulus	: 10.133	21.909
Elastic modulus	: 5.629	12.171
Effective modulus	: 5.629	12.171
Shear Area	: 2.520	2.520

DESIGN DATA (units - kN,m)
BS5950-1/2000
Section Class : SLENDER
Squash Load : 282.90
Axial force/Squash Load : 0.035

	z-z axis	y-y axis
Compression Capacity	: 38.9	83.4
Tension Capacity	: 282.9	282.9
Shear Capacity	: 52.2	52.2

BUCKLING CALCULATIONS (units - kN,m)

(axis nomenclature as per design code)

	v-v axis	a-a axis	b-b axis
Slenderness	: 189.914	122.402	122.402
Radius of gyration (cm)	: 1.370	2.126	2.126
Effective Length	: 2.602	2.602	2.602

LTB Moment Capacity (kNm) and LTB Length (m): 2.50, 4.003
LTB Coefficients & Associated Moments (kNm):
mLT = 1.00 : mx = 0.00 : my = 0.00 : myx = 0.00
MLt = 0.00 : Mx = 0.00 : My = 0.00 : My = 0.00

CRITICAL LOADS FOR EACH CLAUSE CHECK (units- kN,m):

CLAUSE	RATIO	LOAD	FX	VY	VZ	MZ	MY
BS-4.6 (T)	0.010	206	2.9	-	-	-	-
BS-4.7 (C)	0.258	213	10.0	-	-	-	-

Torsion and deflections have not been considered in the design.

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

□	539 ST UA70X70X6	PASS	BS-4.7 (C)	0.268	222
		10.11 C	0.00	0.00	4.07

MATERIAL DATA

Grade of steel = S 275
Modulus of elasticity = 205 kN/mm2
Design Strength (py) = 344 N/mm2

SECTION PROPERTIES (units - cm)

Member Length = 407.37
Gross Area = 8.20 Net Area = 8.20 Eff. Area = 8.20

	z-z axis	y-y axis
Moment of inertia	: 15.391	60.246
Plastic modulus	: 10.133	21.909
Elastic modulus	: 5.629	12.171
Effective modulus	: 5.629	12.171
Shear Area	: 2.520	2.520

DESIGN DATA (units - kN,m) BS5950-1/2000
Section Class : SLENDER
Squash Load : 282.90
Axial force/Squash load : 0.036

	z-z axis	y-y axis
Compression Capacity	: 37.7	81.1
Tension Capacity	: 282.9	282.9
Shear Capacity	: 52.2	52.2

BUCKLING CALCULATIONS (units - kN,m)

(axis nomenclature as per design code)

	v-v axis	a-a axis	b-b axis
Slenderness	: 193.276	124.569	124.569
Radius of gyration (cm)	: 1.370	2.126	2.126
Effective Length	: 2.648	2.648	2.648

LTB Moment Capacity (kNm) and LTB Length (m): 2.47, 4.074
LTB Coefficients & Associated Moments (kNm):
mLT = 1.00 : mx = 0.00 : my = 0.00 : myx = 0.00
MLt = 0.00 : Mx = 0.00 : My = 0.00 : My = 0.00

CRITICAL LOADS FOR EACH CLAUSE CHECK (units- kN,m):

CLAUSE	RATIO	LOAD	FX	VY	VZ	MZ	MY
BS-4.6 (T)	0.010	206	2.9	-	-	-	-
BS-4.7 (C)	0.268	222	10.1	-	-	-	-

Torsion and deflections have not been considered in the design.

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

□	540 ST UA70X70X6	PASS	BS-4.7 (C)	0.268	220
		10.11 C	0.00	0.00	0.00

MATERIAL DATA

Grade of steel = S 275
Modulus of elasticity = 205 kN/mm2
Design Strength (py) = 344 N/mm2

SECTION PROPERTIES (units - cm)

Member Length = 407.37
Gross Area = 8.20 Net Area = 8.20 Eff. Area = 8.20

	z-z axis	y-y axis
Moment of inertia	: 15.391	60.246
Plastic modulus	: 10.133	21.909
Elastic modulus	: 5.629	12.171
Effective modulus	: 5.629	12.171
Shear Area	: 2.520	2.520

DESIGN DATA (units - kN,m)

BS5950-1/2000
Section Class : SLENDER
Squash Load : 282.90
Axial force/Squash load : 0.036

	z-z axis	y-y axis
Compression Capacity	: 37.7	81.1
Tension Capacity	: 282.9	282.9
Shear Capacity	: 52.2	52.2

BUCKLING CALCULATIONS (units - kN,m)

(axis nomenclature as per design code)

	v-v axis	a-a axis	b-b axis
Slenderness	: 193.276	124.569	124.569
Radius of gyration (cm)	: 1.370	2.126	2.126
Effective Length	: 2.648	2.648	2.648

LTB Moment Capacity (kNm) and LTB Length (m): 2.47, 4.074

LTB Coefficients & Associated Moments (kNm):

mLT = 1.00 : mx = 0.00 : my = 0.00 : myx = 0.00
MLt = 0.00 : Mx = 0.00 : My = 0.00 : My = 0.00

CRITICAL LOADS FOR EACH CLAUSE CHECK (units- kN,m):

CLAUSE	RATIO	LOAD	FX	VY	VZ	MZ	MY
BS-4.6 (T)	0.010	206	2.9	-	-	-	-
BS-4.7 (C)	0.268	220	10.1	-	-	-	-

Torsion and deflections have not been considered in the design.

□

Torsion and deflections have not been considered in the design.

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

541 ST UA70X70X6	PASS	BS-4.7 (C)	0.258	213
	10.04 C	0.00	0.00	0.00

□

=====

MATERIAL DATA

Grade of steel = S 275
 Modulus of elasticity = 205 kN/mm²
 Design Strength (py) = 344 N/mm²

SECTION PROPERTIES (units - cm)

Member Length = 400.28
 Gross Area = 8.20 Net Area = 8.20 Eff. Area = 8.20

	z-z axis	y-y axis
Moment of inertia	: 15.391	60.246
Plastic modulus	: 10.133	21.909
Elastic modulus	: 5.629	12.171
Effective modulus	: 5.629	12.171
Shear Area	: 2.520	2.520

DESIGN DATA (units - kN,m)

Section Class : SLENDER
 Squash Load : 282.90
 Axial force/Squash load : 0.035

	z-z axis	y-y axis
Compression Capacity	: 38.9	83.4
Tension Capacity	: 282.9	282.9
Shear Capacity	: 52.2	52.2

BUCKLING CALCULATIONS (units - kN,m)

(axis nomenclature as per design code)

	v-v axis	a-a axis	b-b axis
Slenderness	: 189.914	122.402	122.402
Radius of gyration (cm)	: 1.370	2.126	2.126
Effective Length	: 2.602	2.602	2.602

LTB Moment Capacity (kNm) and LTB Length (m): 2.50, 4.003
 LTB Coefficients & Associated Moments (kNm):
 mLT = 1.00 : mx = 0.00 : my = 0.00 : myx = 0.00
 Mlt = 0.00 : Mx = 0.00 : My = 0.00 : My = 0.00

CRITICAL LOADS FOR EACH CLAUSE CHECK (units- kN,m):

CLAUSE	RATIO	LOAD	FX	VY	VZ	MZ	MY
BS-4.6 (T)	0.010	206	2.9	-	-	-	-
BS-4.7 (C)	0.258	213	10.0	-	-	-	-

□

Torsion and deflections have not been considered in the design.

542	TAPERED	PASS	BS-4.7 (C)	0.229	222
		62.99 C	-5.43	6.42	0.50

CALCULATED CAPACITIES FOR MEMB 542 UNIT - kN,m SECTION CLASS 4
 MCZ= 177.6 MCY= 35.1 PC= 1550.7 PT= 1691.9 MB= 177.6
 BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00
 Shear Buckling check is required: Vb = 352 kN : qw = 207 N/mm²
 d = 284 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm²
 BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS

543	TAPERED	PASS	BS-4.7 (C)	0.241	221
		66.36 C	-5.72	-6.70	0.50

CALCULATED CAPACITIES FOR MEMB 543 UNIT - kN,m SECTION CLASS 4
 MCZ= 177.6 MCY= 35.1 PC= 1550.7 PT= 1691.9 MB= 177.6
 BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00
 Shear Buckling check is required: Vb = 352 kN : qw = 207 N/mm²
 d = 284 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm²
 BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS

544	TAPERED	PASS	BS-4.7 (C)	0.068	213
		85.58 C	-0.01	-2.80	0.50

CALCULATED CAPACITIES FOR MEMB 544 UNIT - kN,m SECTION CLASS 4
 MCZ= 177.6 MCY= 35.1 PC= 1550.7 PT= 1691.9 MB= 177.6
 BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00
 Shear Buckling check is required: Vb = 352 kN : qw = 207 N/mm²
 d = 284 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm²
 BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS

545	TAPERED	PASS	BS-4.7 (C)	0.072	201
		90.24 C	-0.01	3.05	0.50

CALCULATED CAPACITIES FOR MEMB 545 UNIT - kN,m SECTION CLASS 4
 MCZ= 177.6 MCY= 35.1 PC= 1550.7 PT= 1691.9 MB= 177.6
 BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00
 Shear Buckling check is required: Vb = 352 kN : qw = 207 N/mm²
 d = 284 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm²
 BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS

546	TAPERED	PASS	BS-4.7 (C)	0.067	213
		85.66 C	0.01	-2.71	0.50

CALCULATED CAPACITIES FOR MEMB 546 UNIT - kN,m SECTION CLASS 4
 MCZ= 177.6 MCY= 35.1 PC= 1550.7 PT= 1691.9 MB= 177.6
 BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00
 Shear Buckling check is required: Vb = 352 kN : qw = 207 N/mm²
 d = 284 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm²
 BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS

547	TAPERED	PASS	BS-4.7 (C)	0.073	201
		90.22 C	0.01	3.16	0.50

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

□

CALCULATED CAPACITIES FOR MEMB 547 UNIT - kN,m SECTION CLASS 4					
MCZ= 177.6 MCY= 35.1 PC= 1550.7 PT= 1691.9 MB= 177.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 352 kN : qw = 207 N/mm2					
d = 284 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

548	TAPERED	PASS	BS-4.7 (C)	0.229	220
62.99 C 5.44 6.42 0.50					

CALCULATED CAPACITIES FOR MEMB 548 UNIT - kN,m SECTION CLASS 4					
MCZ= 177.6 MCY= 35.1 PC= 1550.7 PT= 1691.9 MB= 177.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 352 kN : qw = 207 N/mm2					
d = 284 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

549	TAPERED	PASS	BS-4.7 (C)	0.242	219
66.37 C 5.77 -6.70 0.50					

CALCULATED CAPACITIES FOR MEMB 549 UNIT - kN,m SECTION CLASS 4					
MCZ= 177.6 MCY= 35.1 PC= 1550.7 PT= 1691.9 MB= 177.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 352 kN : qw = 207 N/mm2					
d = 284 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

550	TAPERED	PASS	BS-4.7 (C)	0.285	207
86.23 C -7.66 2.71 0.20					

CALCULATED CAPACITIES FOR MEMB 550 UNIT - kN,m SECTION CLASS 4					
MCZ= 177.6 MCY= 35.1 PC= 1550.7 PT= 1691.9 MB= 177.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 352 kN : qw = 207 N/mm2					
d = 284 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

CALCULATED CAPACITIES FOR MEMB 551 UNIT - kN,m SECTION CLASS 4					
MCZ= 177.6 MCY= 35.1 PC= 1550.7 PT= 1691.9 MB= 177.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 352 kN : qw = 207 N/mm2					
d = 284 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

551	TAPERED	PASS	BS-4.7 (C)	0.089	208
99.55 C -0.16 4.48 0.20					

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

□

CALCULATED CAPACITIES FOR MEMB 551 UNIT - kN,m SECTION CLASS 4					
MCZ= 177.6 MCY= 35.1 PC= 1550.7 PT= 1691.9 MB= 177.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 352 kN : qw = 207 N/mm2					
d = 284 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

552	TAPERED	PASS	BS-4.7 (C)	0.089	208
99.52 C 0.16 4.50 0.20					

CALCULATED CAPACITIES FOR MEMB 552 UNIT - kN,m SECTION CLASS 4					
MCZ= 177.6 MCY= 35.1 PC= 1550.7 PT= 1691.9 MB= 177.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 352 kN : qw = 207 N/mm2					
d = 284 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

553	TAPERED	PASS	BS-4.7 (C)	0.285	207
86.24 C 7.66 2.71 0.20					

CALCULATED CAPACITIES FOR MEMB 553 UNIT - kN,m SECTION CLASS 4					
MCZ= 177.6 MCY= 35.1 PC= 1550.7 PT= 1691.9 MB= 177.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 352 kN : qw = 207 N/mm2					
d = 284 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

554	TAPERED	PASS	BS-4.7 (C)	0.282	207
83.98 C -7.62 -2.59 0.20					

CALCULATED CAPACITIES FOR MEMB 554 UNIT - kN,m SECTION CLASS 4					
MCZ= 177.6 MCY= 35.1 PC= 1550.7 PT= 1691.9 MB= 177.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 352 kN : qw = 207 N/mm2					
d = 284 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

CALCULATED CAPACITIES FOR MEMB 555 UNIT - kN,m SECTION CLASS 4					
MCZ= 177.6 MCY= 35.1 PC= 1550.7 PT= 1691.9 MB= 177.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 352 kN : qw = 207 N/mm2					
d = 284 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

555	TAPERED	PASS	BS-4.7 (C)	0.087	208
97.28 C -0.14 -4.46 0.20					

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

□

CALCULATED CAPACITIES FOR MEMB 555 UNIT - kN,m SECTION CLASS 4					
MCZ= 177.6 MCY= 35.1 PC= 1550.7 PT= 1691.9 MB= 177.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 352 kN : qw = 207 N/mm2					
d = 284 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

556	TAPERED	PASS	BS-4.7 (C)	0.087	208
		97.28 C	0.14	-4.48	0.20

CALCULATED CAPACITIES FOR MEMB 556 UNIT - kN,m SECTION CLASS 4					
MCZ= 177.6 MCY= 35.1 PC= 1550.7 PT= 1691.9 MB= 177.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 352 kN : qw = 207 N/mm2					
d = 284 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

557	TAPERED	PASS	BS-4.7 (C)	0.281	207
		83.98 C	7.59	-2.59	0.20

CALCULATED CAPACITIES FOR MEMB 557 UNIT - kN,m SECTION CLASS 4					
MCZ= 177.6 MCY= 35.1 PC= 1550.7 PT= 1691.9 MB= 177.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 352 kN : qw = 207 N/mm2					
d = 284 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

558	TAPERED	PASS	BS-4.7 (C)	0.085	203
		36.68 C	-0.01	-11.12	0.44

CALCULATED CAPACITIES FOR MEMB 558 UNIT - kN,m SECTION CLASS 4					
MCZ= 177.6 MCY= 35.1 PC= 1550.7 PT= 1691.9 MB= 177.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 352 kN : qw = 207 N/mm2					
d = 284 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

559	TAPERED	PASS	BS-4.7 (C)	0.110	203
		46.89 C	0.02	-14.36	0.44

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

□

CALCULATED CAPACITIES FOR MEMB 559 UNIT - kN,m SECTION CLASS 4					
MCZ= 177.6 MCY= 35.1 PC= 1550.7 PT= 1691.9 MB= 177.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 352 kN : qw = 207 N/mm2					
d = 284 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

560	TAPERED	PASS	BS-4.7 (C)	0.110	203
		46.85 C	-0.02	-14.36	0.44

CALCULATED CAPACITIES FOR MEMB 560 UNIT - kN,m SECTION CLASS 4					
MCZ= 177.6 MCY= 35.1 PC= 1550.7 PT= 1691.9 MB= 177.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 352 kN : qw = 207 N/mm2					
d = 284 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

561	TAPERED	PASS	BS-4.7 (C)	0.085	203
		36.68 C	0.01	-11.12	0.44

CALCULATED CAPACITIES FOR MEMB 561 UNIT - kN,m SECTION CLASS 4					
MCZ= 177.6 MCY= 35.1 PC= 1550.7 PT= 1691.9 MB= 177.6					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 352 kN : qw = 207 N/mm2					
d = 284 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

562	TAPERED	PASS	BS-4.8.2.2	0.138	207
		25.04 T	5.03	-12.26	0.66

CALCULATED CAPACITIES FOR MEMB 562 UNIT - kN,m SECTION CLASS 3					
MCZ= 324.8 MCY= 56.7 PC= 1663.1 PT= 2166.6 MB= 324.8					
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d = 380 mm : t = 6 mm : a = 0 mm : pyf = 344 N/mm2					
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

564	TAPERED	PASS	BS-4.8.2.2	0.101	212
		56.70 T	0.17	-23.46	0.00

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

□

CALCULATED CAPACITIES FOR MEMB 564 UNIT - kN,m SECTION CLASS 3					
MCZ=	324.8	MCY= 56.7	PC= 1663.1	PT= 2166.6	MB= 324.8
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d	= 380 mm	: t = 6 mm	: a = 0 mm	: pyf = 344 N/mm2	
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

566	TAPERED	PASS	BS-4.8.2.2	0.101	212
56.71 T -0.17 -23.46 0.00					

CALCULATED CAPACITIES FOR MEMB 566 UNIT - kN,m SECTION CLASS 3					
MCZ=	324.8	MCY= 56.7	PC= 1663.1	PT= 2166.6	MB= 324.8
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d	= 380 mm	: t = 6 mm	: a = 0 mm	: pyf = 344 N/mm2	
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

567	TAPERED	PASS	BS-4.8.2.2	0.138	207
25.04 T -5.03 -12.26 0.66					

CALCULATED CAPACITIES FOR MEMB 567 UNIT - kN,m SECTION CLASS 3					
MCZ=	324.8	MCY= 56.7	PC= 1663.1	PT= 2166.6	MB= 324.8
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d	= 380 mm	: t = 6 mm	: a = 0 mm	: pyf = 344 N/mm2	
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

568	TAPERED	PASS	BS-4.7 (C)	0.085	215
36.82 C -0.01 -11.13 0.44					

CALCULATED CAPACITIES FOR MEMB 568 UNIT - kN,m SECTION CLASS 4					
MCZ=	177.6	MCY= 35.1	PC= 1550.7	PT= 1691.9	MB= 177.6
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d	= 380 mm	: t = 6 mm	: a = 0 mm	: pyf = 344 N/mm2	
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

569	TAPERED	PASS	BS-4.7 (C)	0.110	215
46.94 C 0.02 -14.35 0.44					

□

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					

□

CALCULATED CAPACITIES FOR MEMB 569 UNIT - kN,m SECTION CLASS 4					
MCZ=	177.6	MCY= 35.1	PC= 1550.7	PT= 1691.9	MB= 177.6
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 352 kN : qw = 207 N/mm2					
d	= 284 mm	: t = 6 mm	: a = 0 mm	: pyf = 344 N/mm2	
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

570	TAPERED	PASS	BS-4.7 (C)	0.110	215
46.93 C -0.02 -14.35 0.44					

CALCULATED CAPACITIES FOR MEMB 570 UNIT - kN,m SECTION CLASS 4					
MCZ=	177.6	MCY= 35.1	PC= 1550.7	PT= 1691.9	MB= 177.6
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 352 kN : qw = 207 N/mm2					
d	= 284 mm	: t = 6 mm	: a = 0 mm	: pyf = 344 N/mm2	
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

571	TAPERED	PASS	BS-4.7 (C)	0.085	215
36.81 C 0.01 -11.13 0.44					

CALCULATED CAPACITIES FOR MEMB 571 UNIT - kN,m SECTION CLASS 4					
MCZ=	177.6	MCY= 35.1	PC= 1550.7	PT= 1691.9	MB= 177.6
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 352 kN : qw = 207 N/mm2					
d	= 284 mm	: t = 6 mm	: a = 0 mm	: pyf = 344 N/mm2	
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

572	TAPERED	PASS	BS-4.8.2.2	0.136	207
25.32 T -5.02 -11.78 0.66					

CALCULATED CAPACITIES FOR MEMB 572 UNIT - kN,m SECTION CLASS 3					
MCZ=	324.8	MCY= 56.7	PC= 1663.1	PT= 2166.6	MB= 324.8
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00					
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2					
d	= 380 mm	: t = 6 mm	: a = 0 mm	: pyf = 344 N/mm2	
BS-4.4.3.2 status = PASS : BS-4.4.3.3 status = PASS					

573	TAPERED	PASS	BS-4.8.2.2	0.101	212
56.65 T -0.16 -23.37 0.00					

□

□STEEL TAKE OFF □

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER TABLE RESULT/ CRITICAL COND/ RATIO/ LOADING/

FX MY MZ LOCATION

□

CALCULATED CAPACITIES FOR MEMB 573 UNIT - kN,m SECTION CLASS 3				
MCZ= 324.8	MCY= 56.7	PC= 1663.1	PT= 2166.6	MB= 324.8
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00				
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2				
d = 380 mm :	t = 6 mm	: a = 0 mm : pyf = 344 N/mm2		
BS-4.4.3.2		status = PASS : BS-4.4.3.3 status = PASS		

574	TAPERED	PASS	BS-4.8.2.2	0.101 212
		56.65 T	0.16	-23.37 0.00

CALCULATED CAPACITIES FOR MEMB 574 UNIT - kN,m SECTION CLASS 3				
MCZ= 324.8	MCY= 56.7	PC= 1663.1	PT= 2166.6	MB= 324.8
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00				
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2				
d = 380 mm :	t = 6 mm	: a = 0 mm : pyf = 344 N/mm2		
BS-4.4.3.2		status = PASS : BS-4.4.3.3 status = PASS		

575	TAPERED	PASS	BS-4.8.2.2	0.136 207
		25.32 T	5.02	-11.78 0.66

CALCULATED CAPACITIES FOR MEMB 575 UNIT - kN,m SECTION CLASS 3				
MCZ= 324.8	MCY= 56.7	PC= 1663.1	PT= 2166.6	MB= 324.8
BUCKLING CO-EFFICIENTS mLT = 1.00, mx = 0.00, my = 0.00, myx = 0.00				
Shear Buckling check is required : Vb = 471 kN : qw = 207 N/mm2				
d = 380 mm :	t = 6 mm	: a = 0 mm : pyf = 344 N/mm2		
BS-4.4.3.2		status = PASS : BS-4.4.3.3 status = PASS		

***** END OF TABULATED RESULT OF DESIGN *****

608. STEEL TAKE OFF ALL

□

□

STEEL TAKE-OFF

PROFILE	LENGTH(METE)	WEIGHT(KN)
ISECT: TAPERED	1 21.60	9.822
ISECT: TAPERED	2 87.01	42.619
ISECT: TAPERED	95 21.22	10.148
ISECT: TAPERED	201 164.60	60.086
ISECT: TAPERED	301 86.40	49.574
ST UA70X70X6	114.13	7.300
ISECT: TAPERED	542 9.08	3.474
TOTAL =		183.023

***** END OF DATA FROM INTERNAL STORAGE *****

609. FINISH

***** END OF THE STAAD.Pro RUN *****

**** DATE= DEC 25,2007 TIME= 15:43:40 ****