
* STAAD.Pro V8i SELECTseries5 *
* Version 20.07.10.65 *
* Proprietary Program of Bentley Systems, Inc. *
* Date= NOV 16, 2017 *
* Time= 11:56:11 *
* USER ID: *****

1. STAAD PLANE
INPUT FILE: 343K.STD
2. START JOB INFORMATION
3. ENGINEER DATE 16-NOV-17
4. END JOB INFORMATION
5. INPUT WIDTH 79
6. UNIT METER KN
7. JOINT COORDINATES
8. 13 0 3.355 0; 22 5.46 3.355 0; 32 0 6.195 0; 33 0.606667 6.195 0
9. 34 1.21333 6.195 0; 35 1.82 6.195 0; 36 2.42667 6.195 0; 37 3.03333 6.195 0
10. 38 3.64 6.195 0; 39 4.24667 6.195 0; 40 4.85333 6.195 0; 41 5.46 6.195 0
11. 42 0 6.795 0; 43 0.303333 6.795 0; 45 0.91 6.795 0; 47 1.51667 6.795 0
12. 49 2.12333 6.795 0; 51 2.73 6.795 0; 53 3.33667 6.795 0; 55 3.94333 6.795 0
13. 57 4.55 6.795 0; 59 5.15667 6.795 0; 60 5.46 6.795 0; 61 0 9.735 0
14. 62 0.91 9.735 0; 63 1.82 9.735 0; 64 2.73 9.735 0; 65 3.64 9.735 0
15. 66 4.55 9.735 0; 67 5.46 9.735 0; 68 0.91 9.945 0; 69 1.82 10.155 0
16. 70 2.73 10.365 0; 71 3.64 10.155 0; 72 4.55 9.945 0; 74 5.46 9.385 0
17. 75 7.26 9.385 0; 76 6.66 6.795 0; 78 6.375 6.795 0; 80 6.36 9.385 0
18. 82 6.36 9.56 0
19. MEMBER INCIDENCES
20. 3 32 42; 4 41 60; 5 61 42; 6 67 74; 7 32 13; 8 41 22; 11 74 60; 12 60 78
21. 14 78 76; 16 61 62; 17 62 63; 18 63 64; 19 64 65; 20 65 66; 21 66 67; 22 61 68
22. 23 68 69; 24 69 70; 25 70 71; 26 71 72; 27 72 67; 28 41 78; 30 62 68; 31 63 69
23. 32 64 70; 33 65 71; 34 66 72; 35 63 68; 36 64 69; 37 64 71; 38 65 72; 39 67 82
24. 40 74 80; 41 80 75; 42 82 75; 43 82 80; 44 74 82; 72 32 33; 73 33 34; 74 34 35
25. 75 35 36; 76 36 37; 77 37 38; 78 38 39; 79 39 40; 80 40 41; 81 42 43; 90 43 45
26. 91 45 47; 92 47 49; 93 49 51; 94 51 53; 95 53 55; 96 55 57; 97 57 59; 98 59 60
27. 117 32 43; 118 43 33; 119 45 33; 120 45 34; 121 47 34; 122 47 35; 123 49 35
28. 124 49 36; 125 51 36; 126 51 37; 127 53 37; 128 53 38; 129 55 38; 130 55 39
29. 131 57 39; 132 57 40; 133 59 40; 134 59 41
30. START USER TABLE
31. TABLE 1
32. UNIT RMS KN
33. GENERAL
34. 2C75X45
35. 1098 75 6 90 3 938192 638334 100000 26218 14185 450 270 26218 14185 100000 75
36. TABLE 2
37. UNIT RMS KN
38. GENERAL

STAAD PLANE

39. C75X45
40. 518 45 3 75 3 138000 449000 100000 4940 12000 270 315 4940 12000 100000 40
41. TABLE 3
42. UNIT RMS KN
43. TUBE
44. SHS38X3-CF
45. 397 38 38 3 78500 78500 133000 228 152
46. SHS50X3
47. 564 50 50 3 208492 208492 311469 300 200
48. SHS75X75X3
49. 864 75 75 3 747792 747792 1.11974E+006 450 450
50. TABLE 4
51. UNIT RMS KN
52. GENERAL
53. C100X50
54. 653 50 3 100 3 229000 990000 1E+006 7270 19800 300 343 11600 23600 1E+006 48
55. TABLE 5
56. UNIT RMS KN
57. ANGLE
58. UA38X38X3
59. 38 38 3 7.51315 76 76
60. TABLE 6
61. UNIT RMS KN
62. GENERAL
63. C75NSHS75X3
64. 1673 150 6 80 3 3.82575E+006 3.79732E+006 100000 51941 94933 690 848 -
65. 51941 94933 100000 150
66. END
67. UNIT METER KN
68. DEFINE MATERIAL START
69. ISOTROPIC STEEL
70. E 2.05E+008
71. POISSON 0.3
72. DENSITY 76.8195
73. ALPHA 1.2E-005
74. DAMP 0.03
75. END DEFINE MATERIAL
76. MEMBER PROPERTY BRITISH
77. 16 TO 38 32 UPTABLE 2 C75X45
78. MEMBER PROPERTY BRITISH
79. 30 31 33 TO 44 UPTABLE 3 SHS38X3-CF
80. MEMBER PROPERTY BRITISH
81. 72 TO 81 90 TO 98 UPTABLE 4 C100X50
82. MEMBER PROPERTY BRITISH
83. 117 TO 134 UPTABLE 5 UA38X38X3
84. MEMBER PROPERTY BRITISH
85. 12 14 UPTABLE 3 SHS75X75X3
86. MEMBER PROPERTY
87. 3 TO 8 11 UPTABLE 6 C75NSHS75X3
88. CONSTANTS
89. MATERIAL STEEL ALL
90. SUPPORTS
91. 13 22 PINNED
92. MEMBER RELEASE
93. 16 22 39 40 72 81 START MX MY MZ
94. 21 27 80 98 END MX MY MZ

STAAD PLANE

```
95. MEMBER TRUSS
96. 30 TO 38 43 44 117 TO 134
97. LOAD 1 LOADTYPE DEAD TITLE DL
98. SELFWEIGHT Y -1
99. MEMBER LOAD
100. 12 14 81 90 TO 98 UNI GY -0.55
101. 22 TO 27 UNI GY -1.27
102. 39 42 UNI GY -0.64
103. LOAD 2 LOADTYPE LIVE REDUCIBLE TITLE LL
104. MEMBER LOAD
105. 12 14 81 90 TO 98 UNI GY -5.46
106. 22 TO 27 UNI GY -1.82
107. 39 42 UNI GY -0.91
108. LOAD 3 LOADTYPE WIND TITLE WL
109. MEMBER LOAD
110. 16 TO 21 UNI GY 1.18
111. LOAD 4 LOADTYPE NONE TITLE WLII
112. MEMBER LOAD
113. 3 5 7 UNI GX 0.6
114. LOAD COMB 5 1.35DL+1.5LL
115. 1 1.35 2 1.5
116. LOAD COMB 6 1.35DL+1.5LL+0.75WL
117. 1 1.35 2 1.5 3 0.75
118. LOAD COMB 7 1.35DL+1.05LL+1.35WL
119. 1 1.35 2 1.05 3 1.35
120. LOAD COMB 8 1.35DL+1.5LL+0.75WLII
121. 1 1.35 2 1.5 3 0.75
122. LOAD COMB 9 1.35DL+1.05LL+1.35WLII
123. 1 1.35 2 1.05 4 1.35
124. LOAD COMB 10 1.0DL+1.0LL
125. 1 1.0 2 1.0
126. PERFORM ANALYSIS
```

PROBLEM STATISTICS

NUMBER OF JOINTS	41	NUMBER OF MEMBERS	74
NUMBER OF PLATES	0	NUMBER OF SOLIDS	0
NUMBER OF SURFACES	0	NUMBER OF SUPPORTS	2

SOLVER USED IS THE OUT-OF-CORE BASIC SOLVER

ORIGINAL/FINAL BAND-WIDTH=	27/	5/	18 DOF
TOTAL PRIMARY LOAD CASES =	4,	TOTAL DEGREES OF FREEDOM =	119
TOTAL LOAD COMBINATION CASES =	6	SO FAR,	
SIZE OF STIFFNESS MATRIX =	3	DOUBLE KILO-WORDS	
REQD/AVAIL. DISK SPACE =	12.1/-	655695.1 MB	

STAAD PLANE

```
127. PARAMETER 1
128. CODE EN 1993-1-1:2005
129. SGR 1 ALL
130. CHECK CODE ALL

STAAD.PRO CODE CHECKING - EN 1993-1-1:2005
*****
NATIONAL ANNEX - NOT USED

PROGRAM CODE REVISION V1.11 BS_EC3_2005/1
```