

```

*****
*
*          STAAD.Pro V8i SELECTseries3          *
*          Version  20.07.08.22                  *
*          Proprietary Program of                *
*          Bentley Systems, Inc.                 *
*          Date=    NOV 12, 2012                 *
*          Time=    3:12:51                     *
*
*          USER ID: JCUBE ENGINEERING SERVICES PTE L
*****

```

```

1. STAAD SPACE
INPUT FILE: 172-PF-03_EL_+2.70.STD
2. START JOB INFORMATION
3. ENGINEER DATE 12-NOV-12
4. END JOB INFORMATION
5. INPUT WIDTH 79
6. UNIT METER KN
7. JOINT COORDINATES
8. 1 0 0 0; 2 0 0.7 0; 3 0 0 1; 4 0 0.7 1; 5 3.15 0 0; 6 3.15 0.7 0; 7 3.15 0 1
9. 8 3.15 0.7 1; 9 0.5 0 0; 10 0.5 0 1
10. MEMBER INCIDENCES
11. 1 1 2; 2 3 4; 3 5 6; 4 7 8; 5 2 6; 6 4 8; 7 2 4; 8 6 8; 9 1 9; 10 3 10
12. START USER TABLE
13. TABLE 1
14. UNIT METER KN
15. WIDE FLANGE
16. UC10210219.4
17. 0.00244007 0.1057 0.0071 0.1031 0.0088 4.67579E-006 1.60997E-006 5.73505E-008 -
18. 0.00075047 0.00181456
19. END
20. DEFINE MATERIAL START
21. ISOTROPIC STEEL
22. E 2.05E+008
23. POISSON 0.3
24. DENSITY 76.8195
25. ALPHA 1.2E-005
26. DAMP 0.03
27. TYPE STEEL
28. STRENGTH FY 253200 FU 407800 RY 1.5 RT 1.2
29. END DEFINE MATERIAL
30. MEMBER PROPERTY AMERICAN
31. 1 TO 10 UPTABLE 1 UC10210219.4
32. CONSTANTS
33. BETA 90 MEMB 1 TO 4
34. MATERIAL STEEL ALL
35. MEMBER RELEASE
36. 1 2 START MPY 0.99 MPZ 0.99
37. SUPPORTS
38. 9 10 FIXED
39. 5 7 PINNED
40. LOAD 1 LOADTYPE DEAD TITLE LOAD CASE 1 SELF WEIGHT

```

STAAD SPACE

-- PAGE NO. 2

41. LOAD 2 LOADTYPE DEAD TITLE LOAD CASE 2 SDL  
 42. ONEWAY LOAD  
 43. YRANGE 0 1.5 ONE -0.75 GY

**\*\*WARNING\*\*** about Floor/OneWay Loads/Weights.

Please note that depending on the shape of the floor you may have to break up the FLOOR/ONEWAY LOAD into multiple commands. For details please refer to Technical Reference Manual Section 5.32.4 Note 6.

44. LOAD 3 LOADTYPE LIVE TITLE LOAD CASE 3 LL  
 45. ONEWAY LOAD  
 46. YRANGE 0 1.5 ONE -5 GY  
 47. LOAD 4 LOADTYPE WIND TITLE LOAD CASE 4 WL(X)  
 48. LOAD 5 LOADTYPE WIND TITLE LOAD CASE 5 WL(Z)  
 49. LOAD COMB 6 COMBINATION LOAD CASE 6 1.0DL+1.0LL  
 50. 1 1.0 2 1.0 3 1.0  
 51. LOAD COMB 7 COMBINATION LOAD CASE 7 1.4DL+1.6LL  
 52. 1 1.4 2 1.4 3 1.6  
 53. PERFORM ANALYSIS

# P R O B L E M   S T A T I S T I C S

-----

NUMBER OF JOINTS/MEMBER+ELEMENTS/SUPPORTS = 10/ 10/ 4

SOLVER USED IS THE OUT-OF-CORE BASIC SOLVER

ORIGINAL/FINAL BAND-WIDTH= 8/ 3/ 21 DOF  
 TOTAL PRIMARY LOAD CASES = 5, TOTAL DEGREES OF FREEDOM = 42  
 SIZE OF STIFFNESS MATRIX = 1 DOUBLE KILO-WORDS  
 REQ'D/AVAIL. DISK SPACE = 12.0/ 270894.6 MB

54. PARAMETER 1  
 55. CODE BS5950  
 56. CHECK CODE ALL

STAAD.Pro CODE CHECKING - (BSI )  
 \*\*\*\*\*

PROGRAM CODE REVISION V2.13\_5950-1\_2000