

```
*****
*
*      STAAD.Pro
*      Version 2007   Build 04
*      Proprietary Program of
*      Research Engineers, Intl.
*      Date=   JUN 20, 2012
*      Time=   12:26:36
*
*      USER ID: RNS _ASSOCIATES
*****

1. STAAD SPACE
INPUT FILE: 20120512 T-Goal Post 021-022.STD
2. START JOB INFORMATION
3. ENGINEER DATE 12-MAY-12
4. END JOB INFORMATION
5. INPUT WIDTH 79
6. UNIT METER KN
7. JOINT COORDINATES
8. 2 5 1 -6.085; 4 5 2.197 -6.085; 6 5 2.197 -10.085; 11 5 1 -10.085
9. MEMBER INCIDENCES
10. 3 2 4; 5 6 4; 10 11 6
11. DEFINE MATERIAL START
12. ISOTROPIC STEEL
13. E 2.05E+008
14. POISSON 0.3
15. DENSITY 76.8195
16. ALPHA 1.2E-005
17. DAMP 0.03
18. END DEFINE MATERIAL
19. MEMBER PROPERTY JAPANESE
20. 3 10 TABLE ST H394X398X11
21. 5 TABLE ST H394X398X11
22. CONSTANTS
23. BETA 90 MEMB 3 10
24. MATERIAL STEEL ALL
25. SUPPORTS
26. 2 11 FIXED
27. ***** DEAD LOAD *****
28. LOAD 1 LOADTYPE NONE TITLE DL
29. SELFWEIGHT Y -1
30. ***** LIVE LOAD *****
31. LOAD 2 LOADTYPE NONE TITLE FL
32. MEMBER LOAD
33. 5 CON GY -21.41 0.3
34. 5 CON GY -21.41 2
35. 5 CON GY -21.41 3.7
36. 5 CON GX -6.423 0.3
37. 5 CON GX -6.423 2
38. 5 CON GX -6.423 3.7
39. 5 CON GZ -6.26 0.3
40. 5 CON GZ -6.26 2
41. 5 CON GZ -6.26 3.7
42. ***** WIND LOAD X-DIRECTION*****
43. LOAD 3 LOADTYPE NONE TITLE WLX
44. MEMBER LOAD
45. 5 UNI GX -0.34
46. 3 10 UNI GX -0.34
47. ***** WIND LOAD Z-DIRECTION*****
48. LOAD 4 LOADTYPE NONE TITLE WLZ
49. MEMBER LOAD
50. 3 10 UNI GZ -0.34
51. ***** NOTIONAL LOAD X-DIRECTION*****
52. LOAD 5 LOADTYPE NONE TITLE NLX
53. SELFWEIGHT X -0.015
54. ***** NOTIONAL LOAD Z-DIRECTION*****
55. LOAD 6 LOADTYPE NONE TITLE NLZ
```

SOLVER USED IS THE IN-CORE ADVANCED SOLVER

TOTAL PRIMARY LOAD CASES = 6, TOTAL DEGREES OF FREEDOM = 12

80. LOAD LIST 7 TO 11
81. PRINT JOINT DISPLACEMENTS ALL

JOINT DISPLACEMENT (CM RADIANS) STRUCTURE TYPE = SPACE

JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
2	7	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	8	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	9	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	10	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
4	11	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	7	-0.0157	-0.0011	-0.0064	-0.0001	0.0003	0.0002
	8	-0.0171	-0.0011	-0.0064	-0.0001	0.0003	0.0002
	9	-0.0157	-0.0011	-0.0065	-0.0001	0.0003	0.0002
6	10	-0.0158	-0.0011	-0.0064	-0.0001	0.0003	0.0002
	11	-0.0157	-0.0011	-0.0064	-0.0001	0.0003	0.0002
	7	-0.0157	-0.0012	-0.0054	0.0001	-0.0003	0.0002
	8	-0.0171	-0.0012	-0.0054	0.0001	-0.0003	0.0002
11	9	-0.0157	-0.0012	-0.0055	0.0001	-0.0003	0.0002
	10	-0.0158	-0.0012	-0.0054	0.0001	-0.0003	0.0002
	11	-0.0157	-0.0012	-0.0054	0.0001	-0.0003	0.0002
	7	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	8	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	9	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	10	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	11	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000

***** END OF LATEST ANALYSIS RESULT *****

82. PRINT SUPPORT REACTION ALL

SUPPORT REACTIONS -UNIT KN METE STRUCTURE TYPE = SPACE

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM Z
2	7	9.63	35.05	-0.13	10.30	-0.03	-11.53
	8	10.72	35.05	-0.13	10.30	-0.03	-12.59
	9	9.63	35.03	0.28	10.49	-0.03	-11.53
	10	9.70	35.05	-0.13	10.30	-0.03	-11.60
11	11	9.63	35.05	-0.06	10.34	-0.03	-11.53
	7	9.63	38.35	18.91	5.59	0.03	-11.53
	8	10.72	38.35	18.91	5.59	0.03	-12.59
	9	9.63	38.37	19.31	5.79	0.03	-11.53
	10	9.70	38.35	18.91	5.59	0.03	-11.60
	11	9.63	38.36	18.98	5.64	0.03	-11.53

***** END OF LATEST ANALYSIS RESULT *****

83. LOAD LIST 12 TO 16
84. PRINT MEMBER FORCES ALL

FORCES ARE SMALL

Wednesday, June 20, 2012, 12:26 PM

10	12	11	60.44	30.05	15.42	0.05	-18.45	9.00
		6	-58.04	-30.05	-15.42	-0.05	0.00	26.98
	13	11	46.02	22.69	12.87	0.04	-15.11	6.71
		6	-43.96	-22.69	-12.38	-0.04	0.00	20.45
	14	11	46.05	23.18	11.56	0.03	-13.84	6.95
		6	-43.99	-22.69	-11.56	-0.03	0.00	20.50
	15	11	46.02	22.69	11.64	0.03	-13.92	6.71
		6	-43.96	-22.69	-11.61	-0.03	0.00	20.45
	16	11	46.03	22.77	11.56	0.03	-13.84	6.77
		6	-43.97	-22.74	-11.56	-0.03	0.00	20.47

***** END OF LATEST ANALYSIS RESULT *****

85. LOAD LIST ALL
 86. PARAMETER 1
 87. CODE BS5950
 88. BEAM 2 ALL
 89. CHECK CODE ALL

STAAD.Pro CODE CHECKING - (BSI)

PROGRAM CODE REVISION V2.12_5950-1_2000

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
3 ST	H394X398X11	PASS	BS-4.8.3.3.2	0.085	12
		55.17 C	18.45	16.43	-
5 ST	H394X398X11	PASS	BS-4.2.3-(Y)	0.084	12
		30.05 C	0.05	26.98	0.00
10 ST	H394X398X11	PASS	BS-4.8.3.3.2	0.099	12
		60.44 C	18.45	26.98	-

***** END OF TABULATED RESULT OF DESIGN *****

90. FINISH

***** END OF THE STAAD.Pro RUN *****

**** DATE= JUN 20,2012 TIME= 12:26:36 ****

 * For questions on STAAD.Pro, please contact *
 * Research Engineers Offices at the following locations *
 * *
 * Telephone Email *
 * USA: +1 (714)974-2500 support@bentley.com *
 * CANADA +1 (905)632-4771 detech@odandetech.com *
 * UK +44(1454)207-000 support@bentley.com *
 * NORWAY +47 67 57 21 30 staad@edr.no *
 * SINGAPORE +65 6225-6158 support@bentley.com *
 * INDIA +91(033)4006-2021 support@bentley.com *
 * JAPAN +81(03)5952-6500 eng-eye@crc.co.jp *
 * CHINA +86(411)8479-1166 support@bentley.com *
 * THAILAND +66(0)2645-1018/19 support@bentley.com *
 * *
 * North America support@bentley.com *

ratio are rather small to
 cause any major impact to
 structure