

```
*****
*
*          STAAD.Pro
*          Version 2007    Build 04
*          Proprietary Program of
*          Research Engineers, Intl.
*          Date=    JAN 31, 2013
*          Time=    11:15:13
*
*          USER ID:
*****
```

```
1. STAAD SPACE
INPUT FILE: 20130131 T-Goal Post 001 FR.STD
2. START JOB INFORMATION
3. ENGINEER DATE 12-MAY-12
4. END JOB INFORMATION
5. INPUT WIDTH 79
6. UNIT METER KN
7. JOINT COORDINATES
8. 1 5 1 -0.635; 2 5 1 -5.73; 3 5 4.69 -0.635; 4 5 4.69 -5.73; 5 5 4.69 0.165
9. 6 5 4.69 -6.53
10. MEMBER INCIDENCES
11. 1 4 3; 2 1 3; 3 2 4; 4 3 5; 5 6 4
12. DEFINE MATERIAL START
13. ISOTROPIC STEEL
14. E 2.05E+008
15. POISSON 0.3
16. DENSITY 76.8195
17. ALPHA 1.2E-005
18. DAMP 0.03
19. END DEFINE MATERIAL
20. MEMBER PROPERTY JAPANESE
21. 1 4 5 TABLE ST H400X400X13
22. 2 3 TABLE ST H400X400X13
23. CONSTANTS
24. MATERIAL STEEL ALL
25. SUPPORTS
26. 1 2 FIXED
27. ***** DEAD LOAD *****
28. LOAD 1 LOADTYPE NONE TITLE DL
29. SELFWEIGHT Y -1
30. JOINT LOAD
31. 3 4 FY -128.67
32. MEMBER LOAD
33. 1 CON GY -128.67 1.715
34. ***** FRICTIONAL LOAD *****
35. LOAD 2 LOADTYPE NONE TITLE FL
36. JOINT LOAD
37. 3 4 FX -6.67
38. MEMBER LOAD
39. 1 CON GX -6.67 1.715
40. ***** WIND LOAD X-DIRECTION*****
41. LOAD 3 LOADTYPE NONE TITLE WLX
42. MEMBER LOAD
43. 1 4 5 UNI GX -0.34
44. 2 3 UNI GX -0.34
45. ***** WIND LOAD Z-DIRECTION*****
46. LOAD 4 LOADTYPE NONE TITLE WLZ
47. MEMBER LOAD
48. 2 3 UNI GZ -0.34
49. ***** NOTIONAL LOAD X-DIRECTION*****
50. LOAD 5 LOADTYPE NONE TITLE NLX
51. SELFWEIGHT X -0.015
52. JOINT LOAD
53. 3 4 FX -1.94
54. MEMBER LOAD
55. 1 CON GX -1.94 1.715
```

```
56. *****NOTIONAL LOAD Z-DIRECTION*****
57. LOAD 6 LOADTYPE NONE TITLE NLZ
58. SELFWEIGHT Z -0.015
59. JOINT LOAD
60. 3 4 FZ -1.94
61. MEMBER LOAD
62. 1 CON GZ -1.94 1.715
63. ***** LOAD COMBINATION - SERVICE *****
64. LOAD COMB 7 1.0DL+1.0FL
65. 1 1.0 2 1.0
66. LOAD COMB 8 1.0DL+1.0FL+1.0WLX
67. 1 1.0 2 1.0 3 1.0
68. LOAD COMB 9 1.0DL+1.0FL+1.0WLX
69. 1 1.0 2 1.0 4 1.0
70. LOAD COMB 10 1.0DL+1.0FL+1.0NLX
71. 1 1.0 2 1.0 5 1.0
72. LOAD COMB 11 1.0DL+1.0FL+1.0NLZ
73. 1 1.0 2 1.0 6 1.0
74. ***** LOAD COMBINATION - ULTIMATE *****
75. LOAD COMB 12 1.0DL+1.4FL
76. 1 1.0 2 1.4
77. LOAD COMB 13 1.4DL+1.4FL
78. 1 1.4 2 1.4
79. LOAD COMB 14 1.0DL+1.4FL+1.4WLX
80. 1 1.0 2 1.4 3 1.4
81. LOAD COMB 15 1.0DL+1.4FL+1.4WLZ
82. 1 1.0 2 1.4 4 1.4
83. LOAD COMB 16 1.0DL+1.4FL+1.4NLX
84. 1 1.0 2 1.4 5 1.4
85. LOAD COMB 17 1.0DL+1.4FL+1.4NLZ
86. 1 1.0 2 1.4 6 1.4
87. PERFORM ANALYSIS
```

PROBLEM STATISTICS

NUMBER OF JOINTS/MEMBER+ELEMENTS/SUPPORTS = 6/ 5/ 2

SOLVER USED IS THE OUT-OF-CORE BASIC SOLVER

ORIGINAL/FINAL BAND-WIDTH= 2/ 2/ 18 DOF
TOTAL PRIMARY LOAD CASES = 6, TOTAL DEGREES OF FREEDOM = 24
SIZE OF STIFFNESS MATRIX = 1 DOUBLE KILO-WORDS
REQRD/AVAIL. DISK SPACE = 12.0/ 455918.5 MB

88. LOAD LIST 7 TO 11
89. PRINT JOINT DISPLACEMENTS ALL

JOINT DISPLACEMENT (CM RADIANS) STRUCTURE TYPE = SPACE

JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
1	7	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	8	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	9	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	10	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	11	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
2	7	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	8	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	9	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	10	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	11	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000

4	8	-0.1387	-0.0148	0.0271	-0.0006	0.0003	0.0005	
	9	-0.1174	-0.0148	0.0201	-0.0006	0.0002	0.0004	
	10	-0.1531	-0.0148	0.0271	-0.0006	0.0003	0.0006	
	11	-0.1174	-0.0146	-0.0088	-0.0006	0.0002	0.0004	
	7	-0.1461	-0.0184	0.0287	0.0009	-0.0002	0.0006	
	8	-0.1674	-0.0184	0.0287	0.0009	-0.0002	0.0006	
	9	-0.1461	-0.0184	0.0218	0.0009	-0.0002	0.0006	
	10	-0.1901	-0.0184	0.0287	0.0009	-0.0002	0.0007	
	11	-0.1461	-0.0186	-0.0072	0.0009	-0.0002	0.0006	
	5	7	-0.0980	0.0330	0.0271	-0.0006	0.0002	0.0004
		8	-0.1166	0.0330	0.0271	-0.0006	0.0003	0.0005
9		-0.0980	0.0335	0.0201	-0.0006	0.0002	0.0004	
10		-0.1279	0.0330	0.0271	-0.0006	0.0003	0.0006	
11		-0.0980	0.0362	-0.0088	-0.0006	0.0002	0.0004	
6	7	-0.1319	0.0536	0.0287	0.0009	-0.0002	0.0006	
	8	-0.1505	0.0536	0.0287	0.0009	-0.0002	0.0006	
	9	-0.1319	0.0532	0.0218	0.0009	-0.0002	0.0006	
	10	-0.1716	0.0536	0.0287	0.0009	-0.0002	0.0007	
	11	-0.1319	0.0505	-0.0072	0.0009	-0.0002	0.0006	

***** END OF LATEST ANALYSIS RESULT *****

90. PRINT SUPPORT REACTION ALL

SUPPORT REACTIONS -UNIT KN METE STRUCTURE TYPE = SPACE							

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM Z
1	7	8.92	183.07	-14.45	-19.20	-0.01	-32.90
	8	11.31	183.07	-14.45	-19.20	-0.02	-39.42
	9	8.92	182.79	-13.20	-17.59	-0.01	-32.90
	10	11.69	183.07	-14.45	-19.20	-0.02	-42.96
	11	8.92	181.06	-11.37	-13.09	-0.01	-32.90
2	7	11.09	226.59	14.45	15.43	0.01	-40.93
	8	13.49	226.59	14.45	15.43	0.01	-47.45
	9	11.09	226.87	15.71	17.04	0.01	-40.93
	10	14.50	226.59	14.45	15.43	0.01	-53.32
	11	11.09	228.60	17.54	21.54	0.01	-40.93

***** END OF LATEST ANALYSIS RESULT *****

91. LOAD LIST 12 TO 17

92. PRINT MEMBER FORCES ALL

MEMBER END FORCES STRUCTURE TYPE = SPACE								

ALL UNITS ARE -- KN METE (LOCAL)								
MEMBER	LOAD	JT	AXIAL	SHEAR-Y	SHEAR-Z	TORSION	MOM-Y	MOM-Z
1	12	4	14.45	90.38	-6.19	0.01	0.01	38.44
	3		-14.45	46.85	-3.14	-0.01	-0.02	-34.67
13	4		20.23	126.53	-6.19	0.01	0.01	53.81
	3		-20.23	65.59	-3.14	-0.01	-0.02	-48.54
14	4		14.45	90.38	-7.41	0.01	0.17	38.44
	3		-14.45	46.85	-4.36	-0.01	-0.17	-34.67
15	4		14.45	90.77	-6.19	0.01	0.01	39.43
	3		-14.45	46.46	-3.14	-0.01	-0.02	-33.68
16	4		14.45	90.38	-8.09	0.01	0.03	38.44

	17	4	15.90	93.19	-6.19	0.01	0.01	45.60
	3		-13.01	44.04	-3.14	-0.01	-0.02	-27.51
2	12	1	183.07	-12.48	-14.45	-0.02	19.20	-46.07
	3		-176.87	12.48	14.45	0.02	34.14	0.01
13	1		256.29	-12.48	-20.23	-0.02	26.87	-46.07
	3		-247.61	12.48	20.23	0.02	47.79	0.01
14	1		183.07	-15.83	-14.45	-0.02	19.20	-55.19
	3		-176.87	14.08	14.45	0.02	34.14	0.01
15	1		182.68	-12.48	-12.70	-0.02	16.95	-46.07
	3		-176.48	12.48	14.45	0.02	33.15	0.01
16	1		183.07	-16.36	-14.45	-0.03	19.20	-60.14
	3		-176.87	16.23	14.45	0.03	34.14	0.01
17	1		180.25	-12.48	-10.13	-0.02	10.65	-46.07
	3		-174.05	12.48	10.26	0.02	26.98	0.01
3	12	2	226.59	-15.53	14.45	0.01	-15.43	-57.31
	4		-220.39	15.53	-14.45	-0.01	-37.90	-0.01
13	2		317.23	-15.53	20.23	0.01	-21.61	-57.31
	4		-308.55	15.53	-20.23	-0.01	-53.06	-0.01
14	2		226.59	-18.88	14.45	0.02	-15.43	-66.43
	4		-220.39	17.13	-14.45	-0.02	-37.90	-0.01
15	2		226.98	-15.53	16.21	0.01	-17.68	-57.31
	4		-220.78	15.53	-14.45	-0.01	-38.89	-0.01
16	2		226.59	-20.30	14.45	0.02	-15.43	-74.65
	4		-220.39	20.17	-14.45	-0.02	-37.90	-0.01
17	2		229.40	-15.53	18.78	0.01	-23.98	-57.31
	4		-223.20	15.53	-18.65	-0.01	-45.07	-0.01
4	12	3	0.00	1.34	0.00	0.00	0.00	0.54
	5		0.00	0.00	0.00	0.00	0.00	0.00
13	3		0.00	1.88	0.00	0.00	0.00	0.75
	5		0.00	0.00	0.00	0.00	0.00	0.00
14	3		0.00	1.34	-0.38	0.00	0.15	0.54
	5		0.00	0.00	0.00	0.00	0.00	0.00

MEMBER END FORCES STRUCTURE TYPE = SPACE

ALL UNITS ARE -- KN METE (LOCAL)

MEMBER	LOAD	JT	AXIAL	SHEAR-Y	SHEAR-Z	TORSION	MOM-Y	MOM-Z
15	3		0.00	1.34	0.00	0.00	0.00	0.54
	5		0.00	0.00	0.00	0.00	0.00	0.00
16	3		0.00	1.34	-0.03	0.00	0.01	0.54
	5		0.00	0.00	0.00	0.00	0.00	0.00
17	3		0.03	1.34	0.00	0.00	0.00	0.54
	5		0.00	0.00	0.00	0.00	0.00	0.00
5	12	6	0.00	0.00	0.00	0.00	0.00	0.00
	4		0.00	1.34	0.00	0.00	0.00	-0.54
13	6		0.00	0.00	0.00	0.00	0.00	0.00
	4		0.00	1.88	0.00	0.00	0.00	-0.75
14	6		0.00	0.00	0.00	0.00	0.00	0.00
	4		0.00	1.34	-0.38	0.00	-0.15	-0.54
15	6		0.00	0.00	0.00	0.00	0.00	0.00
	4		0.00	1.34	0.00	0.00	0.00	-0.54
16	6		0.00	0.00	0.00	0.00	0.00	0.00
	4		0.00	1.34	-0.03	0.00	-0.01	-0.54
17	6		0.00	0.00	0.00	0.00	0.00	0.00
	4		0.03	1.34	0.00	0.00	0.00	-0.54

***** END OF LATEST ANALYSIS RESULT *****

93. LOAD LIST ALL
94. PARAMETER 1
95. CODE BS5950

96. BEAM 2 ALL
97. CHECK CODE ALL

STAAD.Pro CODE CHECKING - (BSI)

PROGRAM CODE REVISION V2.12_5950-1_2000

ALL UNITS ARE - KN METE (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
=====					
1 ST	H400X400X13	PASS	ANNEX I.1	0.187	13
		20.23 C	10.50	157.68	-
2 ST	H400X400X13	PASS	ANNEX I.1	0.158	13
		256.29 C	47.79	46.07	-
3 ST	H400X400X13	PASS	ANNEX I.1	0.183	13
		317.23 C	53.06	57.31	-
4 ST	H400X400X13	PASS	BS-4.2.3-(Y)	0.002	13
		0.00	0.00	0.75	0.00
5 ST	H400X400X13	PASS	BS-4.2.3-(Y)	0.002	13
		0.00	0.00	-0.75	0.80

***** END OF TABULATED RESULT OF DESIGN *****

98. FINISH

***** END OF THE STAAD.Pro RUN *****

**** DATE= JAN 31,2013 TIME= 11:15:14 ****

* For questions on STAAD.Pro, please contact *
* Research Engineers Offices at the following locations *
* *
* Telephone Email *
* USA: +1 (714)974-2500 support@bentley.com *
* CANADA +1 (905)632-4771 detech@odandetech.com *
* UK +44(1454)207-000 support@bentley.com *
* NORWAY +47 67 57 21 30 staad@edr.no *
* SINGAPORE +65 6225-6158 support@bentley.com *
* INDIA +91(033)4006-2021 support@bentley.com *
* JAPAN +81(03)5952-6500 eng-eye@crc.co.jp *
* CHINA +86(411)8479-1166 support@bentley.com *
* THAILAND +66(0)2645-1018/19 support@bentley.com *
* *
* North America support@bentley.com *
* Europe support@bentley.com *
* Asia support@bentley.com *
